



H.D. Cooke Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002350	3/14/2022	3/14/2023	1	Cooler	In gym 142 High Left	WF-03142022-002350	1/16/2023	FT-FY23-12292022-002350-A	<1	FT-FY23-12292022-002350-B	<1
WS- 002351	3/14/2022	3/14/2023	1	Cooler	In gym 142 Low Right	WF-03142022-002351	1/16/2023	FT-FY23-12292022-002351-A	<1	FT-FY23-12292022-002351-B	<1
WS- 002352	3/14/2022	3/14/2023	1	Break Room	In work room 130	WF-03142022-002352	1/16/2023	FT-FY23-12292022-002352-A	<1	FT-FY23-12292022-002352-B	<1
WS- 002354	3/14/2022	3/14/2023	1	Combo Fountain	In classroom 132	WF-03142022-002354	1/16/2023	FT-FY23-12292022-002354-A	<1	FT-FY23-12292022-002354-B	<1
WS- 002355	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 132	WF-08222022-002355	1/16/2023	FT-FY23-12292022-002355-A	<1	FT-FY23-12292022-002355-B	<1
WS- 002356	3/14/2022	3/14/2023	1	Combo Fountain	In classroom 136	WF-03142022-002356	1/16/2023	FT-FY23-12292022-002356-A	<1	FT-FY23-12292022-002356-B	<1
WS- 002357	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 136	WF-08222022-002357	1/16/2023	FT-FY23-12292022-002357-A	<1	FT-FY23-12292022-002357-B	<1
WS- 002358	3/14/2022	3/14/2023	1	Combo Fountain	In classroom 133	WF-03142022-002358	1/16/2023	FT-FY23-12292022-002358-A	<1	FT-FY23-12292022-002358-B	<1
WS- 002359	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 133	WF-08222022-002359	1/16/2023	FT-FY23-12292022-002359-A	<1	FT-FY23-12292022-002359-B	<1
WS- 002360	3/14/2022	3/14/2023	1	Combo Fountain	In classroom 135	WF-03142022-002360	1/16/2023	FT-FY23-12292022-002360-A	<1	FT-FY23-12292022-002360-B	<1
WS- 002361	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 135	WF-08222022-002361	1/16/2023	FT-FY23-12292022-002361-A	<1	FT-FY23-12292022-002361-B	<1
WS- 002366	3/14/2022	3/14/2023	1	Cooler	In hallway across from room 105 High Left	WF-03142022-002366	1/16/2023	FT-FY23-12292022-002366-A	<1	FT-FY23-12292022-002366-B	<1
WS- 002367	3/14/2022	3/14/2023	1	Cooler	In hallway across from room 105 Low Right	WF-03142022-002367	1/16/2023	FT-FY23-12292022-002367-A	<1	FT-FY23-12292022-002367-B	<1
WS- 002368	3/14/2022	3/14/2023	1	Health Suite	In health suite in exam room 103E	WF-03142022-002368	1/16/2023	FT-FY23-12292022-002368-A	<1	FT-FY23-12292022-002368-B	<1
WS- 002369	3/14/2022	3/14/2023	1	Health Suite	In health suite in exam room 103C	WF-03142022-002369	1/16/2023	FT-FY23-12292022-002369-A	<1	FT-FY23-12292022-002369-B	<1
WS- 002370	3/14/2022	3/14/2023	1	Break Room	In break room 110	WF-03142022-002370	1/16/2023	FT-FY23-12292022-002370-A	<1	FT-FY23-12292022-002370-B	<1
WS- 002374	3/14/2022	3/14/2023	2	Cooler	In hallway across from room 204 High Left	WF-03142022-002374	1/16/2023	FT-FY23-12292022-002374-A	<1	FT-FY23-12292022-002374-B	<1
WS- 002375	3/14/2022	3/14/2023	2	Cooler	In hallway across from room 204 Low Right	WF-03142022-002375	1/16/2023	FT-FY23-12292022-002375-A	<1	FT-FY23-12292022-002375-B	<1
WS- 002376	3/14/2022	3/14/2023	2	Combo Fountain	In classroom 205	WF-03142022-002376	1/16/2023	FT-FY23-12292022-002376-A	<1	FT-FY23-12292022-002376-B	<1
WS- 002377	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 205	WF-08222022-002377	1/16/2023	FT-FY23-12292022-002377-A	<1	FT-FY23-12292022-002377-B	<1
WS- 002378	3/14/2022	3/14/2023	2	Combo Fountain	In classroom 204	WF-03142022-002378	1/16/2023	FT-FY23-12292022-002378-A	<1	FT-FY23-12292022-002378-B	<1
WS- 002379	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 204	WF-08222022-002379	1/16/2023	FT-FY23-12292022-002379-A	<1	FT-FY23-12292022-002379-B	<1
WS- 002380	3/14/2022	3/14/2023	2	Combo Fountain	In classroom 202	WF-03142022-002380	1/16/2023	FT-FY23-12292022-002380-A	<1	FT-FY23-12292022-002380-B	<1
WS- 002381	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 202	WF-08222022-002381	1/16/2023	FT-FY23-12292022-002381-A	<1	FT-FY23-12292022-002381-B	<1
WS- 002382	3/14/2022	3/14/2023	2	Combo Fountain	In classroom 203	WF-03142022-002382	1/16/2023	FT-FY23-12292022-002382-A	<1	FT-FY23-12292022-002382-B	<1
WS- 002383	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 203	WF-08222022-002383	1/16/2023	FT-FY23-12292022-002383-A	<1	FT-FY23-12292022-002383-B	<1
WS- 002384	3/14/2022	3/14/2023	2	Combo Fountain	In classroom 210	WF-03142022-002384	1/16/2023	FT-FY23-12292022-002384-A	<1	FT-FY23-12292022-002384-B	<1
WS- 002385	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 210	WF-08222022-002385	1/16/2023	FT-FY23-12292022-002385-A	<1	FT-FY23-12292022-002385-B	<1
WS- 002386	3/14/2022	3/14/2023	2	Combo Fountain	In classroom 211	WF-03142022-002386	1/16/2023	FT-FY23-12292022-002386-A	<1	FT-FY23-12292022-002386-B	<1
WS- 002387	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 211	WF-08222022-002387	1/16/2023	FT-FY23-12292022-002387-A	<1	FT-FY23-12292022-002387-B	<1
WS- 002388	10/18/2022	10/18/2023	2	Combo Fountain	In classroom 212	WF-10182022-002388	1/16/2023	FT-FY23-12292022-002388-A	<1	FT-FY23-12292022-002388-B	<1
WS- 002389	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 212	WF-08222022-002389	1/16/2023	FT-FY23-12292022-002389-A	<1	FT-FY23-12292022-002389-B	<1
WS- 002390	3/14/2022	3/14/2023	2	Combo Fountain	In classroom 213	WF-03142022-002390	1/16/2023	FT-FY23-12292022-002390-A	<1	FT-FY23-12292022-002390-B	<1
WS- 002391	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 213	WF-08222022-002391	1/16/2023	FT-FY23-12292022-002391-A	<1	FT-FY23-12292022-002391-B	<1
WS- 002392	3/14/2022	3/14/2023	2	Combo Fountain	In resource room 241	WF-03142022-002392	1/16/2023	FT-FY23-12292022-002392-A	<1	FT-FY23-12292022-002392-B	<1

WS-002393	8/22/2022	8/22/2023	2	Combo Faucet	In resource room 241		WF-08222022-002393	1/16/2023	FT-FY23-12292022-002393-A	<1	FT-FY23-12292022-002393-B	<1
WS-002395	8/22/2022	8/22/2023	2	Combo Faucet	In resource room 230		WF-08222022-002395	1/16/2023	FT-FY23-12292022-002395-A	<1	FT-FY23-12292022-002395-B	<1
WS-002399	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 231		WF-08222022-002399	1/16/2023	FT-FY23-12292022-002399-A	<1	FT-FY23-12292022-002399-B	<1
WS-002401	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 235		WF-08222022-002401	1/16/2023	FT-FY23-12292022-002401-A	<1	FT-FY23-12292022-002401-B	<1
WS-002403	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 232		WF-08222022-002403	1/16/2023	FT-FY23-12292022-002403-A	<1	FT-FY23-12292022-002403-B	<1
WS-002405	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 234		WF-08222022-002405	1/16/2023	FT-FY23-12292022-002405-A	<1	FT-FY23-12292022-002405-B	<1
WS-002406	3/14/2022	3/14/2023	3	Cooler	In hallway across from room 304	High Left	WF-03142022-002406	1/16/2023	FT-FY23-12292022-002406-A	<1	FT-FY23-12292022-002406-B	<1
WS-002408	3/14/2022	3/14/2023	3	Combo Fountain	In classroom 303		WF-03142022-002408	1/16/2023	FT-FY23-12292022-002408-A	<1	FT-FY23-12292022-002408-B	<1
WS-002409	8/22/2022	8/22/2023	3	Combo Faucet	In classroom 303		WF-08222022-002409	1/16/2023	FT-FY23-12292022-002409-A	<1	FT-FY23-12292022-002409-B	<1
WS-002410	8/22/2022	8/22/2023	3	Combo Faucet	In classroom 302		WF-08222022-002410	1/16/2023	FT-FY23-12292022-002410-A	<1	FT-FY23-12292022-002410-B	<1
WS-002411	3/14/2022	3/14/2023	3	Combo Fountain	In classroom 302		WF-03142022-002411	1/16/2023	FT-FY23-12292022-002411-A	<1	FT-FY23-12292022-002411-B	<1
WS-002412	3/14/2022	3/14/2023	3	Combo Fountain	In classroom 304		WF-03142022-002412	1/16/2023	FT-FY23-12292022-002412-A	<1	FT-FY23-12292022-002412-B	<1
WS-002413	8/22/2022	8/22/2023	3	Combo Faucet	In classroom 304		WF-08222022-002413	1/16/2023	FT-FY23-12292022-002413-A	<1	FT-FY23-12292022-002413-B	<1
WS-002414	3/14/2022	3/14/2023	3	Combo Fountain	In classroom 305		WF-03142022-002414	1/16/2023	FT-FY23-12292022-002414-A	<1	FT-FY23-12292022-002414-B	<1
WS-002415	8/22/2022	8/22/2023	3	Combo Faucet	In classroom 305		WF-08222022-002415	1/16/2023	FT-FY23-12292022-002415-A	<1	FT-FY23-12292022-002415-B	<1
WS-002416	3/14/2022	3/14/2023	3	Break Room	In staff lounge 319		WF-03142022-002416	1/16/2023	FT-FY23-12292022-002416-A	<1	FT-FY23-12292022-002416-B	<1
WS-002417	3/14/2022	3/14/2023	3	Combo Fountain	In classroom 310		WF-03142022-002417	1/16/2023	FT-FY23-12292022-002417-A	<1	FT-FY23-12292022-002417-B	<1
WS-002418	8/22/2022	8/22/2023	3	Combo Faucet	In classroom 310		WF-08222022-002418	1/16/2023	FT-FY23-12292022-002418-A	<1	FT-FY23-12292022-002418-B	<1
WS-002419	3/14/2022	3/14/2023	3	Combo Fountain	In classroom 311		WF-03142022-002419	1/16/2023	FT-FY23-12292022-002419-A	<1	FT-FY23-12292022-002419-B	<1
WS-002420	8/22/2022	8/22/2023	3	Combo Faucet	In classroom 311		WF-08222022-002420	1/16/2023	FT-FY23-12292022-002420-A	<1	FT-FY23-12292022-002420-B	<1
WS-002421	3/14/2022	3/14/2023	3	Combo Fountain	In classroom 312		WF-03142022-002421	1/16/2023	FT-FY23-12292022-002421-A	<1	FT-FY23-12292022-002421-B	<1
WS-002422	8/22/2022	8/22/2023	3	Combo Faucet	In classroom 312		WF-08222022-002422	1/16/2023	FT-FY23-12292022-002422-A	<1	FT-FY23-12292022-002422-B	<1
WS-002423	3/14/2022	3/14/2023	3	Combo Fountain	In classroom 313		WF-03142022-002423	1/16/2023	FT-FY23-12292022-002423-A	<1	FT-FY23-12292022-002423-B	<1
WS-002424	8/22/2022	8/22/2023	3	Combo Faucet	In classroom 313		WF-08222022-002424	1/16/2023	FT-FY23-12292022-002424-A	<1	FT-FY23-12292022-002424-B	<1
WS-002427	3/14/2022	3/14/2023	3	Combo Fountain	In resource room 341		WF-03142022-002427	1/16/2023	FT-FY23-12292022-002427-A	<1	FT-FY23-12292022-002427-B	<1
WS-002428	8/22/2022	8/22/2023	3	Combo Faucet	In resource room 341		WF-08222022-002428	1/16/2023	FT-FY23-12292022-002428-A	<1	FT-FY23-12292022-002428-B	<1
WS-002429	3/14/2022	3/14/2023	2	Combo Fountain	In classroom 221		WF-03142022-002429	1/16/2023	FT-FY23-12292022-002429-A	<1	FT-FY23-12292022-002429-B	<1
WS-002430	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 221		WF-08222022-002430	1/16/2023	FT-FY23-12292022-002430-A	<1	FT-FY23-12292022-002430-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002363	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen second clockwise from entry door	Left	WF-12192022-002363	1/16/2023	FT-FY23-12292022-002363-A	<1	FT-FY23-12292022-002363-B	<1
WS-002364	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen third clockwise from entry door	Right	WF-12192022-002364	1/16/2023	FT-FY23-12292022-002364-A	<1	FT-FY23-12292022-002364-B	<1
WS-002365	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen fourth clockwise from entry door		WF-12192022-002365	1/16/2023	FT-FY23-12292022-002365-A	<1	FT-FY23-12292022-002365-B	<1