



# H.D. Cooke Elementary School Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002350	3/23/2021	3/23/2022	1	Cooler	In gym 142 High Left	WF-03232021-002350	11/23/2021	FT-FY22-11122021-002350-A	<1	FT-FY22-11122021-002350-B	<1
WS-002351	3/23/2021	3/23/2022	1	Cooler	In gym 142 Low Right	WF-03232021-002351	11/23/2021	FT-FY22-11122021-002351-A	<1	FT-FY22-11122021-002351-B	<1
WS-002352	3/23/2021	3/23/2022	1	Break Room	In work room 130	WF-03232021-002352	11/23/2021	FT-FY22-11122021-002352-A	<1	FT-FY22-11122021-002352-B	<1
WS-002353	3/23/2021	3/23/2022	1	Break Room	In staff lounge 137	WF-03232021-002353	11/23/2021	FT-FY22-11122021-002353-A	<1	FT-FY22-11122021-002353-B	<1
WS-002354	3/23/2021	3/23/2022	1	Combo Fountain	In classroom 132	WF-03232021-002354	11/23/2021	FT-FY22-11122021-002354-A	<1	FT-FY22-11122021-002354-B	<1
WS-002355	8/31/2021	8/31/2022	1	Combo Faucet	In classroom 132	WF-08312021-002355	11/23/2021	FT-FY22-11122021-002355-A	<1	FT-FY22-11122021-002355-B	<1
WS-002356	3/23/2021	3/23/2022	1	Combo Fountain	In classroom 136	WF-03232021-002356	11/23/2021	FT-FY22-11122021-002356-A	<1	FT-FY22-11122021-002356-B	<1
WS-002357	8/31/2021	8/31/2022	1	Combo Faucet	In classroom 136	WF-08312021-002357	11/23/2021	FT-FY22-11122021-002357-A	<1	FT-FY22-11122021-002357-B	<1
WS-002358	3/23/2021	3/23/2022	1	Combo Fountain	In classroom 133	WF-03232021-002358	11/23/2021	FT-FY22-11122021-002358-A	<1	FT-FY22-11122021-002358-B	<1
WS-002359	8/31/2021	8/31/2022	1	Combo Faucet	In classroom 133	WF-08312021-002359	11/23/2021	FT-FY22-11122021-002359-A	<1	FT-FY22-11122021-002359-B	<1
WS-002360	3/23/2021	3/23/2022	1	Combo Fountain	In classroom 135	WF-03232021-002360	11/23/2021	FT-FY22-11122021-002360-A	<1	FT-FY22-11122021-002360-B	<1
WS-002361	8/31/2021	8/31/2022	1	Combo Faucet	In classroom 135	WF-08312021-002361	11/23/2021	FT-FY22-11122021-002361-A	<1	FT-FY22-11122021-002361-B	<1
WS-002366	3/23/2021	3/23/2022	1	Cooler	In hallway across from room 105 High Left	WF-03232021-002366	11/23/2021	FT-FY22-11122021-002366-A	<1	FT-FY22-11122021-002366-B	<1
WS-002367	3/23/2021	3/23/2022	1	Cooler	In hallway across from room 105 Low Right	WF-03232021-002367	11/23/2021	FT-FY22-11122021-002367-A	<1	FT-FY22-11122021-002367-B	<1
WS-002368	3/23/2021	3/23/2022	1	Health Suite	In health suite in exam room 103E	WF-03232021-002368	11/23/2021	FT-FY22-11122021-002368-A	<1	FT-FY22-11122021-002368-B	<1
WS-002369	3/23/2021	3/23/2022	1	Health Suite	In health suite in exam room 103C	WF-03232021-002369	11/23/2021	FT-FY22-11122021-002369-A	<1	FT-FY22-11122021-002369-B	<1
WS-002370	3/23/2021	3/23/2022	1	Break Room	In break room 110	WF-03232021-002370	11/23/2021	FT-FY22-11122021-002370-A	<1	FT-FY22-11122021-002370-B	<1
WS-002374	3/23/2021	3/23/2022	2	Cooler	In hallway across from room 204 High Left	WF-03232021-002374	11/23/2021	FT-FY22-11122021-002374-A	<1	FT-FY22-11122021-002374-B	<1
WS-002375	3/23/2021	3/23/2022	2	Cooler	In hallway across from room 204 Low Right	WF-03232021-002375	11/23/2021	FT-FY22-11122021-002375-A	<1	FT-FY22-11122021-002375-B	<1
WS-002376	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 205	WF-03232021-002376	11/23/2021	FT-FY22-11122021-002376-A	<1	FT-FY22-11122021-002376-B	<1
WS-002377	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 205	WF-08312021-002377	11/23/2021	FT-FY22-11122021-002377-A	<1	FT-FY22-11122021-002377-B	<1
WS-002378	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 204	WF-03232021-002378	11/23/2021	FT-FY22-11122021-002378-A	<1	FT-FY22-11122021-002378-B	<1
WS-002379	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 204	WF-08312021-002379	11/23/2021	FT-FY22-11122021-002379-A	<1	FT-FY22-11122021-002379-B	<1
WS-002380	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 202	WF-03232021-002380	11/23/2021	FT-FY22-11122021-002380-A	<1	FT-FY22-11122021-002380-B	<1
WS-002381	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 202	WF-08312021-002381	11/23/2021	FT-FY22-11122021-002381-A	<1	FT-FY22-11122021-002381-B	<1
WS-002382	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 203	WF-03232021-002382	11/23/2021	FT-FY22-11122021-002382-A	<1	FT-FY22-11122021-002382-B	<1
WS-002383	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 203	WF-08312021-002383	11/23/2021	FT-FY22-11122021-002383-A	<1	FT-FY22-11122021-002383-B	<1
WS-002384	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 210	WF-03232021-002384	11/23/2021	FT-FY22-11122021-002384-A	<1	FT-FY22-11122021-002384-B	<1
WS-002385	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 210	WF-08312021-002385	11/23/2021	FT-FY22-11122021-002385-A	<1	FT-FY22-11122021-002385-B	<1
WS-002386	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 211	WF-03232021-002386	11/23/2021	FT-FY22-11122021-002386-A	<1	FT-FY22-11122021-002386-B	<1
WS-002387	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 211	WF-08312021-002387	11/23/2021	FT-FY22-11122021-002387-A	<1	FT-FY22-11122021-002387-B	<1
WS-002388	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 212	WF-03232021-002388	11/23/2021	FT-FY22-11122021-002388-A	<1	FT-FY22-11122021-002388-B	<1
WS-002389	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 212	WF-08312021-002389	11/23/2021	FT-FY22-11122021-002389-A	<1	FT-FY22-11122021-002389-B	<1
WS-002390	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 213	WF-03232021-002390	11/23/2021	FT-FY22-11122021-002390-A	<1	FT-FY22-11122021-002390-B	<1
WS-002391	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 213	WF-08312021-002391	11/23/2021	FT-FY22-11122021-002391-A	<1	FT-FY22-11122021-002391-B	<1

WS-002392	3/23/2021	3/23/2022	2	Combo Fountain	In resource room 241		WF-03232021-002392	11/23/2021	FT-FY22-11122021-002392-A	<1	FT-FY22-11122021-002392-B	<1
WS-002393	8/31/2021	8/31/2022	2	Combo Faucet	In resource room 241		WF-08312021-002393	11/23/2021	FT-FY22-11122021-002393-A	<1	FT-FY22-11122021-002393-B	<1
WS-002394	3/23/2021	3/23/2022	2	Combo Fountain	In resource room 230		WF-03232021-002394	11/23/2021	FT-FY22-11122021-002394-A	<1	FT-FY22-11122021-002394-B	<1
WS-002395	8/31/2021	8/31/2022	2	Combo Faucet	In resource room 230		WF-08312021-002395	11/23/2021	FT-FY22-11122021-002395-A	<1	FT-FY22-11122021-002395-B	<1
WS-002396	3/23/2021	3/23/2022	2	Combo Fountain	In resource room 236		WF-03232021-002396	11/23/2021	FT-FY22-11122021-002396-A	<1	FT-FY22-11122021-002396-B	<1
WS-002397	8/31/2021	8/31/2022	2	Combo Faucet	In resource room 236		WF-08312021-002397	11/23/2021	FT-FY22-11122021-002397-A	<1	FT-FY22-11122021-002397-B	<1
WS-002398	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 231		WF-03232021-002398	11/23/2021	FT-FY22-11122021-002398-A	<1	FT-FY22-11122021-002398-B	<1
WS-002399	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 231		WF-08312021-002399	11/23/2021	FT-FY22-11122021-002399-A	<1	FT-FY22-11122021-002399-B	<1
WS-002400	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 235		WF-03232021-002400	11/23/2021	FT-FY22-11122021-002400-A	<1	FT-FY22-11122021-002400-B	<1
WS-002401	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 235		WF-08312021-002401	11/23/2021	FT-FY22-11122021-002401-A	<1	FT-FY22-11122021-002401-B	<1
WS-002403	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 232		WF-08312021-002403	11/23/2021	FT-FY22-11122021-002403-A	<1	FT-FY22-11122021-002403-B	<1
WS-002404	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 234		WF-03232021-002404	11/23/2021	FT-FY22-11122021-002404-A	1.1	FT-FY22-11122021-002404-B	<1
WS-002405	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 234		WF-08312021-002405	11/23/2021	FT-FY22-11122021-002405-A	<1	FT-FY22-11122021-002405-B	<1
WS-002406	3/23/2021	3/23/2022	3	Cooler	In hallway across from room 304	High Left	WF-03232021-002406	11/23/2021	FT-FY22-11122021-002406-A	<1	FT-FY22-11122021-002406-B	<1
WS-002407	3/23/2021	3/23/2022	3	Cooler	In hallway across from room 304	Low Right	WF-03232021-002407	11/23/2021	FT-FY22-11122021-002407-A	<1	FT-FY22-11122021-002407-B	<1
WS-002408	3/23/2021	3/23/2022	3	Combo Fountain	In classroom 303		WF-03232021-002408	11/23/2021	FT-FY22-11122021-002408-A	<1	FT-FY22-11122021-002408-B	<1
WS-002409	8/31/2021	8/31/2022	3	Combo Faucet	In classroom 303		WF-08312021-002409	11/23/2021	FT-FY22-11122021-002409-A	<1	FT-FY22-11122021-002409-B	<1
WS-002410	8/31/2021	8/31/2022	3	Combo Faucet	In classroom 302		WF-08312021-002410	11/23/2021	FT-FY22-11122021-002410-A	<1	FT-FY22-11122021-002410-B	<1
WS-002411	3/23/2021	3/23/2022	3	Combo Fountain	In classroom 302		WF-03232021-002411	11/23/2021	FT-FY22-11122021-002411-A	<1	FT-FY22-11122021-002411-B	<1
WS-002412	3/23/2021	3/23/2022	3	Combo Fountain	In classroom 304		WF-03232021-002412	11/23/2021	FT-FY22-11122021-002412-A	<1	FT-FY22-11122021-002412-B	<1
WS-002413	8/31/2021	8/31/2022	3	Combo Faucet	In classroom 304		WF-08312021-002413	11/23/2021	FT-FY22-11122021-002413-A	<1	FT-FY22-11122021-002413-B	<1
WS-002414	3/23/2021	3/23/2022	3	Combo Fountain	In classroom 305		WF-03232021-002414	11/23/2021	FT-FY22-11122021-002414-A	<1	FT-FY22-11122021-002414-B	<1
WS-002415	8/31/2021	8/31/2022	3	Combo Faucet	In classroom 305		WF-08312021-002415	11/23/2021	FT-FY22-11122021-002415-A	<1	FT-FY22-11122021-002415-B	<1
WS-002416	3/23/2021	3/23/2022	3	Break Room	In staff lounge 319		WF-03232021-002416	11/23/2021	FT-FY22-11122021-002416-A	<1	FT-FY22-11122021-002416-B	<1
WS-002417	3/23/2021	3/23/2022	3	Combo Fountain	In classroom 310		WF-03232021-002417	11/23/2021	FT-FY22-11122021-002417-A	<1	FT-FY22-11122021-002417-B	<1
WS-002418	8/31/2021	8/31/2022	3	Combo Faucet	In classroom 310		WF-08312021-002418	11/23/2021	FT-FY22-11122021-002418-A	<1	FT-FY22-11122021-002418-B	<1
WS-002419	3/23/2021	3/23/2022	3	Combo Fountain	In classroom 311		WF-03232021-002419	11/23/2021	FT-FY22-11122021-002419-A	<1	FT-FY22-11122021-002419-B	<1
WS-002420	8/31/2021	8/31/2022	3	Combo Faucet	In classroom 311		WF-08312021-002420	11/23/2021	FT-FY22-11122021-002420-A	<1	FT-FY22-11122021-002420-B	<1
WS-002421	3/23/2021	3/23/2022	3	Combo Fountain	In classroom 312		WF-03232021-002421	11/23/2021	FT-FY22-11122021-002421-A	<1	FT-FY22-11122021-002421-B	<1
WS-002422	8/31/2021	8/31/2022	3	Combo Faucet	In classroom 312		WF-08312021-002422	11/23/2021	FT-FY22-11122021-002422-A	<1	FT-FY22-11122021-002422-B	<1
WS-002423	3/23/2021	3/23/2022	3	Combo Fountain	In classroom 313		WF-03232021-002423	11/23/2021	FT-FY22-11122021-002423-A	<1	FT-FY22-11122021-002423-B	<1
WS-002424	8/31/2021	8/31/2022	3	Combo Faucet	In classroom 313		WF-08312021-002424	11/23/2021	FT-FY22-11122021-002424-A	<1	FT-FY22-11122021-002424-B	<1
WS-002425	3/23/2021	3/23/2022	3	Combo Fountain	In classroom 314		WF-03232021-002425	11/23/2021	FT-FY22-11122021-002425-A	<1	FT-FY22-11122021-002425-B	<1
WS-002427	3/23/2021	3/23/2022	3	Combo Fountain	In resource room 341		WF-03232021-002427	11/23/2021	FT-FY22-11122021-002427-A	<1	FT-FY22-11122021-002427-B	<1
WS-002428	8/31/2021	8/31/2022	3	Combo Faucet	In resource room 341		WF-08312021-002428	11/23/2021	FT-FY22-11122021-002428-A	<1	FT-FY22-11122021-002428-B	<1
WS-002429	3/23/2021	3/23/2022	2	Combo Fountain	In classroom 221		WF-03232021-002429	11/23/2021	FT-FY22-11122021-002429-A	<1	FT-FY22-11122021-002429-B	<1
WS-002430	8/31/2021	8/31/2022	2	Combo Faucet	In classroom 221		WF-08312021-002430	11/23/2021	FT-FY22-11122021-002430-A	<1	FT-FY22-11122021-002430-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002363	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen second clockwise from entry door      Left	WF-01062021-002363	11/23/2021	FT-FY22-11122021-002363-A	<1	FT-FY22-11122021-002363-B	<1
WS- 002364	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen third clockwise from entry door      Right	WF-01062021-002364	11/23/2021	FT-FY22-11122021-002364-A	<1	FT-FY22-11122021-002364-B	<1
WS- 002365	1/6/2021	1/6/2022	1	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-01062021-002365	11/23/2021	FT-FY22-11122021-002365-A	<1	FT-FY22-11122021-002365-B	<1