



H.D. Cooke ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002350	4/9/2019	4/9/2020	1	Cooler	In gym 142 High Left	WF-04092019-002350	10/25/2019	FT-FY20-102019-002350-A	<1	FT-FY20-102019-002350-B	<1
WS- 002351	4/9/2019	4/9/2020	1	Cooler	In gym 142 Low Right	WF-04092019-002351	10/25/2019	FT-FY20-102019-002351-A	<1	FT-FY20-102019-002351-B	<1
WS- 002352	4/9/2019	4/9/2020	1	Break Room	In work room 130	WF-04092019-002352	10/25/2019	FT-FY20-102019-002352-A	<1	FT-FY20-102019-002352-B	<1
WS- 002353	4/9/2019	4/9/2020	1	Break Room	In staff lounge 137	WF-04092019-002353	10/25/2019	FT-FY20-102019-002353-A	<1	FT-FY20-102019-002353-B	<1
WS- 002354	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 132	WF-04092019-002354	10/25/2019	FT-FY20-102019-002354-A	<1	FT-FY20-102019-002354-B	<1
WS- 002355	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 132	WF-09182019-002355	10/25/2019	FT-FY20-102019-002355-A	<1	FT-FY20-102019-002355-B	<1
WS- 002356	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 136	WF-04092019-002356	10/25/2019	FT-FY20-102019-002356-A	<1	FT-FY20-102019-002356-B	<1
WS- 002357	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 136	WF-09182019-002357	10/25/2019	FT-FY20-102019-002357-A	1.1	FT-FY20-102019-002357-B	<1
WS- 002358	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 133	WF-04092019-002358	10/25/2019	FT-FY20-102019-002358-A	<1	FT-FY20-102019-002358-B	<1
WS- 002359	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 133	WF-09182019-002359	10/25/2019	FT-FY20-102019-002359-A	<1	FT-FY20-102019-002359-B	<1
WS- 002360	4/9/2019	4/9/2020	1	Combo Fountain	In classroom 135	WF-04092019-002360	10/25/2019	FT-FY20-102019-002360-A	<1	FT-FY20-102019-002360-B	<1
WS- 002361	9/18/2019	9/18/2020	1	Combo Faucet	In classroom 135	WF-09182019-002361	10/25/2019	FT-FY20-102019-002361-A	<1	FT-FY20-102019-002361-B	<1
WS- 002366	4/9/2019	4/9/2020	1	Cooler	In hallway across from room 105 High Left	WF-04092019-002366	10/25/2019	FT-FY20-102019-002366-A	<1	FT-FY20-102019-002366-B	<1
WS- 002367	4/9/2019	4/9/2020	1	Cooler	In hallway across from room 105 Low Right	WF-04092019-002367	10/25/2019	FT-FY20-102019-002367-A	<1	FT-FY20-102019-002367-B	<1
WS- 002368	4/9/2019	4/9/2020	1	Health Suite	In health suite in exam room 103E	WF-04092019-002368	10/25/2019	FT-FY20-102019-002368-A	<1	FT-FY20-102019-002368-B	<1
WS- 002369	4/9/2019	4/9/2020	1	Health Suite	In health suite in exam room 103C	WF-04092019-002369	10/25/2019	FT-FY20-102019-002369-A	2.7	FT-FY20-102019-002369-B	<1
WS- 002370	4/9/2019	4/9/2020	1	Break Room	In break room 110	WF-04092019-002370	10/25/2019	FT-FY20-102019-002370-A	<1	FT-FY20-102019-002370-B	<1
WS- 002374	4/9/2019	4/9/2020	2	Cooler	In hallway across from room 204 High Left	WF-04092019-002374	10/25/2019	FT-FY20-102019-002374-A	<1	FT-FY20-102019-002374-B	<1
WS- 002375	4/9/2019	4/9/2020	2	Cooler	In hallway across from room 204 Low Right	WF-04092019-002375	10/25/2019	FT-FY20-102019-002375-A	<1	FT-FY20-102019-002375-B	<1
WS- 002376	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 205	WF-04092019-002376	10/25/2019	FT-FY20-102019-002376-A	<1	FT-FY20-102019-002376-B	<1
WS- 002377	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 205	WF-09182019-002377	10/25/2019	FT-FY20-102019-002377-A	1.1	FT-FY20-102019-002377-B	<1
WS- 002378	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 204	WF-04092019-002378	10/25/2019	FT-FY20-102019-002378-A	<1	FT-FY20-102019-002378-B	<1
WS- 002379	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 204	WF-09182019-002379	10/25/2019	FT-FY20-102019-002379-A	<1	FT-FY20-102019-002379-B	<1
WS- 002380	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 202	WF-04092019-002380	10/25/2019	FT-FY20-102019-002380-A	<1	FT-FY20-102019-002380-B	<1
WS- 002381	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 202	WF-09182019-002381	10/25/2019	FT-FY20-102019-002381-A	<1	FT-FY20-102019-002381-B	<1
WS- 002382	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 203	WF-04092019-002382	10/25/2019	FT-FY20-102019-002382-A	<1	FT-FY20-102019-002382-B	<1
WS- 002383	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 203	WF-09182019-002383	10/25/2019	FT-FY20-102019-002383-A	<1	FT-FY20-102019-002383-B	<1
WS- 002384	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 210	WF-04092019-002384	10/25/2019	FT-FY20-102019-002384-A	<1	FT-FY20-102019-002384-B	<1
WS- 002385	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 210	WF-09182019-002385	10/25/2019	FT-FY20-102019-002385-A	1.1	FT-FY20-102019-002385-B	<1
WS- 002386	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 211	WF-04092019-002386	10/25/2019	FT-FY20-102019-002386-A	<1	FT-FY20-102019-002386-B	<1
WS- 002387	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 211	WF-09182019-002387	10/25/2019	FT-FY20-102019-002387-A	<1	FT-FY20-102019-002387-B	<1
WS- 002388	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 212	WF-04092019-002388	10/25/2019	FT-FY20-102019-002388-A	<1	FT-FY20-102019-002388-B	<1
WS- 002389	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 212	WF-09182019-002389	10/25/2019	FT-FY20-102019-002389-A	<1	FT-FY20-102019-002389-B	<1
WS- 002390	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 213	WF-04092019-002390	10/25/2019	FT-FY20-102019-002390-A	<1	FT-FY20-102019-002390-B	<1

WS-002391	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 213		WF-09182019-002391	10/25/2019	FT-FY20-102019-002391-A	<1	FT-FY20-102019-002391-B	<1
WS-002392	4/9/2019	4/9/2020	2	Combo Fountain	In resource room 241		WF-04092019-002392	10/25/2019	FT-FY20-102019-002392-A	1.1	FT-FY20-102019-002392-B	<1
WS-002393	9/18/2019	9/18/2020	2	Combo Faucet	In resource room 241		WF-09182019-002393	10/25/2019	FT-FY20-102019-002393-A	<1	FT-FY20-102019-002393-B	<1
WS-002394	4/9/2019	4/9/2020	2	Combo Fountain	In resource room 230		WF-04092019-002394	10/25/2019	FT-FY20-102019-002394-A	<1	FT-FY20-102019-002394-B	<1
WS-002395	9/18/2019	9/18/2020	2	Combo Faucet	In resource room 230		WF-09182019-002395	10/25/2019	FT-FY20-102019-002395-A	<1	FT-FY20-102019-002395-B	<1
WS-002396	4/9/2019	4/9/2020	2	Combo Fountain	In resource room 236		WF-04092019-002396	10/25/2019	FT-FY20-102019-002396-A	<1	FT-FY20-102019-002396-B	<1
WS-002397	9/18/2019	9/18/2020	2	Combo Faucet	In resource room 236		WF-09182019-002397	10/25/2019	FT-FY20-102019-002397-A	2.9	FT-FY20-102019-002397-B	<1
WS-002398	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 231		WF-04092019-002398	10/25/2019	FT-FY20-102019-002398-A	<1	FT-FY20-102019-002398-B	<1
WS-002399	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 231		WF-09182019-002399	10/25/2019	FT-FY20-102019-002399-A	<1	FT-FY20-102019-002399-B	<1
WS-002400	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 235		WF-04092019-002400	10/25/2019	FT-FY20-102019-002400-A	<1	FT-FY20-102019-002400-B	<1
WS-002401	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 235		WF-09182019-002401	10/25/2019	FT-FY20-102019-002401-A	<1	FT-FY20-102019-002401-B	<1
WS-002402	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 232		WF-04092019-002402	10/25/2019	FT-FY20-102019-002402-A	<1	FT-FY20-102019-002402-B	<1
WS-002403	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 232		WF-09182019-002403	10/25/2019	FT-FY20-102019-002403-A	1.3	FT-FY20-102019-002403-B	<1
WS-002404	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 234		WF-04092019-002404	10/25/2019	FT-FY20-102019-002404-A	<1	FT-FY20-102019-002404-B	<1
WS-002405	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 234		WF-09182019-002405	10/25/2019	FT-FY20-102019-002405-A	<1	FT-FY20-102019-002405-B	<1
WS-002406	4/9/2019	4/9/2020	3	Cooler	In hallway across from room 304	High Left	WF-04092019-002406	10/25/2019	FT-FY20-102019-002406-A	<1	FT-FY20-102019-002406-B	<1
WS-002407	4/9/2019	4/9/2020	3	Cooler	In hallway across from room 304	Low Right	WF-04092019-002407	10/25/2019	FT-FY20-102019-002407-A	<1	FT-FY20-102019-002407-B	<1
WS-002408	4/9/2019	4/9/2020	3	Combo Fountain	In classroom 303		WF-04092019-002408	10/25/2019	FT-FY20-102019-002408-A	<1	FT-FY20-102019-002408-B	<1
WS-002409	9/18/2019	9/18/2020	3	Combo Faucet	In classroom 303		WF-09182019-002409	10/25/2019	FT-FY20-102019-002409-A	<1	FT-FY20-102019-002409-B	<1
WS-002410	9/18/2019	9/18/2020	3	Combo Faucet	In classroom 302		WF-09182019-002410	10/25/2019	FT-FY20-102019-002410-A	<1	FT-FY20-102019-002410-B	<1
WS-002411	4/9/2019	4/9/2020	3	Combo Fountain	In classroom 302		WF-04092019-002411	10/25/2019	FT-FY20-102019-002411-A	<1	FT-FY20-102019-002411-B	<1
WS-002412	4/9/2019	4/9/2020	3	Combo Fountain	In classroom 304		WF-04092019-002412	10/25/2019	FT-FY20-102019-002412-A	<1	FT-FY20-102019-002412-B	<1
WS-002413	9/18/2019	9/18/2020	3	Combo Faucet	In classroom 304		WF-09182019-002413	10/25/2019	FT-FY20-102019-002413-A	<1	FT-FY20-102019-002413-B	<1
WS-002414	4/9/2019	4/9/2020	3	Combo Fountain	In classroom 305		WF-04092019-002414	10/25/2019	FT-FY20-102019-002414-A	<1	FT-FY20-102019-002414-B	<1
WS-002415	9/18/2019	9/18/2020	3	Combo Faucet	In classroom 305		WF-09182019-002415	10/25/2019	FT-FY20-102019-002415-A	<1	FT-FY20-102019-002415-B	<1
WS-002416	4/9/2019	4/9/2020	3	Break Room	In staff lounge 319		WF-04092019-002416	10/25/2019	FT-FY20-102019-002416-A	<1	FT-FY20-102019-002416-B	<1
WS-002417	4/9/2019	4/9/2020	3	Combo Fountain	In classroom 310		WF-04092019-002417	10/25/2019	FT-FY20-102019-002417-A	<1	FT-FY20-102019-002417-B	<1
WS-002418	9/18/2019	9/18/2020	3	Combo Faucet	In classroom 310		WF-09182019-002418	10/25/2019	FT-FY20-102019-002418-A	1.4	FT-FY20-102019-002418-B	<1
WS-002419	4/9/2019	4/9/2020	3	Combo Fountain	In classroom 311		WF-04092019-002419	10/25/2019	FT-FY20-102019-002419-A	<1	FT-FY20-102019-002419-B	<1
WS-002420	9/18/2019	9/18/2020	3	Combo Faucet	In classroom 311		WF-09182019-002420	10/25/2019	FT-FY20-102019-002420-A	<1	FT-FY20-102019-002420-B	<1
WS-002421	4/9/2019	4/9/2020	3	Combo Fountain	In classroom 312		WF-04092019-002421	10/25/2019	FT-FY20-102019-002421-A	<1	FT-FY20-102019-002421-B	<1
WS-002422	9/18/2019	9/18/2020	3	Combo Faucet	In classroom 312		WF-09182019-002422	10/25/2019	FT-FY20-102019-002422-A	<1	FT-FY20-102019-002422-B	<1
WS-002423	4/9/2019	4/9/2020	3	Combo Fountain	In classroom 313		WF-04092019-002423	10/25/2019	FT-FY20-102019-002423-A	<1	FT-FY20-102019-002423-B	<1
WS-002424	9/18/2019	9/18/2020	3	Combo Faucet	In classroom 313		WF-09182019-002424	10/25/2019	FT-FY20-102019-002424-A	<1	FT-FY20-102019-002424-B	<1
WS-002425	4/9/2019	4/9/2020	3	Combo Fountain	In classroom 314		WF-04092019-002425	10/25/2019	FT-FY20-102019-002425-A	<1	FT-FY20-102019-002425-B	<1
WS-002427	4/9/2019	4/9/2020	3	Combo Fountain	In resource room 341		WF-04092019-002427	10/25/2019	FT-FY20-102019-002427-A	<1	FT-FY20-102019-002427-B	<1
WS-002428	9/18/2019	9/18/2020	3	Combo Faucet	In resource room 341		WF-09182019-002428	10/25/2019	FT-FY20-102019-002428-A	1.3	FT-FY20-102019-002428-B	<1
WS-002429	4/9/2019	4/9/2020	2	Combo Fountain	In classroom 221		WF-04092019-002429	10/25/2019	FT-FY20-102019-002429-A	<1	FT-FY20-102019-002429-B	<1
WS-002430	9/18/2019	9/18/2020	2	Combo Faucet	In classroom 221		WF-09182019-002430	10/25/2019	FT-FY20-102019-002430-A	<1	FT-FY20-102019-002430-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002363	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen second clockwise from entry door Left	WF-07222019-002363	10/25/2019	FT-FY20-102019-002363-A	<1	FT-FY20-102019-002363-B	<1
WS- 002364	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen third clockwise from entry door Right	WF-07222019-002364	10/25/2019	FT-FY20-102019-002364-A	<1	FT-FY20-102019-002364-B	<1
WS- 002365	7/22/2019	7/22/2020	1	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-07222019-002365	10/25/2019	FT-FY20-102019-002365-A	<1	FT-FY20-102019-002365-B	<1