



# H.D. Cooke Elementary School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002350	3/7/2023	3/7/2024	1	Cooler	In gym 142	High Left	WF-03072023-002350	10/12/2023	FT-FY24-09182023-002350-A	<1	FT-FY24-09182023-002350-B	<1
WS- 002351	3/7/2023	3/7/2024	1	Cooler	In gym 142	Low Right	WF-03072023-002351	10/12/2023	FT-FY24-09182023-002351-A	<1	FT-FY24-09182023-002351-B	<1
WS- 002352	3/7/2023	3/7/2024	1	Break Room	In work room 130		WF-03072023-002352	10/12/2023	FT-FY24-09182023-002352-A	<1	FT-FY24-09182023-002352-B	<1
WS- 002353	3/7/2023	3/7/2024	1	Break Room	In staff lounge 137		WF-03072023-002353	10/12/2023	FT-FY24-09182023-002353-A	<1	FT-FY24-09182023-002353-B	<1
WS- 002354	3/7/2023	3/7/2024	1	Combo Fountain	In classroom 132		WF-03072023-002354	10/12/2023	FT-FY24-09182023-002354-A	<1	FT-FY24-09182023-002354-B	<1
WS- 002355	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 132		WF-08142023-002355	10/12/2023	FT-FY24-09182023-002355-A	<1	FT-FY24-09182023-002355-B	<1
WS- 002356	3/7/2023	3/7/2024	1	Combo Fountain	In classroom 136		WF-03072023-002356	10/12/2023	FT-FY24-09182023-002356-A	<1	FT-FY24-09182023-002356-B	<1
WS- 002357	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 136		WF-08142023-002357	10/12/2023	FT-FY24-09182023-002357-A	<1	FT-FY24-09182023-002357-B	<1
WS- 002358	3/7/2023	3/7/2024	1	Combo Fountain	In classroom 133		WF-03072023-002358	10/12/2023	FT-FY24-09182023-002358-A	<1	FT-FY24-09182023-002358-B	<1
WS- 002359	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 133		WF-08142023-002359	10/12/2023	FT-FY24-09182023-002359-A	<1	FT-FY24-09182023-002359-B	<1
WS- 002360	3/7/2023	3/7/2024	1	Combo Fountain	In classroom 135		WF-03072023-002360	10/12/2023	FT-FY24-09182023-002360-A	<1	FT-FY24-09182023-002360-B	<1
WS- 002361	8/14/2023	8/14/2024	1	Combo Faucet	In classroom 135		WF-08142023-002361	10/12/2023	FT-FY24-09182023-002361-A	<1	FT-FY24-09182023-002361-B	<1
WS- 002366	3/7/2023	3/7/2024	1	Cooler	In hallway across from room 105	High Left	WF-03072023-002366	10/12/2023	FT-FY24-09182023-002366-A	<1	FT-FY24-09182023-002366-B	<1
WS- 002367	3/7/2023	3/7/2024	1	Cooler	In hallway across from room 105	Low Right	WF-03072023-002367	10/12/2023	FT-FY24-09182023-002367-A	<1	FT-FY24-09182023-002367-B	<1
WS- 002368	3/7/2023	3/7/2024	1	Health Suite	In health suite in exam room 103E		WF-03072023-002368	10/12/2023	FT-FY24-09182023-002368-A	<1	FT-FY24-09182023-002368-B	<1
WS- 002369	3/7/2023	3/7/2024	1	Health Suite	In health suite in exam room 103C		WF-03072023-002369	10/12/2023	FT-FY24-09182023-002369-A	<1	FT-FY24-09182023-002369-B	<1
WS- 002370	3/7/2023	3/7/2024	1	Break Room	In break room 110		WF-03072023-002370	10/12/2023	FT-FY24-09182023-002370-A	<1	FT-FY24-09182023-002370-B	<1
WS- 002374	3/7/2023	3/7/2024	2	Cooler	In hallway across from room 204	High Left	WF-03072023-002374	10/12/2023	FT-FY24-09182023-002374-A	<1	FT-FY24-09182023-002374-B	<1
WS- 002375	3/7/2023	3/7/2024	2	Cooler	In hallway across from room 204	Low Right	WF-03072023-002375	10/12/2023	FT-FY24-09182023-002375-A	<1	FT-FY24-09182023-002375-B	<1
WS- 002376	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 205		WF-03072023-002376	10/12/2023	FT-FY24-09182023-002376-A	<1	FT-FY24-09182023-002376-B	<1
WS- 002377	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 205		WF-08142023-002377	10/12/2023	FT-FY24-09182023-002377-A	<1	FT-FY24-09182023-002377-B	<1
WS- 002378	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 204		WF-03072023-002378	10/12/2023	FT-FY24-09182023-002378-A	<1	FT-FY24-09182023-002378-B	<1
WS- 002379	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 204		WF-08142023-002379	10/12/2023	FT-FY24-09182023-002379-A	<1	FT-FY24-09182023-002379-B	<1
WS- 002380	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 202		WF-03072023-002380	10/12/2023	FT-FY24-09182023-002380-A	<1	FT-FY24-09182023-002380-B	<1
WS- 002381	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 202		WF-08142023-002381	10/12/2023	FT-FY24-09182023-002381-A	<1	FT-FY24-09182023-002381-B	<1
WS- 002382	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 203		WF-03072023-002382	10/12/2023	FT-FY24-09182023-002382-A	<1	FT-FY24-09182023-002382-B	<1
WS- 002383	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 203		WF-08142023-002383	10/12/2023	FT-FY24-09182023-002383-A	<1	FT-FY24-09182023-002383-B	<1
WS- 002384	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 210		WF-03072023-002384	10/12/2023	FT-FY24-09182023-002384-A	<1	FT-FY24-09182023-002384-B	<1
WS- 002385	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 210		WF-08142023-002385	10/12/2023	FT-FY24-09182023-002385-A	<1	FT-FY24-09182023-002385-B	<1
WS- 002386	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 211		WF-03072023-002386	10/12/2023	FT-FY24-09182023-002386-A	<1	FT-FY24-09182023-002386-B	<1
WS- 002387	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 211		WF-08142023-002387	10/12/2023	FT-FY24-09182023-002387-A	<1	FT-FY24-09182023-002387-B	<1
WS- 002388	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 212		WF-03072023-002388	10/12/2023	FT-FY24-09182023-002388-A	<1	FT-FY24-09182023-002388-B	<1
WS- 002389	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 212		WF-08142023-002389	10/12/2023	FT-FY24-09182023-002389-A	<1	FT-FY24-09182023-002389-B	<1
WS- 002390	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 213		WF-03072023-002390	10/12/2023	FT-FY24-09182023-002390-A	<1	FT-FY24-09182023-002390-B	<1

WS- 002391	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 213	WF-08142023-002391	10/12/2023	FT-FY24-09182023-002391-A	<1	FT-FY24-09182023-002391-B	<1
WS- 002393	8/14/2023	8/14/2024	2	Combo Faucet	In resource room 241	WF-08142023-002393	10/12/2023	FT-FY24-09182023-002393-A	<1	FT-FY24-09182023-002393-B	<1
WS- 002394	3/7/2023	3/7/2024	2	Combo Fountain	In resource room 230	WF-03072023-002394	10/12/2023	FT-FY24-09182023-002394-A	<1	FT-FY24-09182023-002394-B	<1
WS- 002395	8/14/2023	8/14/2024	2	Combo Faucet	In resource room 230	WF-08142023-002395	10/12/2023	FT-FY24-09182023-002395-A	<1	FT-FY24-09182023-002395-B	<1
WS- 002397	8/14/2023	8/14/2024	2	Combo Faucet	In resource room 236	WF-08142023-002397	10/12/2023	FT-FY24-09182023-002397-A	<1	FT-FY24-09182023-002397-B	<1
WS- 002398	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 231	WF-03072023-002398	10/12/2023	FT-FY24-09182023-002398-A	<1	FT-FY24-09182023-002398-B	<1
WS- 002399	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 231	WF-08142023-002399	10/12/2023	FT-FY24-09182023-002399-A	<1	FT-FY24-09182023-002399-B	<1
WS- 002400	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 235	WF-03072023-002400	10/12/2023	FT-FY24-09182023-002400-A	<1	FT-FY24-09182023-002400-B	<1
WS- 002401	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 235	WF-08142023-002401	10/12/2023	FT-FY24-09182023-002401-A	<1	FT-FY24-09182023-002401-B	<1
WS- 002402	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 232	WF-03072023-002402	10/12/2023	FT-FY24-09182023-002402-A	<1	FT-FY24-09182023-002402-B	<1
WS- 002403	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 232	WF-08142023-002403	10/12/2023	FT-FY24-09182023-002403-A	<1	FT-FY24-09182023-002403-B	<1
WS- 002404	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 234	WF-03072023-002404	10/12/2023	FT-FY24-09182023-002404-A	<1	FT-FY24-09182023-002404-B	<1
WS- 002405	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 234	WF-08142023-002405	10/12/2023	FT-FY24-09182023-002405-A	<1	FT-FY24-09182023-002405-B	<1
WS- 002408	3/7/2023	3/7/2024	3	Combo Fountain	In classroom 303	WF-03072023-002408	10/12/2023	FT-FY24-09182023-002408-A	<1	FT-FY24-09182023-002408-B	<1
WS- 002409	8/14/2023	8/14/2024	3	Combo Faucet	In classroom 303	WF-08142023-002409	10/12/2023	FT-FY24-09182023-002409-A	<1	FT-FY24-09182023-002409-B	<1
WS- 002410	8/14/2023	8/14/2024	3	Combo Faucet	In classroom 302	WF-08142023-002410	10/12/2023	FT-FY24-09182023-002410-A	1.1	FT-FY24-09182023-002410-B	<1
WS- 002411	3/7/2023	3/7/2024	3	Combo Fountain	In classroom 302	WF-03072023-002411	10/12/2023	FT-FY24-09182023-002411-A	<1	FT-FY24-09182023-002411-B	<1
WS- 002412	3/7/2023	3/7/2024	3	Combo Fountain	In classroom 304	WF-03072023-002412	10/12/2023	FT-FY24-09182023-002412-A	<1	FT-FY24-09182023-002412-B	<1
WS- 002413	8/14/2023	8/14/2024	3	Combo Faucet	In classroom 304	WF-08142023-002413	10/12/2023	FT-FY24-09182023-002413-A	<1	FT-FY24-09182023-002413-B	<1
WS- 002414	3/7/2023	3/7/2024	3	Combo Fountain	In classroom 305	WF-03072023-002414	10/12/2023	FT-FY24-09182023-002414-A	<1	FT-FY24-09182023-002414-B	<1
WS- 002415	8/14/2023	8/14/2024	3	Combo Faucet	In classroom 305	WF-08142023-002415	10/12/2023	FT-FY24-09182023-002415-A	<1	FT-FY24-09182023-002415-B	<1
WS- 002416	3/7/2023	3/7/2024	3	Break Room	In staff lounge 319	WF-03072023-002416	10/12/2023	FT-FY24-09182023-002416-A	1.1	FT-FY24-09182023-002416-B	<1
WS- 002417	3/7/2023	3/7/2024	3	Combo Fountain	In classroom 310	WF-03072023-002417	10/12/2023	FT-FY24-09182023-002417-A	<1	FT-FY24-09182023-002417-B	<1
WS- 002418	8/14/2023	8/14/2024	3	Combo Faucet	In classroom 310	WF-08142023-002418	10/12/2023	FT-FY24-09182023-002418-A	<1	FT-FY24-09182023-002418-B	<1
WS- 002419	3/7/2023	3/7/2024	3	Combo Fountain	In classroom 311	WF-03072023-002419	10/12/2023	FT-FY24-09182023-002419-A	<1	FT-FY24-09182023-002419-B	<1
WS- 002420	8/14/2023	8/14/2024	3	Combo Faucet	In classroom 311	WF-08142023-002420	10/12/2023	FT-FY24-09182023-002420-A	<1	FT-FY24-09182023-002420-B	<1
WS- 002421	3/7/2023	3/7/2024	3	Combo Fountain	In classroom 312	WF-03072023-002421	10/12/2023	FT-FY24-09182023-002421-A	<1	FT-FY24-09182023-002421-B	<1
WS- 002422	8/14/2023	8/14/2024	3	Combo Faucet	In classroom 312	WF-08142023-002422	10/12/2023	FT-FY24-09182023-002422-A	<1	FT-FY24-09182023-002422-B	<1
WS- 002423	3/7/2023	3/7/2024	3	Combo Fountain	In classroom 313	WF-03072023-002423	10/12/2023	FT-FY24-09182023-002423-A	<1	FT-FY24-09182023-002423-B	<1
WS- 002424	8/14/2023	8/14/2024	3	Combo Faucet	In classroom 313	WF-08142023-002424	10/12/2023	FT-FY24-09182023-002424-A	<1	FT-FY24-09182023-002424-B	<1
WS- 002429	3/7/2023	3/7/2024	2	Combo Fountain	In classroom 221	WF-03072023-002429	10/12/2023	FT-FY24-09182023-002429-A	<1	FT-FY24-09182023-002429-B	<1
WS- 002430	8/14/2023	8/14/2024	2	Combo Faucet	In classroom 221	WF-08142023-002430	10/12/2023	FT-FY24-09182023-002430-A	<1	FT-FY24-09182023-002430-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002363	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen second clockwise from entry door Left	WF-12192022-002363	10/12/2023	FT-FY24-09182023-002363-A	<1	FT-FY24-09182023-002363-B	<1
WS- 002364	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen third clockwise from entry door Right	WF-12192022-002364	10/12/2023	FT-FY24-09182023-002364-A	<1	FT-FY24-09182023-002364-B	<1
WS- 002365	12/19/2022	12/19/2023	1	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-12192022-002365	10/12/2023	FT-FY24-09182023-002365-A	<1	FT-FY24-09182023-002365-B	<1