



# HD Cooke Elementary School Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002350	3/4/2024	3/4/2025	1	Cooler	In gym 142 High Left	WF-03042024-002350	10/15/2024	FT-FY25-10032024-002350-A	<2	FT-FY25-10032024-002350-B	<2
WS-002351	3/4/2024	3/4/2025	1	Cooler	In gym 142 Low Right	WF-03042024-002351	10/15/2024	FT-FY25-10032024-002351-A	<2	FT-FY25-10032024-002351-B	<2
WS-002352	3/4/2024	3/4/2025	1	Break Room	In work room 130	WF-03042024-002352	10/15/2024	FT-FY25-10032024-002352-A	<2	FT-FY25-10032024-002352-B	<2
WS-002353	9/6/2024	9/6/2025	1	Break Room	In staff lounge 137	WF-09062024-002353	10/15/2024	FT-FY25-10032024-002353-A	<2	FT-FY25-10032024-002353-B	<2
WS-002354	3/4/2024	3/4/2025	1	Combo Fountain	In classroom 132	WF-03042024-002354	10/15/2024	FT-FY25-10032024-002354-A	<2	FT-FY25-10032024-002354-B	<2
WS-002355	8/12/2024	8/12/2025	1	Combo Faucet	In classroom 132	WF-08122024-002355	10/15/2024	FT-FY25-10032024-002355-A	<2	FT-FY25-10032024-002355-B	<2
WS-002356	3/4/2024	3/4/2025	1	Combo Fountain	In classroom 136	WF-03042024-002356	10/15/2024	FT-FY25-10032024-002356-A	<2	FT-FY25-10032024-002356-B	<2
WS-002357	8/12/2024	8/12/2025	1	Combo Faucet	In classroom 136	WF-08122024-002357	10/15/2024	FT-FY25-10032024-002357-A	<2	FT-FY25-10032024-002357-B	<2
WS-002358	3/4/2024	3/4/2025	1	Combo Fountain	In classroom 133	WF-03042024-002358	10/15/2024	FT-FY25-10032024-002358-A	<2	FT-FY25-10032024-002358-B	<2
WS-002359	8/12/2024	8/12/2025	1	Combo Faucet	In classroom 133	WF-08122024-002359	10/15/2024	FT-FY25-10032024-002359-A	<2	FT-FY25-10032024-002359-B	<2
WS-002360	3/4/2024	3/4/2025	1	Combo Fountain	In classroom 135	WF-03042024-002360	10/15/2024	FT-FY25-10032024-002360-A	<2	FT-FY25-10032024-002360-B	<2
WS-002361	8/12/2024	8/12/2025	1	Combo Faucet	In classroom 135	WF-08122024-002361	10/15/2024	FT-FY25-10032024-002361-A	<2	FT-FY25-10032024-002361-B	<2
WS-002366	3/4/2024	3/4/2025	1	Cooler	In hallway across from room 105 High Left	WF-03042024-002366	10/15/2024	FT-FY25-10032024-002366-A	<2	FT-FY25-10032024-002366-B	<2
WS-002367	3/4/2024	3/4/2025	1	Cooler	In hallway across from room 105 Low Right	WF-03042024-002367	10/15/2024	FT-FY25-10032024-002367-A	<2	FT-FY25-10032024-002367-B	<2
WS-002368	3/4/2024	3/4/2025	1	Health Suite	In health suite in exam room 103E	WF-03042024-002368	10/15/2024	FT-FY25-10032024-002368-A	<2	FT-FY25-10032024-002368-B	<2
WS-002369	3/4/2024	3/4/2025	1	Health Suite	In health suite in exam room 103C	WF-03042024-002369	10/15/2024	FT-FY25-10032024-002369-A	<2	FT-FY25-10032024-002369-B	<2
WS-002370	3/4/2024	3/4/2025	1	Break Room	In break room 110	WF-03042024-002370	10/15/2024	FT-FY25-10032024-002370-A	<2	FT-FY25-10032024-002370-B	<2
WS-002374	3/4/2024	3/4/2025	2	Cooler	In hallway across from room 204 High Left	WF-03042024-002374	10/15/2024	FT-FY25-10032024-002374-A	<2	FT-FY25-10032024-002374-B	<2
WS-002375	3/4/2024	3/4/2025	2	Cooler	In hallway across from room 204 Low Right	WF-03042024-002375	10/15/2024	FT-FY25-10032024-002375-A	<2	FT-FY25-10032024-002375-B	<2
WS-002376	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 205	WF-03042024-002376	10/15/2024	FT-FY25-10032024-002376-A	<2	FT-FY25-10032024-002376-B	<2
WS-002377	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 205	WF-08122024-002377	10/15/2024	FT-FY25-10032024-002377-A	<2	FT-FY25-10032024-002377-B	<2
WS-002378	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 204	WF-03042024-002378	10/15/2024	FT-FY25-10032024-002378-A	<2	FT-FY25-10032024-002378-B	<2
WS-002379	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 204	WF-08122024-002379	10/15/2024	FT-FY25-10032024-002379-A	<2	FT-FY25-10032024-002379-B	<2
WS-002380	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 202	WF-03042024-002380	10/15/2024	FT-FY25-10032024-002380-A	<2	FT-FY25-10032024-002380-B	<2
WS-002381	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 202	WF-08122024-002381	10/15/2024	FT-FY25-10032024-002381-A	<2	FT-FY25-10032024-002381-B	<2
WS-002382	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 203	WF-03042024-002382	10/15/2024	FT-FY25-10032024-002382-A	<2	FT-FY25-10032024-002382-B	<2
WS-002383	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 203	WF-08122024-002383	10/15/2024	FT-FY25-10032024-002383-A	<2	FT-FY25-10032024-002383-B	<2
WS-002384	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 210	WF-03042024-002384	10/15/2024	FT-FY25-10032024-002384-A	<2	FT-FY25-10032024-002384-B	<2
WS-002385	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 210	WF-08122024-002385	10/15/2024	FT-FY25-10032024-002385-A	<2	FT-FY25-10032024-002385-B	<2
WS-002386	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 211	WF-03042024-002386	10/15/2024	FT-FY25-10032024-002386-A	<2	FT-FY25-10032024-002386-B	<2
WS-002387	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 211	WF-08122024-002387	10/15/2024	FT-FY25-10032024-002387-A	<2	FT-FY25-10032024-002387-B	<2
WS-002388	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 212	WF-03042024-002388	10/15/2024	FT-FY25-10032024-002388-A	<2	FT-FY25-10032024-002388-B	<2
WS-002389	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 212	WF-08122024-002389	10/15/2024	FT-FY25-10032024-002389-A	<2	FT-FY25-10032024-002389-B	<2

WS-002390	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 213		WF-03042024-002390	10/15/2024	FT-FY25-10032024-002390-A	<2	FT-FY25-10032024-002390-B	<2
WS-002391	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 213		WF-08122024-002391	10/15/2024	FT-FY25-10032024-002391-A	<2	FT-FY25-10032024-002391-B	<2
WS-002392	3/4/2024	3/4/2025	2	Combo Fountain	In resource room 241		WF-03042024-002392	10/15/2024	FT-FY25-10032024-002392-A	<2	FT-FY25-10032024-002392-B	<2
WS-002393	8/12/2024	8/12/2025	2	Combo Faucet	In resource room 241		WF-08122024-002393	10/15/2024	FT-FY25-10032024-002393-A	<2	FT-FY25-10032024-002393-B	<2
WS-002394	3/4/2024	3/4/2025	2	Combo Fountain	In resource room 230		WF-03042024-002394	10/15/2024	FT-FY25-10032024-002394-A	<2	FT-FY25-10032024-002394-B	<2
WS-002395	8/12/2024	8/12/2025	2	Combo Faucet	In resource room 230		WF-08122024-002395	10/15/2024	FT-FY25-10032024-002395-A	<2	FT-FY25-10032024-002395-B	<2
WS-002396	3/4/2024	3/4/2025	2	Combo Fountain	In resource room 236		WF-03042024-002396	10/15/2024	FT-FY25-10032024-002396-A	<2	FT-FY25-10032024-002396-B	<2
WS-002397	8/12/2024	8/12/2025	2	Combo Faucet	In resource room 236		WF-08122024-002397	10/15/2024	FT-FY25-10032024-002397-A	<2	FT-FY25-10032024-002397-B	<2
WS-002398	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 231		WF-03042024-002398	10/15/2024	FT-FY25-10032024-002398-A	<2	FT-FY25-10032024-002398-B	<2
WS-002399	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 231		WF-08122024-002399	10/15/2024	FT-FY25-10032024-002399-A	<2	FT-FY25-10032024-002399-B	<2
WS-002400	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 235		WF-03042024-002400	10/15/2024	FT-FY25-10032024-002400-A	<2	FT-FY25-10032024-002400-B	<2
WS-002401	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 235		WF-08122024-002401	10/15/2024	FT-FY25-10032024-002401-A	<2	FT-FY25-10032024-002401-B	<2
WS-002402	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 232		WF-03042024-002402	10/15/2024	FT-FY25-10032024-002402-A	<2	FT-FY25-10032024-002402-B	<2
WS-002403	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 232		WF-08122024-002403	10/15/2024	FT-FY25-10032024-002403-A	<2	FT-FY25-10032024-002403-B	<2
WS-002404	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 234		WF-03042024-002404	10/15/2024	FT-FY25-10032024-002404-A	<2	FT-FY25-10032024-002404-B	<2
WS-002405	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 234		WF-08122024-002405	10/15/2024	FT-FY25-10032024-002405-A	<2	FT-FY25-10032024-002405-B	<2
WS-002406	3/4/2024	3/4/2025	3	Cooler	In hallway across from room 304	High Left	WF-03042024-002406	10/15/2024	FT-FY25-10032024-002406-A	<2	FT-FY25-10032024-002406-B	<2
WS-002407	3/4/2024	3/4/2025	3	Cooler	In hallway across from room 304	Low Right	WF-03042024-002407	10/15/2024	FT-FY25-10032024-002407-A	<2	FT-FY25-10032024-002407-B	<2
WS-002408	3/4/2024	3/4/2025	3	Combo Fountain	In classroom 303		WF-03042024-002408	10/15/2024	FT-FY25-10032024-002408-A	<2	FT-FY25-10032024-002408-B	<2
WS-002409	8/12/2024	8/12/2025	3	Combo Faucet	In classroom 303		WF-08122024-002409	10/15/2024	FT-FY25-10032024-002409-A	<2	FT-FY25-10032024-002409-B	<2
WS-002410	8/12/2024	8/12/2025	3	Combo Faucet	In classroom 302		WF-08122024-002410	10/15/2024	FT-FY25-10032024-002410-A	<2	FT-FY25-10032024-002410-B	<2
WS-002411	3/4/2024	3/4/2025	3	Combo Fountain	In classroom 302		WF-03042024-002411	10/15/2024	FT-FY25-10032024-002411-A	<2	FT-FY25-10032024-002411-B	<2
WS-002412	3/4/2024	3/4/2025	3	Combo Fountain	In classroom 304		WF-03042024-002412	10/15/2024	FT-FY25-10032024-002412-A	<2	FT-FY25-10032024-002412-B	<2
WS-002413	8/12/2024	8/12/2025	3	Combo Faucet	In classroom 304		WF-08122024-002413	10/15/2024	FT-FY25-10032024-002413-A	<2	FT-FY25-10032024-002413-B	<2
WS-002414	3/4/2024	3/4/2025	3	Combo Fountain	In classroom 305		WF-03042024-002414	10/15/2024	FT-FY25-10032024-002414-A	<2	FT-FY25-10032024-002414-B	<2
WS-002415	8/12/2024	8/12/2025	3	Combo Faucet	In classroom 305		WF-08122024-002415	10/15/2024	FT-FY25-10032024-002415-A	<2	FT-FY25-10032024-002415-B	<2
WS-002416	3/4/2024	3/4/2025	3	Break Room	In staff lounge 319		WF-03042024-002416	10/15/2024	FT-FY25-10032024-002416-A	<2	FT-FY25-10032024-002416-B	<2
WS-002417	3/4/2024	3/4/2025	3	Combo Fountain	In classroom 310		WF-03042024-002417	10/15/2024	FT-FY25-10032024-002417-A	<2	FT-FY25-10032024-002417-B	<2
WS-002418	8/12/2024	8/12/2025	3	Combo Faucet	In classroom 310		WF-08122024-002418	10/15/2024	FT-FY25-10032024-002418-A	<2	FT-FY25-10032024-002418-B	<2
WS-002419	3/4/2024	3/4/2025	3	Combo Fountain	In classroom 311		WF-03042024-002419	10/15/2024	FT-FY25-10032024-002419-A	<2	FT-FY25-10032024-002419-B	<2
WS-002420	8/12/2024	8/12/2025	3	Combo Faucet	In classroom 311		WF-08122024-002420	10/15/2024	FT-FY25-10032024-002420-A	<2	FT-FY25-10032024-002420-B	<2
WS-002421	3/4/2024	3/4/2025	3	Combo Fountain	In classroom 312		WF-03042024-002421	10/15/2024	FT-FY25-10032024-002421-A	<2	FT-FY25-10032024-002421-B	<2
WS-002422	8/12/2024	8/12/2025	3	Combo Faucet	In classroom 312		WF-08122024-002422	10/15/2024	FT-FY25-10032024-002422-A	<2	FT-FY25-10032024-002422-B	<2
WS-002423	3/4/2024	3/4/2025	3	Combo Fountain	In classroom 313		WF-03042024-002423	10/15/2024	FT-FY25-10032024-002423-A	<2	FT-FY25-10032024-002423-B	<2
WS-002424	8/12/2024	8/12/2025	3	Combo Faucet	In classroom 313		WF-08122024-002424	10/15/2024	FT-FY25-10032024-002424-A	<2	FT-FY25-10032024-002424-B	<2
WS-002425	3/4/2024	3/4/2025	3	Combo Fountain	In classroom 314		WF-03042024-002425	10/15/2024	FT-FY25-10032024-002425-A	<2	FT-FY25-10032024-002425-B	<2
WS-002427	3/4/2024	3/4/2025	3	Combo Fountain	In resource room 341		WF-03042024-002427	10/15/2024	FT-FY25-10032024-002427-A	<2	FT-FY25-10032024-002427-B	<2
WS-002428	8/12/2024	8/12/2025	3	Combo Faucet	In resource room 341		WF-08122024-002428	10/15/2024	FT-FY25-10032024-002428-A	<2	FT-FY25-10032024-002428-B	<2
WS-002429	3/4/2024	3/4/2025	2	Combo Fountain	In classroom 221		WF-03042024-002429	10/15/2024	FT-FY25-10032024-002429-A	<2	FT-FY25-10032024-002429-B	<2

WS-002430	8/12/2024	8/12/2025	2	Combo Faucet	In classroom 221	WF-08122024-002430	10/15/2024	FT-FY25-10032024-002430-A	<2	FT-FY25-10032024-002430-B	<2
-----------	-----------	-----------	---	--------------	------------------	--------------------	------------	---------------------------	----	---------------------------	----

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002363	11/14/2023	11/14/2024	1	Food Prep Sink	In kitchen second clockwise from entry door      Left	WF-11142023-002363	10/15/2024	FT-FY25-10032024-002363-A	<2	FT-FY25-10032024-002363-B	<2
WS-002364	11/14/2023	11/14/2024	1	Food Prep Sink	In kitchen third clockwise from entry door      Right	WF-11142023-002364	10/15/2024	FT-FY25-10032024-002364-A	<2	FT-FY25-10032024-002364-B	<2
WS-002365	11/14/2023	11/14/2024	1	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-11142023-002365	10/15/2024	FT-FY25-10032024-002365-A	<2	FT-FY25-10032024-002365-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.