



H.D. Cooke Elementary School Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002350	2/24/2025	2/24/2026	1	Cooler	In gym 142 High Left	WF-02242025-002350	10/10/2025	FT-FY26-09232025-002350-A	<2	FT-FY26-09232025-002350-B	<2
WS- 002351	2/24/2025	2/24/2026	1	Cooler	In gym 142 Low Right	WF-02242025-002351	10/10/2025	FT-FY26-09232025-002351-A	<2	FT-FY26-09232025-002351-B	<2
WS- 002352	2/24/2025	2/24/2026	1	Break Room	In work room 130	WF-02242025-002352	10/10/2025	FT-FY26-09232025-002352-A	<2	FT-FY26-09232025-002352-B	<2
WS- 002353	2/24/2025	2/24/2026	1	Break Room	In staff lounge 137	WF-02242025-002353	10/10/2025	FT-FY26-09232025-002353-A	<2	FT-FY26-09232025-002353-B	<2
WS- 002354	2/24/2025	2/24/2026	1	Combo Fountain	In classroom 132	WF-02242025-002354	10/10/2025	FT-FY26-09232025-002354-A	<2	FT-FY26-09232025-002354-B	<2
WS- 002355	7/30/2025	7/30/2026	1	Combo Faucet	In classroom 132	WF-07302025-002355	10/10/2025	FT-FY26-09232025-002355-A	<2	FT-FY26-09232025-002355-B	<2
WS- 002357	7/30/2025	7/30/2026	1	Combo Faucet	In classroom 136	WF-07302025-002357	10/10/2025	FT-FY26-09232025-002357-A	<2	FT-FY26-09232025-002357-B	<2
WS- 002358	2/24/2025	2/24/2026	1	Combo Fountain	In classroom 133	WF-02242025-002358	10/10/2025	FT-FY26-09232025-002358-A	<2	FT-FY26-09232025-002358-B	<2
WS- 002359	7/30/2025	7/30/2026	1	Combo Faucet	In classroom 133	WF-07302025-002359	10/10/2025	FT-FY26-09232025-002359-A	<2	FT-FY26-09232025-002359-B	<2
WS- 002360	2/24/2025	2/24/2026	1	Combo Fountain	In classroom 135	WF-02242025-002360	10/10/2025	FT-FY26-09232025-002360-A	<2	FT-FY26-09232025-002360-B	<2
WS- 002361	7/30/2025	7/30/2026	1	Combo Faucet	In classroom 135	WF-07302025-002361	10/10/2025	FT-FY26-09232025-002361-A	<2	FT-FY26-09232025-002361-B	<2
WS- 002366	2/24/2025	2/24/2026	1	Cooler	In hallway across from room 105 High Left	WF-02242025-002366	10/10/2025	FT-FY26-09232025-002366-A	<2	FT-FY26-09232025-002366-B	<2
WS- 002367	2/24/2025	2/24/2026	1	Cooler	In hallway across from room 105 Low Right	WF-02242025-002367	10/10/2025	FT-FY26-09232025-002367-A	<2	FT-FY26-09232025-002367-B	<2
WS- 002368	2/24/2025	2/24/2026	1	Health Suite	In health suite in exam room 103E	WF-02242025-002368	10/10/2025	FT-FY26-09232025-002368-A	<2	FT-FY26-09232025-002368-B	<2
WS- 002369	2/24/2025	2/24/2026	1	Health Suite	In health suite in exam room 103C	WF-02242025-002369	10/10/2025	FT-FY26-09232025-002369-A	<2	FT-FY26-09232025-002369-B	<2
WS- 002370	2/24/2025	2/24/2026	1	Break Room	In break room 110	WF-02242025-002370	10/10/2025	FT-FY26-09232025-002370-A	<2	FT-FY26-09232025-002370-B	<2
WS- 002374	2/24/2025	2/24/2026	2	Cooler	In hallway across from room 204 High Left	WF-02242025-002374	10/10/2025	FT-FY26-09232025-002374-A	<2	FT-FY26-09232025-002374-B	<2
WS- 002375	2/24/2025	2/24/2026	2	Cooler	In hallway across from room 204 Low Right	WF-02242025-002375	10/10/2025	FT-FY26-09232025-002375-A	<2	FT-FY26-09232025-002375-B	<2
WS- 002376	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 205	WF-02242025-002376	10/10/2025	FT-FY26-09232025-002376-A	<2	FT-FY26-09232025-002376-B	<2
WS- 002377	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 205	WF-07302025-002377	10/10/2025	FT-FY26-09232025-002377-A	<2	FT-FY26-09232025-002377-B	<2
WS- 002378	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 204	WF-02242025-002378	10/10/2025	FT-FY26-09232025-002378-A	<2	FT-FY26-09232025-002378-B	<2
WS- 002379	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 204	WF-07302025-002379	10/10/2025	FT-FY26-09232025-002379-A	<2	FT-FY26-09232025-002379-B	<2
WS- 002380	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 202	WF-02242025-002380	10/10/2025	FT-FY26-09232025-002380-A	<2	FT-FY26-09232025-002380-B	<2
WS- 002381	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 202	WF-07302025-002381	10/10/2025	FT-FY26-09232025-002381-A	<2	FT-FY26-09232025-002381-B	<2
WS- 002382	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 203	WF-02242025-002382	10/10/2025	FT-FY26-09232025-002382-A	<2	FT-FY26-09232025-002382-B	<2
WS- 002383	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 203	WF-07302025-002383	10/10/2025	FT-FY26-09232025-002383-A	<2	FT-FY26-09232025-002383-B	<2
WS- 002384	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 210	WF-02242025-002384	10/10/2025	FT-FY26-09232025-002384-A	<2	FT-FY26-09232025-002384-B	<2
WS- 002385	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 210	WF-07302025-002385	10/10/2025	FT-FY26-09232025-002385-A	<2	FT-FY26-09232025-002385-B	<2
WS- 002386	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 211	WF-02242025-002386	10/10/2025	FT-FY26-09232025-002386-A	<2	FT-FY26-09232025-002386-B	<2
WS- 002387	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 211	WF-07302025-002387	10/10/2025	FT-FY26-09232025-002387-A	<2	FT-FY26-09232025-002387-B	<2
WS- 002388	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 212	WF-02242025-002388	10/10/2025	FT-FY26-09232025-002388-A	<2	FT-FY26-09232025-002388-B	<2
WS- 002389	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 212	WF-07302025-002389	10/10/2025	FT-FY26-09232025-002389-A	<2	FT-FY26-09232025-002389-B	<2
WS- 002390	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 213	WF-02242025-002390	10/10/2025	FT-FY26-09232025-002390-A	<2	FT-FY26-09232025-002390-B	<2
WS- 002392	2/24/2025	2/24/2026	2	Combo Fountain	In resource room 241	WF-02242025-002392	10/10/2025	FT-FY26-09232025-002392-A	<2	FT-FY26-09232025-002392-B	<2

WS- 002393	7/30/2025	7/30/2026	2	Combo Faucet	In resource room 241	WF-07302025-002393	10/10/2025	FT-FY26-09232025-002393-A	<2	FT-FY26-09232025-002393-B	<2
WS- 002394	2/24/2025	2/24/2026	2	Combo Fountain	In resource room 230	WF-02242025-002394	10/10/2025	FT-FY26-09232025-002394-A	<2	FT-FY26-09232025-002394-B	<2
WS- 002395	7/30/2025	7/30/2026	2	Combo Faucet	In resource room 230	WF-07302025-002395	10/10/2025	FT-FY26-09232025-002395-A	<2	FT-FY26-09232025-002395-B	<2
WS- 002396	2/24/2025	2/24/2026	2	Combo Fountain	In resource room 236	WF-02242025-002396	10/10/2025	FT-FY26-09232025-002396-A	<2	FT-FY26-09232025-002396-B	<2
WS- 002397	7/30/2025	7/30/2026	2	Combo Faucet	In resource room 236	WF-07302025-002397	10/10/2025	FT-FY26-09232025-002397-A	2.6	FT-FY26-09232025-002397-B	<2
WS- 002398	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 231	WF-02242025-002398	10/10/2025	FT-FY26-09232025-002398-A	<2	FT-FY26-09232025-002398-B	<2
WS- 002399	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 231	WF-07302025-002399	10/10/2025	FT-FY26-09232025-002399-A	<2	FT-FY26-09232025-002399-B	<2
WS- 002400	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 235	WF-02242025-002400	10/10/2025	FT-FY26-09232025-002400-A	<2	FT-FY26-09232025-002400-B	<2
WS- 002401	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 235	WF-07302025-002401	10/10/2025	FT-FY26-09232025-002401-A	<2	FT-FY26-09232025-002401-B	<2
WS- 002402	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 232	WF-02242025-002402	10/10/2025	FT-FY26-09232025-002402-A	<2	FT-FY26-09232025-002402-B	<2
WS- 002403	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 232	WF-07302025-002403	10/10/2025	FT-FY26-09232025-002403-A	<2	FT-FY26-09232025-002403-B	<2
WS- 002404	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 234	WF-02242025-002404	10/10/2025	FT-FY26-09232025-002404-A	<2	FT-FY26-09232025-002404-B	<2
WS- 002405	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 234	WF-07302025-002405	10/10/2025	FT-FY26-09232025-002405-A	<2	FT-FY26-09232025-002405-B	<2
WS- 002406	2/24/2025	2/24/2026	3	Cooler	In hallway across from room 304 High Left	WF-02242025-002406	10/10/2025	FT-FY26-09232025-002406-A	<2	FT-FY26-09232025-002406-B	<2
WS- 002409	7/30/2025	7/30/2026	3	Combo Faucet	In classroom 303	WF-07302025-002409	10/10/2025	FT-FY26-09232025-002409-A	<2	FT-FY26-09232025-002409-B	<2
WS- 002410	7/30/2025	7/30/2026	3	Combo Faucet	In classroom 302	WF-07302025-002410	10/10/2025	FT-FY26-09232025-002410-A	<2	FT-FY26-09232025-002410-B	<2
WS- 002411	2/24/2025	2/24/2026	3	Combo Fountain	In classroom 302	WF-02242025-002411	10/10/2025	FT-FY26-09232025-002411-A	<2	FT-FY26-09232025-002411-B	<2
WS- 002412	2/24/2025	2/24/2026	3	Combo Fountain	In classroom 304	WF-02242025-002412	10/10/2025	FT-FY26-09232025-002412-A	<2	FT-FY26-09232025-002412-B	<2
WS- 002413	7/30/2025	7/30/2026	3	Combo Faucet	In classroom 304	WF-07302025-002413	10/10/2025	FT-FY26-09232025-002413-A	<2	FT-FY26-09232025-002413-B	<2
WS- 002414	2/24/2025	2/24/2026	3	Combo Fountain	In classroom 305	WF-02242025-002414	10/10/2025	FT-FY26-09232025-002414-A	<2	FT-FY26-09232025-002414-B	<2
WS- 002415	7/30/2025	7/30/2026	3	Combo Faucet	In classroom 305	WF-07302025-002415	10/10/2025	FT-FY26-09232025-002415-A	<2	FT-FY26-09232025-002415-B	<2
WS- 002416	2/24/2025	2/24/2026	3	Break Room	In staff lounge 319	WF-02242025-002416	10/10/2025	FT-FY26-09232025-002416-A	<2	FT-FY26-09232025-002416-B	<2
WS- 002417	2/24/2025	2/24/2026	3	Combo Fountain	In classroom 310	WF-02242025-002417	10/10/2025	FT-FY26-09232025-002417-A	<2	FT-FY26-09232025-002417-B	<2
WS- 002418	7/30/2025	7/30/2026	3	Combo Faucet	In classroom 310	WF-07302025-002418	10/10/2025	FT-FY26-09232025-002418-A	<2	FT-FY26-09232025-002418-B	<2
WS- 002419	2/24/2025	2/24/2026	3	Combo Fountain	In classroom 311	WF-02242025-002419	10/10/2025	FT-FY26-09232025-002419-A	<2	FT-FY26-09232025-002419-B	<2
WS- 002421	2/24/2025	2/24/2026	3	Combo Fountain	In classroom 312	WF-02242025-002421	10/10/2025	FT-FY26-09232025-002421-A	<2	FT-FY26-09232025-002421-B	<2
WS- 002422	7/30/2025	7/30/2026	3	Combo Faucet	In classroom 312	WF-07302025-002422	10/10/2025	FT-FY26-09232025-002422-A	<2	FT-FY26-09232025-002422-B	<2
WS- 002423	2/24/2025	2/24/2026	3	Combo Fountain	In classroom 313	WF-02242025-002423	10/10/2025	FT-FY26-09232025-002423-A	<2	FT-FY26-09232025-002423-B	<2
WS- 002424	7/30/2025	7/30/2026	3	Combo Faucet	In classroom 313	WF-07302025-002424	10/10/2025	FT-FY26-09232025-002424-A	3.6	FT-FY26-09232025-002424-B	<2
WS- 002425	2/24/2025	2/24/2026	3	Combo Fountain	In classroom 314	WF-02242025-002425	10/10/2025	FT-FY26-09232025-002425-A	<2	FT-FY26-09232025-002425-B	<2
WS- 002427	2/24/2025	2/24/2026	3	Combo Fountain	In resource room 341	WF-02242025-002427	10/10/2025	FT-FY26-09232025-002427-A	<2	FT-FY26-09232025-002427-B	<2
WS- 002428	7/30/2025	7/30/2026	3	Combo Faucet	In resource room 341	WF-07302025-002428	10/10/2025	FT-FY26-09232025-002428-A	2.0	FT-FY26-09232025-002428-B	<2
WS- 002429	2/24/2025	2/24/2026	2	Combo Fountain	In classroom 221	WF-02242025-002429	10/10/2025	FT-FY26-09232025-002429-A	2.3	FT-FY26-09232025-002429-B	<2
WS- 002430	7/30/2025	7/30/2026	2	Combo Faucet	In classroom 221	WF-07302025-002430	10/10/2025	FT-FY26-09232025-002430-A	<2	FT-FY26-09232025-002430-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002363	11/12/2024	11/12/2025	1	Food Prep Sink	In kitchen second clockwise from entry door Left	WF-11122024-002363	10/10/2025	FT-FY26-09232025-002363-A	<2	FT-FY26-09232025-002363-B	<2
WS- 002364	11/12/2024	11/12/2025	1	Food Prep Sink	In kitchen third clockwise from entry door Right	WF-11122024-002364	10/10/2025	FT-FY26-09232025-002364-A	<2	FT-FY26-09232025-002364-B	<2
WS- 002365	11/12/2024	11/12/2025	1	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-11122024-002365	10/10/2025	FT-FY26-09232025-002365-A	<2	FT-FY26-09232025-002365-B	<2

FY26 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002420	7/30/2025	7/30/2026	3	Combo Faucet	In classroom 311	WF-07302025-002420	10/10/2025	FT-FY26-09232025-002420-A	10.5	FT-FY26-09232025-002420-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.