



HD COOKE ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	H.D. COOKE ELEMENTARY SCHOOL	WS- 002350	8/8/2016	1	Cooler	In gym 142 High Left	FT-72016-002350-A	< 1	FT-72016-002350-B	< 1
2	H.D. COOKE ELEMENTARY SCHOOL	WS- 002351	8/8/2016	1	Cooler	In gym 142 Low Right	FT-72016-002351-A	< 1	FT-72016-002351-B	< 1
3	H.D. COOKE ELEMENTARY SCHOOL	WS- 002354	8/8/2016	1	Fountain	In classroom 132	FT-72016-002354-A	< 1	FT-72016-002354-B	< 1
4	H.D. COOKE ELEMENTARY SCHOOL	WS- 002356	8/8/2016	1	Fountain	In classroom 136	FT-72016-002356-A	< 1	FT-72016-002356-B	< 1
5	H.D. COOKE ELEMENTARY SCHOOL	WS- 002358	8/8/2016	1	Fountain	In classroom 133	FT-72016-002358-A	< 1	FT-72016-002358-B	< 1
6	H.D. COOKE ELEMENTARY SCHOOL	WS- 002360	8/8/2016	1	Fountain	In classroom 135	FT-72016-002360-A	< 1	FT-72016-002360-B	< 1
7	H.D. COOKE ELEMENTARY SCHOOL	WS- 002365	8/8/2016	1	Food Prep Sink	In kitchen fourth clockwise from entry door	FT-72016-002365-A	< 1	FT-72016-002365-B	< 1
8	H.D. COOKE ELEMENTARY SCHOOL	WS- 002366	8/8/2016	1	Cooler	In hallway across from room 105 High Left	FT-72016-002366-A	< 1	FT-72016-002366-B	< 1
9	H.D. COOKE ELEMENTARY SCHOOL	WS- 002367	8/8/2016	1	Cooler	In hallway across from room 105 Low	FT-72016-002367-A	< 1	FT-72016-002367-B	< 1
10	H.D. COOKE ELEMENTARY SCHOOL	WS- 002368	8/8/2016	1	Health Suite	In exam room 103E in health suite	FT-72016-002368-A	2.2	FT-72016-002368-B	< 1
11	H.D. COOKE ELEMENTARY SCHOOL	WS- 002369	8/8/2016	1	Health Suite	In exam room 103C in health suite	FT-72016-002369-A	< 1	FT-72016-002369-B	< 1
12	H.D. COOKE ELEMENTARY SCHOOL	WS- 002374	8/8/2016	2	Cooler	In hallway across from room 204 High Left	FT-72016-002374-A	< 1	FT-72016-002374-B	< 1
13	H.D. COOKE ELEMENTARY SCHOOL	WS- 002375	8/8/2016	2	Cooler	In hallway across from room 204 Low Right	FT-72016-002375-A	< 1	FT-72016-002375-B	< 1
14	H.D. COOKE ELEMENTARY SCHOOL	WS- 002376	8/8/2016	2	Fountain	In classroom 205	FT-72016-002376-A	< 1	FT-72016-002376-B	< 1
15	H.D. COOKE ELEMENTARY SCHOOL	WS- 002378	8/8/2016	2	Fountain	In classroom 204	FT-72016-002378-A	< 1	FT-72016-002378-B	< 1
16	H.D. COOKE ELEMENTARY SCHOOL	WS- 002380	8/8/2016	2	Fountain	In classroom 202	FT-72016-002380-A	< 1	FT-72016-002380-B	< 1
17	H.D. COOKE ELEMENTARY SCHOOL	WS- 002382	8/8/2016	2	Fountain	In classroom 203	FT-72016-002382-A	< 1	FT-72016-002382-B	< 1
18	H.D. COOKE ELEMENTARY SCHOOL	WS- 002384	8/8/2016	2	Fountain	In classroom 210	FT-72016-002384-A	< 1	FT-72016-002384-B	< 1
19	H.D. COOKE ELEMENTARY SCHOOL	WS- 002386	8/8/2016	2	Fountain	In classroom 211	FT-72016-002386-A	< 1	FT-72016-002386-B	< 1
20	H.D. COOKE ELEMENTARY SCHOOL	WS- 002388	8/8/2016	2	Fountain	In classroom 212	FT-72016-002388-A	< 1	FT-72016-002388-B	< 1
21	H.D. COOKE ELEMENTARY SCHOOL	WS- 002390	8/8/2016	2	Fountain	In classroom 213	FT-72016-002390-A	< 1	FT-72016-002390-B	< 1
22	H.D. COOKE ELEMENTARY SCHOOL	WS- 002392	8/8/2016	2	Fountain	In resource room 241	FT-72016-002392-A	< 1	FT-72016-002392-B	< 1
23	H.D. COOKE ELEMENTARY SCHOOL	WS- 002394	8/8/2016	2	Fountain	In resource room 230	FT-72016-002394-A	< 1	FT-72016-002394-B	< 1
24	H.D. COOKE ELEMENTARY SCHOOL	WS- 002396	8/8/2016	2	Fountain	In resource room 236	FT-72016-002396-A	< 1	FT-72016-002396-B	< 1
25	H.D. COOKE ELEMENTARY SCHOOL	WS- 002398	8/8/2016	2	Fountain	In classroom 231	FT-72016-002398-A	< 1	FT-72016-002398-B	< 1
26	H.D. COOKE ELEMENTARY SCHOOL	WS- 002400	8/8/2016	2	Fountain	In classroom 235	FT-72016-002400-A	< 1	FT-72016-002400-B	< 1
27	H.D. COOKE ELEMENTARY SCHOOL	WS- 002402	8/8/2016	2	Fountain	In classroom 232	FT-72016-002402-A	1.2	FT-72016-002402-B	< 1
28	H.D. COOKE ELEMENTARY SCHOOL	WS- 002404	8/9/2016	2	Fountain	In classroom 234	FT-72016-002404-A	< 1	FT-72016-002404-B	< 1
29	H.D. COOKE ELEMENTARY SCHOOL	WS- 002406	8/9/2016	3	Cooler	In hallway across from room 304 High Left	FT-72016-002406-A	< 1	FT-72016-002406-B	< 1
30	H.D. COOKE ELEMENTARY SCHOOL	WS- 002407	8/9/2016	3	Cooler	In hallway across from room 304 Low Right	FT-72016-002407-A	< 1	FT-72016-002407-B	< 1
31	H.D. COOKE ELEMENTARY SCHOOL	WS- 002408	8/9/2016	3	Fountain	In classroom 303	FT-72016-002408-A	< 1	FT-72016-002408-B	< 1
32	H.D. COOKE ELEMENTARY SCHOOL	WS- 002411	8/9/2016	3	Fountain	In classroom 302	FT-72016-002411-A	< 1	FT-72016-002411-B	< 1
33	H.D. COOKE ELEMENTARY SCHOOL	WS- 002412	8/9/2016	3	Fountain	In classroom 304	FT-72016-002412-A	< 1	FT-72016-002412-B	< 1
34	H.D. COOKE ELEMENTARY SCHOOL	WS- 002414	8/9/2016	3	Fountain	In classroom 305	FT-72016-002414-A	< 1	FT-72016-002414-B	< 1
35	H.D. COOKE ELEMENTARY SCHOOL	WS- 002417	8/9/2016	3	Fountain	In classroom 310	FT-72016-002417-A	< 1	FT-72016-002417-B	< 1
36	H.D. COOKE ELEMENTARY SCHOOL	WS- 002419	8/9/2016	3	Fountain	In classroom 311	FT-72016-002419-A	< 1	FT-72016-002419-B	< 1
37	H.D. COOKE ELEMENTARY SCHOOL	WS- 002421	8/9/2016	3	Fountain	In classroom 312	FT-72016-002421-A	< 1	FT-72016-002421-B	< 1
38	H.D. COOKE ELEMENTARY SCHOOL	WS- 002423	8/9/2016	3	Fountain	In classroom 313	FT-72016-002423-A	< 1	FT-72016-002423-B	< 1
39	H.D. COOKE ELEMENTARY SCHOOL	WS- 002425	8/9/2016	3	Fountain	In classroom 314	FT-82016-002425-A	< 1	FT-82016-002425-B	< 1
40	H.D. COOKE ELEMENTARY SCHOOL	WS- 002429	8/9/2016	2	Fountain	In classroom 221	FT-72016-002429-A	< 1	FT-72016-002429-B	< 1