



HD Cooke ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002350	4/16/2018	4/16/2019	1	Cooler	In gym 142	High Left	WF-04162018-002350	10/30/2018	FT-FY19-102018-002350-A	< 1	FT-FY19-102018-002350-B	< 1
WS-002351	4/16/2018	4/16/2019	1	Cooler	In gym 142	Low Right	WF-04162018-002351	10/30/2018	FT-FY19-102018-002351-A	< 1	FT-FY19-102018-002351-B	< 1
WS-002352	4/16/2018	4/16/2019	1	Break Room	In work room 130		WF-04162018-002352	10/30/2018	FT-FY19-102018-002352-A	< 1	FT-FY19-102018-002352-B	< 1
WS-002353	4/16/2018	4/16/2019	1	Break Room	In staff lounge 137		WF-04162018-002353	10/30/2018	FT-FY19-102018-002353-A	< 1	FT-FY19-102018-002353-B	< 1
WS-002354	4/16/2018	4/16/2019	1	Combo Fountain	In classroom 132		WF-04162018-002354	10/30/2018	FT-FY19-102018-002354-A	< 1	FT-FY19-102018-002354-B	< 1
WS-002355	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 132		WF-09242018-002355	10/30/2018	FT-FY19-102018-002355-A	< 1	FT-FY19-102018-002355-B	< 1
WS-002356	4/16/2018	4/16/2019	1	Combo Fountain	In classroom 136		WF-04162018-002356	10/30/2018	FT-FY19-102018-002356-A	< 1	FT-FY19-102018-002356-B	< 1
WS-002357	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 136		WF-09242018-002357	10/30/2018	FT-FY19-102018-002357-A	< 1	FT-FY19-102018-002357-B	< 1
WS-002358	4/16/2018	4/16/2019	1	Combo Fountain	In classroom 133		WF-04162018-002358	10/30/2018	FT-FY19-102018-002358-A	< 1	FT-FY19-102018-002358-B	< 1
WS-002359	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 133		WF-09242018-002359	10/30/2018	FT-FY19-102018-002359-A	< 1	FT-FY19-102018-002359-B	< 1
WS-002360	4/16/2018	4/16/2019	1	Combo Fountain	In classroom 135		WF-04162018-002360	10/30/2018	FT-FY19-102018-002360-A	< 1	FT-FY19-102018-002360-B	< 1
WS-002361	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 135		WF-09242018-002361	10/30/2018	FT-FY19-102018-002361-A	< 1	FT-FY19-102018-002361-B	< 1
WS-002366	4/16/2018	4/16/2019	1	Cooler	In hallway across from room 105	High Left	WF-04162018-002366	10/30/2018	FT-FY19-102018-002366-A	< 1	FT-FY19-102018-002366-B	< 1
WS-002367	4/16/2018	4/16/2019	1	Cooler	In hallway across from room 105	Low Right	WF-04162018-002367	10/30/2018	FT-FY19-102018-002367-A	< 1	FT-FY19-102018-002367-B	< 1
WS-002368	4/16/2018	4/16/2019	1	Health Suite	In health suite in exam room 103E		WF-04162018-002368	10/30/2018	FT-FY19-102018-002368-A	< 1	FT-FY19-102018-002368-B	< 1
WS-002369	4/16/2018	4/16/2019	1	Health Suite	In health suite in exam room 103C		WF-04162018-002369	10/30/2018	FT-FY19-102018-002369-A	< 1	FT-FY19-102018-002369-B	< 1
WS-002370	4/16/2018	4/16/2019	1	Break Room	In break room 110		WF-04162018-002370	10/30/2018	FT-FY19-102018-002370-A	< 1	FT-FY19-102018-002370-B	< 1
WS-002374	4/16/2018	4/16/2019	2	Cooler	In hallway across from room 204	High Left	WF-04162018-002374	10/30/2018	FT-FY19-102018-002374-A	< 1	FT-FY19-102018-002374-B	< 1
WS-002375	4/16/2018	4/16/2019	2	Cooler	In hallway across from room 204	Low Right	WF-04162018-002375	10/30/2018	FT-FY19-102018-002375-A	< 1	FT-FY19-102018-002375-B	< 1
WS-002376	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 205		WF-04162018-002376	10/30/2018	FT-FY19-102018-002376-A	< 1	FT-FY19-102018-002376-B	< 1
WS-002377	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 205		WF-09242018-002377	10/30/2018	FT-FY19-102018-002377-A	< 1	FT-FY19-102018-002377-B	< 1
WS-002378	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 204		WF-04162018-002378	10/30/2018	FT-FY19-102018-002378-A	< 1	FT-FY19-102018-002378-B	< 1
WS-002379	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 204		WF-09242018-002379	10/30/2018	FT-FY19-102018-002379-A	< 1	FT-FY19-102018-002379-B	< 1
WS-002380	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 202		WF-04162018-002380	10/30/2018	FT-FY19-102018-002380-A	< 1	FT-FY19-102018-002380-B	< 1
WS-002381	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 202		WF-09242018-002381	10/30/2018	FT-FY19-102018-002381-A	< 1	FT-FY19-102018-002381-B	< 1
WS-002382	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 203		WF-04162018-002382	10/30/2018	FT-FY19-102018-002382-A	< 1	FT-FY19-102018-002382-B	< 1
WS-002383	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 203		WF-09242018-002383	10/30/2018	FT-FY19-102018-002383-A	< 1	FT-FY19-102018-002383-B	< 1
WS-002384	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 210		WF-04162018-002384	10/30/2018	FT-FY19-102018-002384-A	< 1	FT-FY19-102018-002384-B	< 1
WS-002385	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 210		WF-09242018-002385	10/30/2018	FT-FY19-102018-002385-A	< 1	FT-FY19-102018-002385-B	< 1
WS-002386	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 211		WF-04162018-002386	10/30/2018	FT-FY19-102018-002386-A	< 1	FT-FY19-102018-002386-B	< 1
WS-002387	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 211		WF-09242018-002387	10/30/2018	FT-FY19-102018-002387-A	< 1	FT-FY19-102018-002387-B	< 1
WS-002388	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 212		WF-04162018-002388	10/30/2018	FT-FY19-102018-002388-A	< 1	FT-FY19-102018-002388-B	< 1
WS-002389	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 212		WF-09242018-002389	10/30/2018	FT-FY19-102018-002389-A	< 1	FT-FY19-102018-002389-B	< 1

WS- 002390	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 213			WF-04162018-002390	10/30/2018	FT-FY19-102018-002390-A	< 1	FT-FY19-102018-002390-B	< 1
WS- 002391	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 213			WF-09242018-002391	10/30/2018	FT-FY19-102018-002391-A	< 1	FT-FY19-102018-002391-B	< 1
WS- 002392	4/16/2018	4/16/2019	2	Combo Fountain	In resource room 241			WF-04162018-002392	10/30/2018	FT-FY19-102018-002392-A	< 1	FT-FY19-102018-002392-B	< 1
WS- 002393	9/24/2018	9/24/2019	2	Combo Faucet	In resource room 241			WF-09242018-002393	10/30/2018	FT-FY19-102018-002393-A	< 1	FT-FY19-102018-002393-B	< 1
WS- 002394	4/16/2018	4/16/2019	2	Combo Fountain	In resource room 230			WF-04162018-002394	10/30/2018	FT-FY19-102018-002394-A	< 1	FT-FY19-102018-002394-B	< 1
WS- 002395	9/24/2018	9/24/2019	2	Combo Faucet	In resource room 230			WF-09242018-002395	10/30/2018	FT-FY19-102018-002395-A	< 1	FT-FY19-102018-002395-B	< 1
WS- 002396	4/16/2018	4/16/2019	2	Combo Fountain	In resource room 236			WF-04162018-002396	10/30/2018	FT-FY19-102018-002396-A	< 1	FT-FY19-102018-002396-B	< 1
WS- 002397	9/24/2018	9/24/2019	2	Combo Faucet	In resource room 236			WF-09242018-002397	10/30/2018	FT-FY19-102018-002397-A	< 1	FT-FY19-102018-002397-B	< 1
WS- 002398	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 231			WF-04162018-002398	10/30/2018	FT-FY19-102018-002398-A	< 1	FT-FY19-102018-002398-B	< 1
WS- 002399	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 231			WF-09242018-002399	10/30/2018	FT-FY19-102018-002399-A	< 1	FT-FY19-102018-002399-B	< 1
WS- 002400	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 235			WF-04162018-002400	10/30/2018	FT-FY19-102018-002400-A	< 1	FT-FY19-102018-002400-B	< 1
WS- 002401	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 235			WF-09242018-002401	10/30/2018	FT-FY19-102018-002401-A	< 1	FT-FY19-102018-002401-B	< 1
WS- 002402	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 232			WF-04162018-002402	10/30/2018	FT-FY19-102018-002402-A	< 1	FT-FY19-102018-002402-B	< 1
WS- 002403	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 232			WF-09242018-002403	10/30/2018	FT-FY19-102018-002403-A	< 1	FT-FY19-102018-002403-B	< 1
WS- 002404	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 234			WF-04162018-002404	10/30/2018	FT-FY19-102018-002404-A	< 1	FT-FY19-102018-002404-B	< 1
WS- 002405	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 234			WF-09242018-002405	10/30/2018	FT-FY19-102018-002405-A	< 1	FT-FY19-102018-002405-B	< 1
WS- 002406	4/16/2018	4/16/2019	3	Cooler	In hallway across from room 304	High	Left	WF-04162018-002406	10/30/2018	FT-FY19-102018-002406-A	< 1	FT-FY19-102018-002406-B	< 1
WS- 002407	4/16/2018	4/16/2019	3	Cooler	In hallway across from room 304	Low	Right	WF-04162018-002407	10/30/2018	FT-FY19-102018-002407-A	< 1	FT-FY19-102018-002407-B	< 1
WS- 002408	4/16/2018	4/16/2019	3	Combo Fountain	In classroom 303			WF-04162018-002408	10/30/2018	FT-FY19-102018-002408-A	< 1	FT-FY19-102018-002408-B	< 1
WS- 002409	9/24/2018	9/24/2019	3	Combo Faucet	In classroom 303			WF-09242018-002409	10/30/2018	FT-FY19-102018-002409-A	< 1	FT-FY19-102018-002409-B	< 1
WS- 002410	9/24/2018	9/24/2019	3	Combo Faucet	In classroom 302			WF-09242018-002410	10/30/2018	FT-FY19-102018-002410-A	< 1	FT-FY19-102018-002410-B	< 1
WS- 002411	4/16/2018	4/16/2019	3	Combo Fountain	In classroom 302			WF-04162018-002411	10/30/2018	FT-FY19-102018-002411-A	< 1	FT-FY19-102018-002411-B	< 1
WS- 002412	4/16/2018	4/16/2019	3	Combo Fountain	In classroom 304			WF-04162018-002412	10/30/2018	FT-FY19-102018-002412-A	< 1	FT-FY19-102018-002412-B	< 1
WS- 002413	9/24/2018	9/24/2019	3	Combo Faucet	In classroom 304			WF-09242018-002413	10/30/2018	FT-FY19-102018-002413-A	< 1	FT-FY19-102018-002413-B	< 1
WS- 002414	4/16/2018	4/16/2019	3	Combo Fountain	In classroom 305			WF-04162018-002414	10/30/2018	FT-FY19-102018-002414-A	< 1	FT-FY19-102018-002414-B	< 1
WS- 002415	9/24/2018	9/24/2019	3	Combo Faucet	In classroom 305			WF-09242018-002415	10/30/2018	FT-FY19-102018-002415-A	< 1	FT-FY19-102018-002415-B	< 1
WS- 002416	4/16/2018	4/16/2019	3	Break Room	In staff lounge 319			WF-04162018-002416	10/30/2018	FT-FY19-102018-002416-A	< 1	FT-FY19-102018-002416-B	< 1
WS- 002417	4/16/2018	4/16/2019	3	Combo Fountain	In classroom 310			WF-04162018-002417	10/30/2018	FT-FY19-102018-002417-A	< 1	FT-FY19-102018-002417-B	< 1
WS- 002418	9/24/2018	9/24/2019	3	Combo Faucet	In classroom 310			WF-09242018-002418	10/30/2018	FT-FY19-102018-002418-A	< 1	FT-FY19-102018-002418-B	< 1
WS- 002419	4/16/2018	4/16/2019	3	Combo Fountain	In classroom 311			WF-04162018-002419	10/30/2018	FT-FY19-102018-002419-A	< 1	FT-FY19-102018-002419-B	< 1
WS- 002420	9/24/2018	9/24/2019	3	Combo Faucet	In classroom 311			WF-09242018-002420	10/30/2018	FT-FY19-102018-002420-A	< 1	FT-FY19-102018-002420-B	< 1
WS- 002421	4/16/2018	4/16/2019	3	Combo Fountain	In classroom 312			WF-04162018-002421	10/30/2018	FT-FY19-102018-002421-A	< 1	FT-FY19-102018-002421-B	< 1
WS- 002422	9/24/2018	9/24/2019	3	Combo Faucet	In classroom 312			WF-09242018-002422	10/30/2018	FT-FY19-102018-002422-A	< 1	FT-FY19-102018-002422-B	< 1
WS- 002423	4/16/2018	4/16/2019	3	Combo Fountain	In classroom 313			WF-04162018-002423	10/30/2018	FT-FY19-102018-002423-A	< 1	FT-FY19-102018-002423-B	< 1
WS- 002424	9/24/2018	9/24/2019	3	Combo Faucet	In classroom 313			WF-09242018-002424	10/30/2018	FT-FY19-102018-002424-A	< 1	FT-FY19-102018-002424-B	< 1
WS- 002425	4/16/2018	4/16/2019	3	Combo Fountain	In classroom 314			WF-04162018-002425	10/30/2018	FT-FY19-102018-002425-A	< 1	FT-FY19-102018-002425-B	< 1
WS- 002427	4/16/2018	4/16/2019	3	Combo Fountain	In resource room 341			WF-04162018-002427	10/30/2018	FT-FY19-102018-002427-A	< 1	FT-FY19-102018-002427-B	< 1
WS- 002428	9/24/2018	9/24/2019	3	Combo Faucet	In resource room 341			WF-09242018-002428	10/30/2018	FT-FY19-102018-002428-A	< 1	FT-FY19-102018-002428-B	< 1
WS- 002429	4/16/2018	4/16/2019	2	Combo Fountain	In classroom 221			WF-04162018-002429	10/30/2018	FT-FY19-102018-002429-A	< 1	FT-FY19-102018-002429-B	< 1

WS-002430	9/24/2018	9/24/2019	2	Combo Faucet	In classroom 221	WF-09242018-002430	10/30/2018	FT-FY19-102018-002430-A	< 1	FT-FY19-102018-002430-B	< 1
-----------	-----------	-----------	---	--------------	------------------	--------------------	------------	-------------------------	-----	-------------------------	-----

Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002365	1	Food Prep Sink	In kitchen fourth clockwise from entry door	10/30/2018	FT-FY19-102018-002365-A	< 1	FT-FY19-102018-002365-B	< 1	