



HD Woodson HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002538	10/14/2019	10/14/2020	1	Classroom Faucet	In day care room 174	WF-10142019-002538	1/9/2020	FT-FY20-122019-002538-A	<1	FT-FY20-122019-002538-B	<1
WS- 002539	10/14/2019	10/14/2020	1	Classroom Faucet	In day care room 175	WF-10142019-002539	1/9/2020	FT-FY20-122019-002539-A	<1	FT-FY20-122019-002539-B	<1
WS- 002540	10/14/2019	10/14/2020	1	Classroom Faucet	In day care room 175 adjacent to bathroom	WF-10142019-002540	1/9/2020	FT-FY20-122019-002540-A	<1	FT-FY20-122019-002540-B	<1
WS- 004892	4/8/2019	4/8/2020	Basement	Cooler	In hallway adjacent to room 002 High Left	WF-04082019-004892	1/9/2020	FT-FY20-122019-004892-A	<1	FT-FY20-122019-004892-B	<1
WS- 004893	4/8/2019	4/8/2020	Basement	Cooler	In hallway adjacent to room 002 Low Right	WF-04082019-004893	1/9/2020	FT-FY20-122019-004893-A	<1	FT-FY20-122019-004893-B	<1
WS- 004896	4/8/2019	4/8/2020	Basement	Cooler	In hallway adjacent to girls' restroom High Left	WF-04082019-004896	1/9/2020	FT-FY20-122019-004896-A	<1	FT-FY20-122019-004896-B	<1
WS- 004897	4/8/2019	4/8/2020	Basement	Cooler	In hallway adjacent to girls' restroom Low Right	WF-04082019-004897	1/9/2020	FT-FY20-122019-004897-A	<1	FT-FY20-122019-004897-B	<1
WS- 004903	4/8/2019	4/8/2020	Basement	Bottle Filler	In classroom 016 (bottle filler)	WF-04082019-004903	1/9/2020	FT-FY20-122019-004903-A	<1	FT-FY20-122019-004903-B	<1
WS- 004904	4/8/2019	4/8/2020	Basement	Cooler	In classroom 016 High Left	WF-04082019-004904	1/9/2020	FT-FY20-122019-004904-A	<1	FT-FY20-122019-004904-B	<1
WS- 004905	4/8/2019	4/8/2020	Basement	Cooler	In classroom 016 Low Right	WF-04082019-004905	1/9/2020	FT-FY20-122019-004905-A	<1	FT-FY20-122019-004905-B	<1
WS- 004906	4/8/2019	4/8/2020	Basement	Bottle Filler	In the gym 012 (bottle filler)	WF-04082019-004906	1/9/2020	FT-FY20-122019-004906-A	<1	FT-FY20-122019-004906-B	<1
WS- 004907	4/8/2019	4/8/2020	Basement	Cooler	In the gym 012 High Left	WF-04082019-004907	1/9/2020	FT-FY20-122019-004907-A	<1	FT-FY20-122019-004907-B	<1
WS- 004908	4/8/2019	4/8/2020	Basement	Cooler	In the gym 012 Low Right	WF-04082019-004908	1/9/2020	FT-FY20-122019-004908-A	<1	FT-FY20-122019-004908-B	<1
WS- 004911	4/8/2019	4/8/2020	Basement	Bottle Filler	In pool area (bottle filler)	WF-04082019-004911	1/9/2020	FT-FY20-122019-004911-A	<1	FT-FY20-122019-004911-B	<1
WS- 004912	4/8/2019	4/8/2020	Basement	Cooler	In pool area High Left	WF-04082019-004912	1/9/2020	FT-FY20-122019-004912-A	<1	FT-FY20-122019-004912-B	<1
WS- 004913	4/8/2019	4/8/2020	Basement	Cooler	In pool area Low Right	WF-04082019-004913	1/9/2020	FT-FY20-122019-004913-A	<1	FT-FY20-122019-004913-B	<1
WS- 004914	4/8/2019	4/8/2020	3	Cooler	In lobby adjacent to room 333	WF-04082019-004914	1/9/2020	FT-FY20-122019-004914-A	<1	FT-FY20-122019-004914-B	<1
WS- 004929	4/8/2019	4/8/2020	3	Cooler	In hallway adjacent to room 315 High Left	WF-04082019-004929	1/9/2020	FT-FY20-122019-004929-A	<1	FT-FY20-122019-004929-B	<1
WS- 004930	4/8/2019	4/8/2020	3	Cooler	In hallway adjacent to room 315 Low Right	WF-04082019-004930	1/9/2020	FT-FY20-122019-004930-A	<1	FT-FY20-122019-004930-B	<1
WS- 004931	4/8/2019	4/8/2020	3	Cooler	In hallway adjacent to room 307 High Left	WF-04082019-004931	1/9/2020	FT-FY20-122019-004931-A	<1	FT-FY20-122019-004931-B	<1
WS- 004932	4/8/2019	4/8/2020	3	Cooler	In hallway adjacent to room 307 Low Right	WF-04082019-004932	1/9/2020	FT-FY20-122019-004932-A	<1	FT-FY20-122019-004932-B	<1
WS- 004950	4/8/2019	4/8/2020	2	Cooler	In hallway adjacent to room 209A (bottle filler) High Left	WF-04082019-004950	1/9/2020	FT-FY20-122019-004950-A	<1	FT-FY20-122019-004950-B	<1
WS- 004952	4/8/2019	4/8/2020	2	Cooler	In hallway adjacent to room 209A Low Right	WF-04082019-004952	1/9/2020	FT-FY20-122019-004952-A	<1	FT-FY20-122019-004952-B	<1
WS- 004988	4/8/2019	4/8/2020	1	Break Room	In work room 104	WF-04082019-004988	1/9/2020	FT-FY20-122019-004988-A	<1	FT-FY20-122019-004988-B	<1
WS- 004989	4/8/2019	4/8/2020	1	Break Room	In work room 105	WF-04082019-004989	1/9/2020	FT-FY20-122019-004989-A	<1	FT-FY20-122019-004989-B	<1
WS- 004990	4/8/2019	4/8/2020	1	Health Suite	In health suite in exam room W106	WF-04082019-004990	1/9/2020	FT-FY20-122019-004990-A	<1	FT-FY20-122019-004990-B	<1
WS- 004991	4/8/2019	4/8/2020	1	Health Suite	In health suite in exam room W104	WF-04082019-004991	1/9/2020	FT-FY20-122019-004991-A	<1	FT-FY20-122019-004991-B	<1
WS- 004992	4/8/2019	4/8/2020	1	Health Suite	In health suite in dental exam room W111	WF-04082019-004992	1/9/2020	FT-FY20-122019-004992-A	<1	FT-FY20-122019-004992-B	<1
WS- 004993	4/8/2019	4/8/2020	1	Health Suite	In health suite in exam room W112	WF-04082019-004993	1/9/2020	FT-FY20-122019-004993-A	<1	FT-FY20-122019-004993-B	<1
WS- 004994	4/8/2019	4/8/2020	1	Health Suite	In health suite in exam room W113	WF-04082019-004994	1/9/2020	FT-FY20-122019-004994-A	<1	FT-FY20-122019-004994-B	<1
WS- 004996	4/8/2019	4/8/2020	1	Cooler	In hallway adjacent to room 101 High Left	WF-04082019-004996	1/9/2020	FT-FY20-122019-004996-A	<1	FT-FY20-122019-004996-B	<1
WS- 004997	4/8/2019	4/8/2020	1	Cooler	In hallway adjacent to room 101 Low Right	WF-04082019-004997	1/9/2020	FT-FY20-122019-004997-A	<1	FT-FY20-122019-004997-B	<1
WS- 004998	4/8/2019	4/8/2020	1	Bottle Filler	In cafeteria (bottle filler)	WF-04082019-004998	1/9/2020	FT-FY20-122019-004998-A	<1	FT-FY20-122019-004998-B	<1
WS- 005000	4/8/2019	4/8/2020	1	Cooler	In cafeteria High Left	WF-04082019-005000	1/9/2020	FT-FY20-122019-005000-A	<1	FT-FY20-122019-005000-B	<1
WS- 005001	4/8/2019	4/8/2020	1	Cooler	In cafeteria Low Right	WF-04082019-005001	1/9/2020	FT-FY20-122019-005001-A	<1	FT-FY20-122019-005001-B	<1

WS-005003	4/8/2019	4/8/2020	1	Cooler	In hallway adjacent to room 153	High Left	WF-04082019-005003	1/9/2020	FT-FY20-122019-005003-A	<1	FT-FY20-122019-005003-B	<1
WS-005004	4/8/2019	4/8/2020	1	Cooler	In hallway adjacent to room 153	Low Right	WF-04082019-005004	1/9/2020	FT-FY20-122019-005004-A	<1	FT-FY20-122019-005004-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-005006	7/3/2019	7/3/2020	1	Food Prep Sink	In kitchen west wall	WF-07032019-005006	1/9/2020	FT-FY20-122019-005006-A	<1	FT-FY20-122019-005006-B	<1