



Hamilton RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006392	5/18/2020	5/18/2021	Ground Floor	Cooler	In hallway adjacent to men's restroom	Low	Right	WF-05182020-006392	3/9/2021	FT-FY21-022021-006392-A	<1	FT-FY21-022021-006392-B	<1
WS- 006393	5/18/2020	5/18/2021	Ground Floor	Cooler	In hallway adjacent to men's restroom	High	Left	WF-05182020-006393	3/9/2021	FT-FY21-022021-006393-A	<1	FT-FY21-022021-006393-B	<1