



HARDY MS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	HARDY MIDDLE SCHOOL	WS- 008749	8/12/2016	3	Cooler	In hallway across from room 313	High Left	FT-82016-008749-A	< 1	FT-82016-008749-B	< 1
2	HARDY MIDDLE SCHOOL	WS- 008750	8/12/2016	3	Cooler	In hallway across from room 313	Low Right	FT-82016-008750-A	< 1	FT-82016-008750-B	< 1
3	HARDY MIDDLE SCHOOL	WS- 010860	8/12/2016	1	Cooler	In hallway adjacent to room 167	High Left	FT-82016-010860-A	< 1	FT-82016-010860-B	< 1
4	HARDY MIDDLE SCHOOL	WS- 010861	8/12/2016	1	Cooler	In hallway adjacent to room 167	Low Right	FT-82016-010861-A	< 1	FT-82016-010861-B	< 1
5	HARDY MIDDLE SCHOOL	WS- 010863	8/12/2016	1	Health Suite	In health suite 173		FT-82016-010863-A	< 1	FT-82016-010863-B	< 1
6	HARDY MIDDLE SCHOOL	WS- 010867	8/12/2016	1	Bottle Filler	In cafeteria (bottle filler)		FT-82016-010867-A	< 1	FT-82016-010867-B	< 1
7	HARDY MIDDLE SCHOOL	WS- 010868	8/12/2016	1	Cooler	In cafeteria	Low Right	FT-82016-010868-A	< 1	FT-82016-010868-B	< 1
8	HARDY MIDDLE SCHOOL	WS- 010869	8/12/2016	1	Food Prep Sink	In kitchen on island		FT-82016-010869-A	< 1	FT-82016-010869-B	< 1
9	HARDY MIDDLE SCHOOL	WS- 010871	8/12/2016	1	Food Prep Sink	In kitchen adjacent to room 143		FT-82016-010871-A	< 1	FT-82016-010871-B	< 1
10	HARDY MIDDLE SCHOOL	WS- 010872	8/12/2016	1	Food Prep Sink	In kitchen adjacent to ice maker		FT-82016-010872-A	< 1	FT-82016-010872-B	< 1
11	HARDY MIDDLE SCHOOL	WS- 010877	8/12/2016	1	Ice Maker	In kitchen (ice maker)		FT-82016-010877-A	1.8	FT-82016-010877-B	< 1
			10/10/2016					Re-test A	< 1	Re-test B	< 1
12	HARDY MIDDLE SCHOOL	WS- 010880	8/12/2016	1	Cooler	In hallway adjacent to room 119	High Left	FT-82016-010880-A	< 1	FT-82016-010880-B	< 1
13	HARDY MIDDLE SCHOOL	WS- 010881	8/12/2016	1	Cooler	In hallway adjacent to room 119	Low Right	FT-82016-010881-A	< 1	FT-82016-010881-B	< 1
14	HARDY MIDDLE SCHOOL	WS- 010898	8/12/2016	2	Cooler	In hallway adjacent to room 212	High Left	FT-82016-010898-A	< 1	FT-82016-010898-B	< 1
15	HARDY MIDDLE SCHOOL	WS- 010899	8/12/2016	2	Cooler	In hallway adjacent to room 212	Low Right	FT-82016-010899-A	1	FT-82016-010899-B	< 1
			10/10/2016					Re-test A	< 1	Re-test B	< 1
16	HARDY MIDDLE SCHOOL	WS- 010901	8/12/2016	2	Cooler	In hallway adjacent to room 247	High Left	FT-82016-010901-A	< 1	FT-82016-010901-B	< 1
17	HARDY MIDDLE SCHOOL	WS- 010902	8/12/2016	2	Cooler	In hallway adjacent to room 247	Low Right	FT-82016-010902-A	< 1	FT-82016-010902-B	< 1
18	HARDY MIDDLE SCHOOL	WS- 010903	8/12/2016	2	Cooler	In gym	High Left	FT-82016-010903-A	1	FT-82016-010903-B	< 1
			10/10/2016					Re-test A	< 1	Re-test B	< 1
19	HARDY MIDDLE SCHOOL	WS- 010904	8/12/2016	2	Cooler	In gym	Low Right	FT-82016-010904-A	< 1	FT-82016-010904-B	< 1
20	HARDY MIDDLE SCHOOL	WS- 010906	8/12/2016	1	Cooler	In cafeteria	High Left	FT-82016-010906-A	1	FT-82016-010906-B	< 1