



Hardy Middle School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008749	5/4/2022	5/4/2023	3	Cooler	In hallway across from room 313	High Left	WF-05042022-008749	2/2/2023	FT-FY23-01102023-008749-A	<1	FT-FY23-01102023-008749-B	<1
WS- 008750	5/4/2022	5/4/2023	3	Cooler	In hallway across from room 313	Low Right	WF-05042022-008750	2/2/2023	FT-FY23-01102023-008750-A	<1	FT-FY23-01102023-008750-B	<1
WS- 008753	5/4/2022	5/4/2023	3	Break Room	In staff lounge 327		WF-05042022-008753	2/2/2023	FT-FY23-01102023-008753-A	<1	FT-FY23-01102023-008753-B	<1
WS- 010860	5/4/2022	5/4/2023	1	Cooler	In hallway adjacent to room 167	High Left	WF-05042022-010860	2/2/2023	FT-FY23-01102023-010860-A	<1	FT-FY23-01102023-010860-B	<1
WS- 010861	5/4/2022	5/4/2023	1	Cooler	In hallway adjacent to room 167	Low Right	WF-05042022-010861	2/2/2023	FT-FY23-01102023-010861-A	<1	FT-FY23-01102023-010861-B	<1
WS- 010863	5/4/2022	5/4/2023	1	Health Suite	In health suite 173		WF-05042022-010863	2/2/2023	FT-FY23-01102023-010863-A	<1	FT-FY23-01102023-010863-B	<1
WS- 010867	5/4/2022	5/4/2023	1	Bottle Filler	In cafeteria (bottle filler)		WF-05042022-010867	2/2/2023	FT-FY23-01102023-010867-A	<1	FT-FY23-01102023-010867-B	<1
WS- 010880	5/4/2022	5/4/2023	1	Cooler	In hallway adjacent to room 119	High Left	WF-05042022-010880	2/2/2023	FT-FY23-01102023-010880-A	<1	FT-FY23-01102023-010880-B	<1
WS- 010881	5/4/2022	5/4/2023	1	Cooler	In hallway adjacent to room 119	Low Right	WF-05042022-010881	2/2/2023	FT-FY23-01102023-010881-A	<1	FT-FY23-01102023-010881-B	<1
WS- 010882	5/4/2022	5/4/2023	1	Break Room	In staff lounge 134		WF-05042022-010882	2/2/2023	FT-FY23-01102023-010882-A	<1	FT-FY23-01102023-010882-B	<1
WS- 010897	5/4/2022	5/4/2023	2	Break Room	In staff lounge 229		WF-05042022-010897	2/2/2023	FT-FY23-01102023-010897-A	<1	FT-FY23-01102023-010897-B	<1
WS- 010898	5/4/2022	5/4/2023	2	Cooler	In hallway adjacent to room 212	High Left	WF-05042022-010898	2/2/2023	FT-FY23-01102023-010898-A	<1	FT-FY23-01102023-010898-B	<1
WS- 010899	5/4/2022	5/4/2023	2	Cooler	In hallway adjacent to room 212	Low Right	WF-05042022-010899	2/2/2023	FT-FY23-01102023-010899-A	<1	FT-FY23-01102023-010899-B	<1
WS- 010901	5/4/2022	5/4/2023	2	Cooler	In hallway adjacent to room 247	High Left	WF-05042022-010901	2/2/2023	FT-FY23-01102023-010901-A	<1	FT-FY23-01102023-010901-B	<1
WS- 010902	5/4/2022	5/4/2023	2	Cooler	In hallway adjacent to room 247	Low Right	WF-05042022-010902	2/2/2023	FT-FY23-01102023-010902-A	<1	FT-FY23-01102023-010902-B	<1
WS- 010903	5/4/2022	5/4/2023	2	Cooler	In gym	High Left	WF-05042022-010903	2/2/2023	FT-FY23-01102023-010903-A	<1	FT-FY23-01102023-010903-B	<1
WS- 010904	5/4/2022	5/4/2023	2	Cooler	In gym	Low Right	WF-05042022-010904	2/2/2023	FT-FY23-01102023-010904-A	<1	FT-FY23-01102023-010904-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010869	12/20/2022	12/20/2023	1	Food Prep Sink	In kitchen on island		WF-12202022-010869	2/2/2023	FT-FY23-01102023-010869-A	<1	FT-FY23-01102023-010869-B	<1
WS- 010871	12/20/2022	12/20/2023	1	Food Prep Sink	In kitchen adjacent to room 143		WF-12202022-010871	2/2/2023	FT-FY23-01102023-010871-A	<1	FT-FY23-01102023-010871-B	<1
WS- 010872	12/20/2022	12/20/2023	1	Food Prep Sink	In kitchen adjacent to ice maker		WF-12202022-010872	2/2/2023	FT-FY23-01102023-010872-A	<1	FT-FY23-01102023-010872-B	<1