



Hardy Middle School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 008749	4/26/2023	4/26/2024	3	Cooler	In hallway across from room 313 High Left	WF-04262023-008749	11/13/2023	FT-FY24-10102023-008749-A	<1	FT-FY24-10102023-008749-B	<1	
WS- 008750	4/26/2023	4/26/2024	3	Cooler	In hallway across from room 313 Low Right	WF-04262023-008750	11/13/2023	FT-FY24-10102023-008750-A	<1	FT-FY24-10102023-008750-B	<1	
WS- 008753	4/26/2023	4/26/2024	3	Break Room	In staff lounge 327	WF-04262023-008753	11/13/2023	FT-FY24-10102023-008753-A	<1	FT-FY24-10102023-008753-B	<1	
WS- 010860	4/26/2023	4/26/2024	1	Cooler	In hallway adjacent to room 167 High Left	WF-04262023-010860	11/13/2023	FT-FY24-10102023-010860-A	<1	FT-FY24-10102023-010860-B	<1	
WS- 010861	4/26/2023	4/26/2024	1	Cooler	In hallway adjacent to room 167 Low Right	WF-04262023-010861	11/13/2023	FT-FY24-10102023-010861-A	<1	FT-FY24-10102023-010861-B	<1	
WS- 010863	4/26/2023	4/26/2024	1	Health Suite	In health suite 173	WF-04262023-010863	11/13/2023	FT-FY24-10102023-010863-A	<1	FT-FY24-10102023-010863-B	<1	
WS- 010867	4/26/2023	4/26/2024	1	Bottle Filler	In cafeteria (bottle filler)	WF-04262023-010867	11/13/2023	FT-FY24-10102023-010867-A	<1	FT-FY24-10102023-010867-B	<1	
WS- 010868	4/26/2023	4/26/2024	1	Cooler	In cafeteria Low Right	WF-04262023-010868	11/13/2023	FT-FY24-10102023-010868-A	<1	FT-FY24-10102023-010868-B	<1	
WS- 010880	4/26/2023	4/26/2024	1	Cooler	In hallway adjacent to room 119 High Left	WF-04262023-010880	11/13/2023	FT-FY24-10102023-010880-A	<1	FT-FY24-10102023-010880-B	<1	
WS- 010881	4/26/2023	4/26/2024	1	Cooler	In hallway adjacent to room 119 Low Right	WF-04262023-010881	11/13/2023	FT-FY24-10102023-010881-A	<1	FT-FY24-10102023-010881-B	<1	
WS- 010882	4/26/2023	4/26/2024	1	Break Room	In staff lounge 134	WF-04262023-010882	11/13/2023	FT-FY24-10102023-010882-A	1.1	FT-FY24-10102023-010882-B	<1	
WS- 010897	4/26/2023	4/26/2024	2	Break Room	In staff lounge 229	WF-04262023-010897	11/13/2023	FT-FY24-10102023-010897-A	<1	FT-FY24-10102023-010897-B	<1	
WS- 010898	4/26/2023	4/26/2024	2	Cooler	In hallway adjacent to room 212 High Left	WF-04262023-010898	11/13/2023	FT-FY24-10102023-010898-A	<1	FT-FY24-10102023-010898-B	<1	
WS- 010899	4/26/2023	4/26/2024	2	Cooler	In hallway adjacent to room 212 Low Right	WF-04262023-010899	11/13/2023	FT-FY24-10102023-010899-A	<1	FT-FY24-10102023-010899-B	<1	
WS- 010901	4/26/2023	4/26/2024	2	Cooler	In hallway adjacent to room 247 High Left	WF-04262023-010901	11/13/2023	FT-FY24-10102023-010901-A	<1	FT-FY24-10102023-010901-B	<1	
WS- 010902	4/26/2023	4/26/2024	2	Cooler	In hallway adjacent to room 247 Low Right	WF-04262023-010902	11/13/2023	FT-FY24-10102023-010902-A	<1	FT-FY24-10102023-010902-B	<1	
WS- 010903	4/26/2023	4/26/2024	2	Cooler	In gym High Left	WF-04262023-010903	11/13/2023	FT-FY24-10102023-010903-A	<1	FT-FY24-10102023-010903-B	<1	
WS- 010904	4/26/2023	4/26/2024	2	Cooler	In gym Low Right	WF-04262023-010904	11/13/2023	FT-FY24-10102023-010904-A	<1	FT-FY24-10102023-010904-B	<1	
WS- 010906	4/26/2023	4/26/2024	1	Cooler	In cafeteria High Left	WF-04262023-010906	11/13/2023	FT-FY24-10102023-010906-A	<1	FT-FY24-10102023-010906-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010871	12/20/2022	12/20/2023	1	Food Prep Sink	In kitchen adjacent to room 143	WF-12202022-010871	11/13/2023	FT-FY24-10102023-010871-A	<1	FT-FY24-10102023-010871-B	<1
WS- 010872	12/20/2022	12/20/2023	1	Food Prep Sink	In kitchen adjacent to ice maker	WF-12202022-010872	11/13/2023	FT-FY24-10102023-010872-A	4.7	FT-FY24-10102023-010872-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010869	12/20/2022	12/20/2023	1	Food Prep Sink	In kitchen on island	WF-12202022-010869	11/13/2023	FT-FY24-10102023-010869-A	7.9	FT-FY24-10102023-010869-B	<1

**First Re-Test (After Plumbing Check)
FY24 Filter Test**

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010869	11/17/2023	11/17/2024	1	Food Prep Sink	In kitchen on island	WF-11172023-010869	11/21/2023	FT-FY24-11192023-010869-A	1.8	FT-FY24-11192023-010869-B	<1