



# HARDY REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	HARDY RECREATION CENTER	WS- 005515	9/20/2016	Ground Floor	Bottle Filler	In main lobby adjacent women's restroom (bottle filler) High	FT-82016-005515-A	< 1	FT-82016-005515-B	< 1
2	HARDY RECREATION CENTER	WS- 005516	9/20/2016	Ground Floor	Cooler	In main lobby adjacent to women's restroom Low	FT-82016-005516-A	< 1	FT-82016-005516-B	< 1
3	HARDY RECREATION CENTER	WS- 005517	9/20/2016	Ground Floor	Food Prep Sink	In kitchenette in main lobby	FT-82016-005517-A	< 1	FT-82016-005517-B	< 1