



Hardy MS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008749	4/30/2018	4/30/2019	3	Cooler	In hallway across from room 313	High Left	WF-04302018-008749	12/28/2018	FT-FY19-122018-008749-A	<1	FT-FY19-122018-008749-B	<1
WS- 008750	4/30/2018	4/30/2019	3	Cooler	In hallway across from room 313	Low Right	WF-04302018-008750	12/28/2018	FT-FY19-122018-008750-A	<1	FT-FY19-122018-008750-B	<1
WS- 008753	4/30/2018	4/30/2019	3	Break Room	In staff lounge 327		WF-04302018-008753	12/28/2018	FT-FY19-122018-008753-A	<1	FT-FY19-122018-008753-B	<1
WS- 008762	4/30/2018	4/30/2019	3	Break Room	In staff lounge 339		WF-04302018-008762	12/27/2018	FT-FY19-122018-008762-A	<1	FT-FY19-122018-008762-B	<1
WS- 008763	4/30/2018	4/30/2019	3	Cooler	In hallway across from classroom 302	High Left	WF-04302018-008763	12/27/2018	FT-FY19-122018-008763-A	<1	FT-FY19-122018-008763-B	<1
WS- 008764	4/30/2018	4/30/2019	3	Cooler	In hallway across from classroom 302	Low Right	WF-04302018-008764	12/27/2018	FT-FY19-122018-008764-A	<1	FT-FY19-122018-008764-B	<1
WS- 010860	4/30/2018	4/30/2019	1	Cooler	In hallway adjacent to room 167	High Left	WF-04302018-010860	12/28/2018	FT-FY19-122018-010860-A	<1	FT-FY19-122018-010860-B	<1
WS- 010861	4/30/2018	4/30/2019	1	Cooler	In hallway adjacent to room 167	Low Right	WF-04302018-010861	12/28/2018	FT-FY19-122018-010861-A	<1	FT-FY19-122018-010861-B	<1
WS- 010863	4/30/2018	4/30/2019	1	Health Suite	In health suite 173		WF-04302018-010863	12/28/2018	FT-FY19-122018-010863-A	<1	FT-FY19-122018-010863-B	<1
WS- 010867	4/30/2018	4/30/2019	1	Bottle Filler	In cafeteria (bottle filler)		WF-04302018-010867	12/28/2018	FT-FY19-122018-010867-A	<1	FT-FY19-122018-010867-B	<1
WS- 010868	4/30/2018	4/30/2019	1	Cooler	In cafeteria	Low Right	WF-04302018-010868	12/28/2018	FT-FY19-122018-010868-A	<1	FT-FY19-122018-010868-B	<1
WS- 010880	4/30/2018	4/30/2019	1	Cooler	In hallway adjacent to room 119	High Left	WF-04302018-010880	12/28/2018	FT-FY19-122018-010880-A	<1	FT-FY19-122018-010880-B	<1
WS- 010881	4/30/2018	4/30/2019	1	Cooler	In hallway adjacent to room 119	Low Right	WF-04302018-010881	12/28/2018	FT-FY19-122018-010881-A	<1	FT-FY19-122018-010881-B	<1
WS- 010882	4/30/2018	4/30/2019	1	Break Room	In staff lounge 134		WF-04302018-010882	12/28/2018	FT-FY19-122018-010882-A	<1	FT-FY19-122018-010882-B	<1
WS- 010897	4/30/2018	4/30/2019	2	Break Room	In staff lounge 229		WF-04302018-010897	12/28/2018	FT-FY19-122018-010897-A	<1	FT-FY19-122018-010897-B	<1
WS- 010901	4/30/2018	4/30/2019	2	Cooler	In hallway adjacent to room 247	High Left	WF-04302018-010901	12/28/2018	FT-FY19-122018-010901-A	<1	FT-FY19-122018-010901-B	<1
WS- 010902	4/30/2018	4/30/2019	2	Cooler	In hallway adjacent to room 247	Low Right	WF-04302018-010902	12/28/2018	FT-FY19-122018-010902-A	<1	FT-FY19-122018-010902-B	<1
WS- 010903	4/30/2018	4/30/2019	2	Cooler	In gym	High Left	WF-04302018-010903	12/28/2018	FT-FY19-122018-010903-A	<1	FT-FY19-122018-010903-B	<1
WS- 010904	4/30/2018	4/30/2019	2	Cooler	In gym	Low Right	WF-04302018-010904	12/28/2018	FT-FY19-122018-010904-A	<1	FT-FY19-122018-010904-B	<1
WS- 010906	4/30/2018	4/30/2019	1	Cooler	In cafeteria	High Left	WF-04302018-010906	12/28/2018	FT-FY19-122018-010906-A	<1	FT-FY19-122018-010906-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location		Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010869	1	Food Prep Sink	In kitchen on island		12/28/2018	FT-FY19-122018-010869-A	<1	FT-FY19-122018-010869-B	<1
WS- 010871	1	Food Prep Sink	In kitchen adjacent to room 143		12/28/2018	FT-FY19-122018-010871-A	<1	FT-FY19-122018-010871-B	<1
WS- 010872	1	Food Prep Sink	In kitchen adjacent to ice maker		12/28/2018	FT-FY19-122018-010872-A	<1	FT-FY19-122018-010872-B	<1