



HARRISON REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	HARRISON RECREATION CENTER	WS- 006137	9/21/2016	1	Food Prep Sink	In kitchen area adjacent to janitors' closet	FT-82016-006137-A	< 1	FT-82016-006137-B	< 1
2	HARRISON RECREATION CENTER	WS- 006138	9/21/2016	1	Cooler	In hallway adjacent to boys' restroom	FT-82016-006138-A	< 1	FT-82016-006138-B	< 1