



Harry Thomas Recreation Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005658	3/13/2024	3/13/2025	2	Bottle Filler	In hallway	WF-03132024-005658	4/2/2024	FT-FY24-03202024-005658-A	<1	FT-FY24-03202024-005658-B	<1
WS- 005659	3/13/2024	3/13/2025	2	Cooler	In hallway High Right	WF-03132024-005659	4/2/2024	FT-FY24-03202024-005659-A	<1	FT-FY24-03202024-005659-B	<1
WS- 005661	3/13/2024	3/13/2025	2	Cooler	In hallway Low Left	WF-03132024-005661	4/2/2024	FT-FY24-03202024-005661-A	<1	FT-FY24-03202024-005661-B	<1
WS- 005662	12/18/2023	12/18/2024	2	Food Prep Sink	In kitchen	WF-12182023-005662	4/2/2024	FT-FY24-03202024-005662-A	<1	FT-FY24-03202024-005662-B	<1