



Harry Thomas Recreation Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005658	3/30/2022	3/30/2023	2	Bottle Filler	In hallway	WF-03302022-005658	2/20/2023	FT-FY23-02022023-005658-A	<1	FT-FY23-02022023-005658-B	<1
WS- 005659	3/30/2022	3/30/2023	2	Cooler	In hallway High Right	WF-03302022-005659	2/20/2023	FT-FY23-02022023-005659-A	<1	FT-FY23-02022023-005659-B	<1
WS- 005661	3/30/2022	3/30/2023	2	Cooler	In hallway Low Left	WF-03302022-005661	2/20/2023	FT-FY23-02022023-005661-A	<1	FT-FY23-02022023-005661-B	<1
WS- 005662	1/25/2023	1/25/2024	2	Food Prep Sink	In kitchen	WF-01252023-005662	2/20/2023	FT-FY23-02022023-005662-A	<1	FT-FY23-02022023-005662-B	<1