



Harry Thomas RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005658	3/30/2021	3/30/2022	2	Bottle Filler	In hallway	WF-03302021-005658	5/7/2021	FT-FY21-042021-005658-A	<1	FT-FY21-042021-005658-B	<1
WS- 005659	3/30/2021	3/30/2022	2	Cooler	In hallway High Right	WF-03302021-005659	5/7/2021	FT-FY21-042021-005659-A	<1	FT-FY21-042021-005659-B	<1
WS- 005661	3/30/2021	3/30/2022	2	Cooler	In hallway Low Left	WF-03302021-005661	5/7/2021	FT-FY21-042021-005661-A	<1	FT-FY21-042021-005661-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005662	3/17/2021	3/17/2022	2	Food Prep Sink	In kitchen	WF-03172021-005662	5/7/2021	FT-FY21-042021-005662-A	<1	FT-FY21-042021-005662-B	<1