



HARRY THOMAS REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	HARRY THOMAS RECREATION CENTER	WS- 005661	9/21/2016	2	Cooler	In hallway	FT-82016-005661-A	< 1	FT-82016-005661-B	< 1
2	HARRY THOMAS RECREATION CENTER	WS- 005662	9/21/2016	2	Food Prep Sink	In kitchen	FT-82016-005662-A	< 1	FT-82016-005662-B	< 1