



HART MS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	HART MIDDLE SCHOOL	WS- 000415	8/23/2016	1	Health Suite	In Health Suite	FT-82016-000415-A	< 1	FT-82016-000415-B	< 1
2	HART MIDDLE SCHOOL	WS- 004386	8/23/2016	2	Cooler	In hallway adjacent to room 206 High Left	FT-72016-004386-A	< 1	FT-72016-004386-B	< 1
3	HART MIDDLE SCHOOL	WS- 004387	8/23/2016	2	Cooler	In hallway adjacent to room 206 Low Right	FT-72016-004387-A	< 1	FT-72016-004387-B	< 1
4	HART MIDDLE SCHOOL	WS- 004404	8/23/2016	3	Cooler	In hallway adjacent to room 305	FT-72016-004404-A	< 1	FT-72016-004404-B	< 1
5	HART MIDDLE SCHOOL	WS- 004406	8/23/2016	3	Cooler	In hallway adjacent to room 321 High Left	FT-72016-004406-A	< 1	FT-72016-004406-B	< 1
6	HART MIDDLE SCHOOL	WS- 004407	8/23/2016	3	Cooler	In hallway adjacent to room 321 Low Right	FT-72016-004407-A	< 1	FT-72016-004407-B	< 1
7	HART MIDDLE SCHOOL	WS- 004409	8/23/2016	2	Fountain	In classroom 235 Left	FT-72016-004409-A	< 1	FT-72016-004409-B	< 1
8	HART MIDDLE SCHOOL	WS- 004412	8/23/2016	Basement	Cooler	In hallway adjacent to room B029	FT-72016-004412-A	< 1	FT-72016-004412-B	< 1
9	HART MIDDLE SCHOOL	WS- 009912	8/23/2016	Basement	Cooler	In hallway adjacent to room 023 High Left	FT-72016-009912-A	< 1	FT-72016-009912-B	< 1
10	HART MIDDLE SCHOOL	WS- 009913	8/23/2016	Basement	Cooler	In hallway adjacent to room 023 Low Right	FT-72016-009913-A	< 1	FT-72016-009913-B	< 1
11	HART MIDDLE SCHOOL	WS- 009916	8/23/2016	Basement	Cooler	In cafeteria	FT-72016-009916-A	< 1	FT-72016-009916-B	< 1
12	HART MIDDLE SCHOOL	WS- 009917	8/23/2016	Basement	Food Prep Sink	In kitchen first clock wise from entry door Left	FT-82016-009917-A	< 1	FT-82016-009917-B	< 1
13	HART MIDDLE SCHOOL	WS- 009920	8/23/2016	1	Cooler	In hallway adjacent to room 103 High Left	FT-72016-009920-A	< 1	FT-72016-009920-B	< 1
14	HART MIDDLE SCHOOL	WS- 009921	8/23/2016	1	Cooler	In hallway adjacent to room 103 Low Right	FT-72016-009921-A	< 1	FT-72016-009921-B	< 1
15	HART MIDDLE SCHOOL	WS- 009922	8/23/2016	1	Fountain	In classroom 117 Right	FT-72016-009922-A	< 1	FT-72016-009922-B	< 1
16	HART MIDDLE SCHOOL	WS- 009925	8/23/2016	1	Fountain	In classroom 116 Right	FT-72016-009925-A	< 1	FT-72016-009925-B	3.1
17	HART MIDDLE SCHOOL	WS- 009927	8/23/2016	1	Fountain	In classroom 118 Right	FT-72016-009927-A	< 1	FT-72016-009927-B	< 1
18	HART MIDDLE SCHOOL	WS- 009928	8/23/2016	1	Fountain	In classroom 119 Right	FT-82016-009928-A	< 1	FT-82016-009928-B	< 1
19	HART MIDDLE SCHOOL	WS- 009931	8/23/2016	1	Fountain	In classroom 114 Right	FT-72016-009931-A	< 1	FT-72016-009931-B	< 1
20	HART MIDDLE SCHOOL	WS- 009932	8/23/2016	1	Cooler	In girls' locker room	FT-72016-009932-A	< 1	FT-72016-009932-B	< 1
21	HART MIDDLE SCHOOL	WS- 009933	8/23/2016	1	Cooler	In hallway adjacent to room 119	FT-72016-009933-A	< 1	FT-72016-009933-B	< 1
22	HART MIDDLE SCHOOL	WS- 009934	8/23/2016	1	Cooler	In hallway adjacent to room 123	FT-72016-009934-A	< 1	FT-72016-009934-B	< 1
23	HART MIDDLE SCHOOL	WS- 009935	8/23/2016	1	Cooler	In hallway adjacent to room 123	FT-72016-009935-A	< 1	FT-72016-009935-B	< 1
24	HART MIDDLE SCHOOL	WS- 009936	8/23/2016	1	Cooler	In hallway adjacent to room 131	FT-72016-009936-A	< 1	FT-72016-009936-B	< 1
25	HART MIDDLE SCHOOL	WS- 009937	8/23/2016	2	Cooler	In hallway across from room 245 High Left	FT-72016-009937-A	< 1	FT-72016-009937-B	< 1
26	HART MIDDLE SCHOOL	WS- 009938	8/23/2016	2	Cooler	In hallway across from room 245 Low Right	FT-72016-009938-A	< 1	FT-72016-009938-B	< 1
27	HART MIDDLE SCHOOL	WS- 009939	8/23/2016	2	Cooler	In hallway adjacent to room 232 High Left	FT-72016-009939-A	< 1	FT-72016-009939-B	< 1
28	HART MIDDLE SCHOOL	WS- 009940	8/23/2016	2	Cooler	In hallway adjacent to room 232 Low Right	FT-72016-009940-A	< 1	FT-72016-009940-B	< 1
29	HART MIDDLE SCHOOL	WS- 009951	8/23/2016	2	Cooler	In hallway adjacent to room 226 High Left	FT-72016-009951-A	< 1	FT-72016-009951-B	< 1
30	HART MIDDLE SCHOOL	WS- 009952	8/23/2016	2	Cooler	In hallway adjacent to room 226 Low Right	FT-72016-009952-A	< 1	FT-72016-009952-B	< 1
31	HART MIDDLE SCHOOL	WS- 011597	8/23/2016	1	Cooler	In boys' locker room	FT-72016-011597-A	< 1	FT-72016-011597-B	< 1