



HART LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw	
1	HART MIDDLE SCHOOL	5/13/2016	WS-004385	Classroom	2	In room 206 counterclockwise 5	WT-042916-4402-A	3.06	WT-042916-4402-B	< 1				
2	HART MIDDLE SCHOOL	5/13/2016	WS-004386	Cooler	2	In hallway adjacent to room 206	WT-042916-4403-A	< 1	WT-042916-4403-B	< 1				
3	HART MIDDLE SCHOOL	5/13/2016	WS-004387	Cooler	2	In hallway adjacent to room 206 Right Low	WT-042916-4404-A	< 1	WT-042916-4404-B	< 1				
4	HART MIDDLE SCHOOL	5/13/2016	WS-004388	Classroom	2	In room 201 counter clockwise 1	WT-042916-4405-A	9.21	WT-042916-4405-B	1.43				
5	HART MIDDLE SCHOOL	5/13/2016	WS-004389	Classroom	2	In room 201 counter clockwise 2	WT-042916-4406-A	1.57	WT-042916-4406-B	< 1				
6	HART MIDDLE SCHOOL	5/14/2016	WS-004390	Classroom	2	In room 201 counterclockwise 3	WT-042916-4407-A	1.97	WT-042916-4407-B	< 1				
7	HART MIDDLE SCHOOL	5/13/2016	WS-004391	Classroom	2	In room 201 counter clockwise 4	WT-042916-4408-A	1.97	WT-042916-4408-B	< 1				
8	HART MIDDLE SCHOOL	5/13/2016	WS-004392	Classroom	2	In room 201 counterclockwise 5	WT-042916-4409-A	7.2	WT-042916-4409-B	< 1				
9	HART MIDDLE SCHOOL	5/13/2016	WS-004393	Classroom	3	In room 301 clockwise 1	WT-042916-4410-A	6.4	WT-042916-4410-B	1.02				
10	HART MIDDLE SCHOOL	5/13/2016	WS-004394	Classroom	3	In room 301 clockwise 2	WT-042916-4411-A	1.21	WT-042916-4411-B	< 1				
11	HART MIDDLE SCHOOL	5/13/2016	WS-004395	Classroom	3	In room 301 clockwise 3	WT-042916-4412-A	1.2	WT-042916-4412-B	< 1				
12	HART MIDDLE SCHOOL	5/13/2016	WS-004396	Classroom	3	In room 301 clockwise 4	WT-042916-4413-A	< 1	WT-042916-4413-B	< 1				
13	HART MIDDLE SCHOOL	5/13/2016	WS-004397	Classroom	3	In room 301 clockwise 5	WT-042916-4414-A	< 1	WT-042916-4414-B	< 1				
14	HART MIDDLE SCHOOL	5/13/2016	WS-004398	Classroom	3	In room 303	WT-042916-4415-A	7.07	WT-042916-4415-B	< 1				
15	HART MIDDLE SCHOOL	5/13/2016	WS-004399	Classroom	3	In room 305 counterclockwise 1	WT-042916-4416-A	1.02	WT-042916-4416-B	< 1				
16	HART MIDDLE SCHOOL	5/13/2016	WS-004400	Classroom	3	In room 305 counter clockwise 2	WT-042916-4417-A	3	WT-042916-4417-B	< 1				
17	HART MIDDLE SCHOOL	5/13/2016	WS-004401	Classroom	3	In room 305 counterclockwise 3	WT-042916-4418-A	1.05	WT-042916-4418-B	< 1				
18	HART MIDDLE SCHOOL	5/13/2016	WS-004402	Classroom	3	In room 305 counter clockwise 4	WT-042916-4419-A	< 1	WT-042916-4419-B	< 1				
19	HART MIDDLE SCHOOL	5/13/2016	WS-004403	Classroom	5	In room 305 counterclockwise 5	WT-042916-4420-A	1.78	WT-042916-4420-B	< 1				
20	HART MIDDLE SCHOOL	5/13/2016	WS-004404	Cooler	3	In hallway adjacent to room 305	WT-042916-4421-A	< 1	WT-042916-4421-B	< 1				
21	HART MIDDLE SCHOOL	5/13/2016	WS-004405	Classroom	3	In room 312	WT-042916-4422-A	< 1	WT-042916-4422-B	< 1				
22	HART MIDDLE SCHOOL	5/13/2016	WS-004406	Cooler	3	In hallway adjacent to 321 Left High	WT-042916-4423-A	< 1	WT-042916-4423-B	< 1				
23	HART MIDDLE SCHOOL	5/13/2016	WS-004407	Cooler	3	In hallway adjacent to room 321 Right Low	WT-042916-4424-A	< 1	WT-042916-4424-B	< 1				
24	HART MIDDLE SCHOOL	5/13/2016	WS-004408	Classroom	2	In room 203	WT-042916-4425-A	2.12	WT-042916-4425-B	< 1				
25	HART MIDDLE SCHOOL	5/13/2016	WS-004409	Fountain	2	In room 235 Left	WT-042916-4426-A	9.19	WT-042916-4426-B	3.1				
26	HART MIDDLE SCHOOL	5/13/2016	WS-004410	Classroom	2	In room 235 Right	WT-042916-4427-A	1.78	WT-042916-4427-B	< 1				
27	HART MIDDLE SCHOOL	5/13/2016	WS-004411	Kitchen	Basement	In kitchen (Ice maker)	WT-042916-4428-A	< 1	WT-042916-4428-B	< 1				
28	HART MIDDLE SCHOOL	5/13/2016	WS-004412	Cooler	Basement	In hallway adjacent to room B029	WT-042916-4429-A	2.6	WT-042916-4429-B	1.45				
29	HART MIDDLE SCHOOL	5/13/2016	WS-009909	Utility	Basement	In boiler room (water source)	WT-042916-9926-A	33.8	WT-042916-9926-B	11.3	Non-drinking water source - Not accessible to children (boilers)			
30	HART MIDDLE SCHOOL	5/13/2016	WS-009910	Classroom	Basement	In room 006	WT-042916-9927-A	< 1	WT-042916-9927-B	< 1				
31	HART MIDDLE SCHOOL	5/13/2016	WS-009911	Classroom	Basement	In room 006 clock wise 2	WT-042916-9928-A	< 1	WT-042916-9928-B	< 1				
32	HART MIDDLE SCHOOL	5/13/2016	WS-009912	Cooler	Basement	In hallway adjacent to room 023 Left High	WT-042916-9929-A	9.88	WT-042916-9929-B	23	Filter will be installed and then retested			
33	HART MIDDLE SCHOOL	5/13/2016	WS-009913	Cooler	Basement	In hallways adjacent to room 023 Right Low	WT-042916-9930-A	15.4	WT-042916-9930-B	26	Filter will be installed and then retested			
34	HART MIDDLE SCHOOL	5/13/2016	WS-009914	Classroom	Basement	In room across from 031 Left	WT-042916-9931-A	< 1	WT-042916-9931-B	< 1				
35	HART MIDDLE SCHOOL	5/13/2016	WS-009915	Classroom	Basement	In room across 031 Right	WT-042916-9932-A	< 1	WT-042916-9932-B	< 1				
36	HART MIDDLE SCHOOL	5/13/2016	WS-009916	Cooler	Basement	In Cafeteria	WT-042916-9933-A	< 1	WT-042916-9933-B	< 1				
37	HART MIDDLE SCHOOL	5/13/2016	WS-009917	Kitchen	Basement	In kitchen clock wise 1 Left	WT-042916-9934-A	2.21	WT-042916-9934-B	< 1				
38	HART MIDDLE SCHOOL	5/13/2016	WS-009918	Kitchen	Basement	In kitchen clockwise 2	WT-042916-9935-A	< 1	WT-042916-9935-B	< 1				
39	HART MIDDLE SCHOOL	5/13/2016	WS-009919	Kitchen	Basement	In kitchen clock wise 3	WT-042916-9936-A	1.46	WT-042916-9936-B	< 1				
40	HART MIDDLE SCHOOL	5/13/2016	WS-009920	Cooler	1	In hallway adjacent to room 103 Left High	WT-042916-9937-A	< 1	WT-042916-9937-B	< 1				
41	HART MIDDLE SCHOOL	5/13/2016	WS-009921	Cooler	1	In hallway adjacent to room 103 Right Low	WT-042916-9938-A	< 1	WT-042916-9938-B	< 1				
42	HART MIDDLE SCHOOL	5/13/2016	WS-009922	Fountain	1	In room 117 Right	WT-042916-9939-A	12.5	WT-042916-9939-B	3.71				
43	HART MIDDLE SCHOOL	5/13/2016	WS-009923	Classroom	1	In room 117 Left	WT-042916-9940-A	4.82	WT-042916-9940-B	< 1				
44	HART MIDDLE SCHOOL	5/13/2016	WS-009924	Classroom	1	In room 116 Left	WT-042916-9941-A	5.38	WT-042916-9941-B	< 1				
45	HART MIDDLE SCHOOL	5/13/2016	WS-009925	Fountain	1	In room 116 Right	WT-042916-9942-A	3.09	WT-042916-9942-B	1.1				
46	HART MIDDLE SCHOOL	5/13/2016	WS-009926	Classroom	1	In room 118 Left	WT-042916-9943-A	1.21	WT-042916-9943-B	< 1				
47	HART MIDDLE SCHOOL	5/13/2016	WS-009927	Classroom	1	In room 118 Right	WT-042916-9944-A	4.83	WT-042916-9944-B	1.56				
48	HART MIDDLE SCHOOL	5/13/2016	WS-009928	Fountain	1	In room 119 Right	WT-042916-9945-A	13.8	WT-042916-9945-B	5.36				



HART LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
49 HART MIDDLE SCHOOL	5/13/2016	WS- 009929	Classroom	1	in room 119 Left	WT-042916-9946- A	1.65	WT-042916-9946- B	< 1				
50 HART MIDDLE SCHOOL	5/13/2016	WS- 009930	Classroom	1	in room 114 Left	WT-042916-9947- A	< 1	WT-042916-9947- B	< 1				
51 HART MIDDLE SCHOOL	5/13/2016	WS- 009931	Classroom	1	in room 114 Right	WT-042916-9948- A	2.51	WT-042916-9948- B	< 1				
52 HART MIDDLE SCHOOL	5/13/2016	WS- 009932	Cooler	1	in gym girls locker room	WT-042916-9949- A	< 1	WT-042916-9949- B	< 1				
53 HART MIDDLE SCHOOL	5/13/2016	WS- 009933	Cooler	1	in hallway adjacent to room 119	WT-042916-9950- A	< 1	WT-042916-9950- B	< 1				
54 HART MIDDLE SCHOOL	5/13/2016	WS- 009934	Cooler	1	in hallway adjacent to 123	WT-042916-9951- A	< 1	WT-042916-9951- B	< 1				
55 HART MIDDLE SCHOOL	5/13/2016	WS- 009935	Cooler	1	in hallway adjacent to room 123	WT-042916-9952- A	< 1	WT-042916-9952- B	< 1				
56 HART MIDDLE SCHOOL	5/13/2016	WS- 009936	Cooler	1	in hallway adjacent to room 131	WT-042916-9953- A	< 1	WT-042916-9953- B	< 1				
57 HART MIDDLE SCHOOL	5/13/2016	WS- 009937	Cooler	2	in hallway across from room 245 Left High	WT-042916-9954- A	< 1	WT-042916-9954- B	< 1				
58 HART MIDDLE SCHOOL	5/13/2016	WS- 009938	Cooler	2	in hallway across from the room 245 Right Low	WT-042916-9955- A	< 1	WT-042916-9955- B	< 1				
59 HART MIDDLE SCHOOL	5/13/2016	WS- 009939	Cooler	2	in hallway adjacent to room 232 Left High	WT-042916-9956- A	< 1	WT-042916-9956- B	< 1				
60 HART MIDDLE SCHOOL	5/13/2016	WS- 009940	Cooler	2	in hallway adjacent to room 232 Right Low	WT-042916-9957- A	< 1	WT-042916-9957- B	< 1				
61 HART MIDDLE SCHOOL	5/13/2016	WS- 009941	Classroom	2	in room 239 clockwise 1	WT-042916-9958- A	5.06	WT-042916-9958- B	2.1				
62 HART MIDDLE SCHOOL	5/13/2016	WS- 009942	Classroom	2	in room 239 counter clockwise 2	WT-042916-9959- A	< 1	WT-042916-9959- B	< 1				
63 HART MIDDLE SCHOOL	5/13/2016	WS- 009943	Classroom	2	in room 239 counterclockwise 3	WT-042916-9960- A	3.66	WT-042916-9960- B	< 1				
64 HART MIDDLE SCHOOL	5/13/2016	WS- 009944	Classroom	2	in room 239 counter clockwise 4	WT-042916-9961- A	5.12	WT-042916-9961- B	< 1				
65 HART MIDDLE SCHOOL	5/13/2016	WS- 009945	Classroom	2	in room 239 counter clockwise 5	WT-042916-9962- A	6.65	WT-042916-9962- B	1.62				
66 HART MIDDLE SCHOOL	5/13/2016	WS- 009946	Classroom	2	in room 233 counter clockwise 1	WT-042916-9963- A	3.22	WT-042916-9963- B	< 1				
67 HART MIDDLE SCHOOL	5/13/2016	WS- 009947	Classroom	2	in room 233 counterclockwise 2	WT-042916-9964- A	14.5	WT-042916-9964- B	< 1				
68 HART MIDDLE SCHOOL	5/13/2016	WS- 009948	Classroom	2	in room 233 counter clockwise 3	WT-042916-9965- A	1.26	WT-042916-9965- B	2.19				
69 HART MIDDLE SCHOOL	5/13/2016	WS- 009949	Classroom	2	in room 233 counter clockwise 4	WT-042916-9966- A	2.05	WT-042916-9966- B	< 1				
70 HART MIDDLE SCHOOL	5/13/2016	WS- 009950	Classroom	2	in room 233 counterclockwise 5	WT-042916-9967- A	< 1	WT-042916-9967- B	< 1				
71 HART MIDDLE SCHOOL	5/13/2016	WS- 009951	Cooler	2	in hallway adjacent to room 226 Left High	WT-042916-9968- A	< 1	WT-042916-9968- B	< 1				
72 HART MIDDLE SCHOOL	5/13/2016	WS- 009952	Cooler	2	in hallway adjacent to room 226 Right Low	WT-042916-9969- A	< 1	WT-042916-9969- B	< 1				
73 HART MIDDLE SCHOOL	5/13/2016	WS- 009953	Break Room	2	in room 218	WT-042916-9970- A	< 1	WT-042916-9970- B	< 1				
74 HART MIDDLE SCHOOL	5/13/2016	WS- 009954	Classroom	2	in room 206 counter clockwise 1	WT-042916-9971- A	15.2	WT-042916-9971- B	< 1	Filter will be installed and then retested			
75 HART MIDDLE SCHOOL	5/13/2016	WS- 009955	Classroom	2	in room 206 counterclockwise 2	WT-042916-9972- A	10.1	WT-042916-9972- B	< 1				
76 HART MIDDLE SCHOOL	5/13/2016	WS- 009956	Classroom	2	in room 206 counter clockwise 3	WT-042916-9973- A	4.3	WT-042916-9973- B	< 1				
77 HART MIDDLE SCHOOL	5/13/2016	WS- 009957	Classroom	2	in room 206 counter clockwise 4	WT-042916-9974- A	1.07	WT-042916-9974- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.