



Hart Middle School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000415	3/1/2023	3/1/2024	1	Health Suite	In health suite	WF-03012023-000415	12/11/2023	FT-FY24-11012023-000415-A	<1	FT-FY24-11012023-000415-B	<1
WS- 004386	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to room 206 High Left	WF-03012023-004386	12/11/2023	FT-FY24-11012023-004386-A	<1	FT-FY24-11012023-004386-B	<1
WS- 004387	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to room 206 Low Right	WF-03012023-004387	12/11/2023	FT-FY24-11012023-004387-A	<1	FT-FY24-11012023-004387-B	<1
WS- 004404	3/1/2023	3/1/2024	3	Cooler	In hallway adjacent to room 305	WF-03012023-004404	12/11/2023	FT-FY24-11012023-004404-A	<1	FT-FY24-11012023-004404-B	<1
WS- 004405	3/1/2023	3/1/2024	3	Break Room	In break room 312	WF-03012023-004405	12/11/2023	FT-FY24-11012023-004405-A	<1	FT-FY24-11012023-004405-B	<1
WS- 004406	3/1/2023	3/1/2024	3	Cooler	In hallway adjacent to room 321 High Left	WF-03012023-004406	12/11/2023	FT-FY24-11012023-004406-A	<1	FT-FY24-11012023-004406-B	<1
WS- 004407	3/1/2023	3/1/2024	3	Cooler	In hallway adjacent to room 321 Low Right	WF-03012023-004407	12/11/2023	FT-FY24-11012023-004407-A	<1	FT-FY24-11012023-004407-B	<1
WS- 004409	3/1/2023	3/1/2024	2	Combo Fountain	In classroom 235 Left	WF-03012023-004409	12/11/2023	FT-FY24-11012023-004409-A	<1	FT-FY24-11012023-004409-B	<1
WS- 004410	9/12/2023	9/12/2024	2	Combo Faucet	In classroom 235 Prep/Storage Room Right	WF-09122023-004410	12/11/2023	FT-FY24-11012023-004410-A	<1	FT-FY24-11012023-004410-B	<1
WS- 007257	3/1/2023	3/1/2024	1	Bottle Filler	In hallway adjacent to room 123	WF-03012023-007257	12/11/2023	FT-FY24-11012023-007257-A	<1	FT-FY24-11012023-007257-B	<1
WS- 009120	3/1/2023	3/1/2024	1	Break Room	In break room 101	WF-03012023-009120	12/11/2023	FT-FY24-11012023-009120-A	<1	FT-FY24-11012023-009120-B	<1
WS- 009916	3/1/2023	3/1/2024	Basement	Cooler	In cafeteria	WF-03012023-009916	12/11/2023	FT-FY24-11012023-009916-A	<1	FT-FY24-11012023-009916-B	<1
WS- 009922	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 117 Right	WF-03012023-009922	12/11/2023	FT-FY24-11012023-009922-A	<1	FT-FY24-11012023-009922-B	<1
WS- 009923	9/12/2023	9/12/2024	1	Combo Faucet	In classroom 117 Left	WF-09122023-009923	12/11/2023	FT-FY24-11012023-009923-A	<1	FT-FY24-11012023-009923-B	<1
WS- 009924	9/12/2023	9/12/2024	1	Combo Faucet	In classroom 116 Left	WF-09122023-009924	12/11/2023	FT-FY24-11012023-009924-A	<1	FT-FY24-11012023-009924-B	<1
WS- 009925	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 116 Right	WF-03012023-009925	12/11/2023	FT-FY24-11012023-009925-A	<1	FT-FY24-11012023-009925-B	<1
WS- 009930	9/12/2023	9/12/2024	1	Combo Faucet	In classroom 114 Left	WF-09122023-009930	12/11/2023	FT-FY24-11012023-009930-A	2.3	FT-FY24-11012023-009930-B	1.3
WS- 009931	3/1/2023	3/1/2024	1	Combo Fountain	In classroom 114 Right	WF-03012023-009931	12/11/2023	FT-FY24-11012023-009931-A	<1	FT-FY24-11012023-009931-B	<1
WS- 009934	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to room 123	WF-03012023-009934	12/11/2023	FT-FY24-11012023-009934-A	<1	FT-FY24-11012023-009934-B	<1
WS- 009935	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to room 123	WF-03012023-009935	12/11/2023	FT-FY24-11012023-009935-A	<1	FT-FY24-11012023-009935-B	<1
WS- 009936	3/1/2023	3/1/2024	1	Cooler	In hallway adjacent to room 131	WF-03012023-009936	12/11/2023	FT-FY24-11012023-009936-A	<1	FT-FY24-11012023-009936-B	<1
WS- 009953	3/1/2023	3/1/2024	2	Break Room	In break room 218	WF-03012023-009953	12/11/2023	FT-FY24-11012023-009953-A	<1	FT-FY24-11012023-009953-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009917	1/17/2023	1/17/2024	Basement	Food Prep Sink	In kitchen first clock wise from entry door Left	WF-01172023-009917	12/11/2023	FT-FY24-11012023-009917-A	<1	FT-FY24-11012023-009917-B	<1