



Hart Middle School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 000415	3/16/2021	3/16/2022	1	Health Suite	In health suite	WF-03162021-000415	3/6/2022	FT-FY22-02092022-000415-A	<1	FT-FY22-02092022-000415-B	<1	
WS- 004405	3/16/2021	3/16/2022	3	Break Room	In break room 312	WF-03162021-004405	3/6/2022	FT-FY22-02092022-004405-A	<1	FT-FY22-02092022-004405-B	<1	
WS- 004406	3/16/2021	3/16/2022	3	Cooler	In hallway adjacent to room 321	High Left	WF-03162021-004406	3/6/2022	FT-FY22-02092022-004406-A	<1	FT-FY22-02092022-004406-B	<1
WS- 004407	3/16/2021	3/16/2022	3	Cooler	In hallway adjacent to room 321	Low Right	WF-03162021-004407	3/6/2022	FT-FY22-02092022-004407-A	<1	FT-FY22-02092022-004407-B	<1
WS- 009120	3/16/2021	3/16/2022	1	Break Room	In break room 101	WF-03162021-009120	3/6/2022	FT-FY22-02092022-009120-A	<1	FT-FY22-02092022-009120-B	<1	
WS- 009912	3/16/2021	3/16/2022	Basement	Cooler	In hallway adjacent to room 023	WF-03162021-009912	3/6/2022	FT-FY22-02092022-009912-A	<1	FT-FY22-02092022-009912-B	<1	
WS- 009916	3/16/2021	3/16/2022	Basement	Cooler	In cafeteria	WF-03162021-009916	3/6/2022	FT-FY22-02092022-009916-A	<1	FT-FY22-02092022-009916-B	<1	
WS- 009922	3/16/2021	3/16/2022	1	Combo Fountain	In classroom 117	Right	WF-03162021-009922	3/6/2022	FT-FY22-02092022-009922-A	<1	FT-FY22-02092022-009922-B	<1
WS- 009923	9/29/2021	9/29/2022	1	Combo Faucet	In classroom 117	Left	WF-09292021-009923	3/6/2022	FT-FY22-02092022-009923-A	<1	FT-FY22-02092022-009923-B	<1
WS- 009924	9/29/2021	9/29/2022	1	Combo Faucet	In classroom 116	Left	WF-09292021-009924	3/6/2022	FT-FY22-02092022-009924-A	<1	FT-FY22-02092022-009924-B	<1
WS- 009925	3/16/2021	3/16/2022	1	Combo Fountain	In classroom 116	Right	WF-03162021-009925	3/6/2022	FT-FY22-02092022-009925-A	<1	FT-FY22-02092022-009925-B	<1
WS- 009926	9/29/2021	9/29/2022	1	Combo Faucet	In classroom 118	Left	WF-09292021-009926	3/6/2022	FT-FY22-02092022-009926-A	<1	FT-FY22-02092022-009926-B	<1
WS- 009927	3/16/2021	3/16/2022	1	Combo Fountain	In classroom 118	Right	WF-03162021-009927	3/6/2022	FT-FY22-02092022-009927-A	<1	FT-FY22-02092022-009927-B	<1
WS- 009928	3/16/2021	3/16/2022	1	Combo Fountain	In classroom 119	Right	WF-03162021-009928	3/6/2022	FT-FY22-02092022-009928-A	1.4	FT-FY22-02092022-009928-B	<1
WS- 009929	9/29/2021	9/29/2022	1	Combo Faucet	In classroom 119	Left	WF-09292021-009929	3/6/2022	FT-FY22-02092022-009929-A	1.2	FT-FY22-02092022-009929-B	1.2
WS- 009930	9/29/2021	9/29/2022	1	Combo Faucet	In classroom 114	Left	WF-09292021-009930	3/6/2022	FT-FY22-02092022-009930-A	1.5	FT-FY22-02092022-009930-B	1.5
WS- 009931	3/16/2021	3/16/2022	1	Combo Fountain	In classroom 114	Right	WF-03162021-009931	3/6/2022	FT-FY22-02092022-009931-A	<1	FT-FY22-02092022-009931-B	1.8
WS- 009932	3/16/2021	3/16/2022	1	Cooler	In girls' locker room	WF-03162021-009932	3/6/2022	FT-FY22-02092022-009932-A	<1	FT-FY22-02092022-009932-B	<1	
WS- 009933	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to room 119	WF-03162021-009933	3/6/2022	FT-FY22-02092022-009933-A	2.2	FT-FY22-02092022-009933-B	<1	
WS- 009937	3/16/2021	3/16/2022	2	Cooler	In hallway across from room 245	High Left	WF-03162021-009937	3/6/2022	FT-FY22-02092022-009937-A	<1	FT-FY22-02092022-009937-B	<1
WS- 009938	3/16/2021	3/16/2022	2	Cooler	In hallway across from room 245	Low Right	WF-03162021-009938	3/6/2022	FT-FY22-02092022-009938-A	<1	FT-FY22-02092022-009938-B	<1
WS- 009939	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 232	High Left	WF-03162021-009939	3/6/2022	FT-FY22-02092022-009939-A	<1	FT-FY22-02092022-009939-B	<1
WS- 009940	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 232	Low Right	WF-03162021-009940	3/6/2022	FT-FY22-02092022-009940-A	<1	FT-FY22-02092022-009940-B	<1
WS- 009951	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 226	High Left	WF-03162021-009951	3/6/2022	FT-FY22-02092022-009951-A	<1	FT-FY22-02092022-009951-B	<1
WS- 009952	3/16/2021	3/16/2022	2	Cooler	In hallway adjacent to room 226	Low Right	WF-03162021-009952	3/6/2022	FT-FY22-02092022-009952-A	<1	FT-FY22-02092022-009952-B	<1
WS- 009953	3/16/2021	3/16/2022	2	Break Room	In break room 218	WF-03162021-009953	3/6/2022	FT-FY22-02092022-009953-A	<1	FT-FY22-02092022-009953-B	<1	
WS- 011597	3/16/2021	3/16/2022	1	Cooler	In boys' locker room	WF-03162021-011597	3/6/2022	FT-FY22-02092022-011597-A	<1	FT-FY22-02092022-011597-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 009917	2/9/2022	2/9/2023	Basement	Food Prep Sink	In kitchen first clock wise from entry door	Left	WF-02092022-009917	3/6/2022	FT-FY22-02092022-009917-A	<1	FT-FY22-02092022-009917-B	<1