



Hart Middle School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000415	3/8/2022	3/8/2023	1	Health Suite	In health suite	WF-03082022-000415	1/23/2023	FT-FY23-12292022-000415-A	<1	FT-FY23-12292022-000415-B	<1
WS- 004387	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to room 206 Low Right	WF-03082022-004387	1/23/2023	FT-FY23-12292022-004387-A	1.1	FT-FY23-12292022-004387-B	2.6
WS- 004404	3/8/2022	3/8/2023	3	Cooler	In hallway adjacent to room 305	WF-03082022-004404	1/23/2023	FT-FY23-12292022-004404-A	<1	FT-FY23-12292022-004404-B	<1
WS- 004405	3/8/2022	3/8/2023	3	Break Room	In break room 312	WF-03082022-004405	1/23/2023	FT-FY23-12292022-004405-A	<1	FT-FY23-12292022-004405-B	<1
WS- 004406	3/8/2022	3/8/2023	3	Cooler	In hallway adjacent to room 321 High Left	WF-03082022-004406	1/23/2023	FT-FY23-12292022-004406-A	<1	FT-FY23-12292022-004406-B	<1
WS- 004407	3/8/2022	3/8/2023	3	Cooler	In hallway adjacent to room 321 Low Right	WF-03082022-004407	1/23/2023	FT-FY23-12292022-004407-A	<1	FT-FY23-12292022-004407-B	<1
WS- 004541	3/8/2022	3/8/2023	Basement	Bottle Filler	In hallway adjacent to room 023	WF-03082022-004541	1/23/2023	FT-FY23-12292022-004541-A	<1	FT-FY23-12292022-004541-B	<1
WS- 009916	3/8/2022	3/8/2023	Basement	Cooler	In cafeteria	WF-03082022-009916	1/23/2023	FT-FY23-12292022-009916-A	<1	FT-FY23-12292022-009916-B	<1
WS- 009922	3/8/2022	3/8/2023	1	Combo Fountain	In classroom 117 Right	WF-03082022-009922	1/23/2023	FT-FY23-12292022-009922-A	<1	FT-FY23-12292022-009922-B	<1
WS- 009923	9/19/2022	9/19/2023	1	Combo Faucet	In classroom 117 Left	WF-09192022-009923	1/23/2023	FT-FY23-12292022-009923-A	1.1	FT-FY23-12292022-009923-B	<1
WS- 009924	9/19/2022	9/19/2023	1	Combo Faucet	In classroom 116 Left	WF-09192022-009924	1/23/2023	FT-FY23-12292022-009924-A	<1	FT-FY23-12292022-009924-B	<1
WS- 009925	3/8/2022	3/8/2023	1	Combo Fountain	In classroom 116 Right	WF-03082022-009925	1/23/2023	FT-FY23-12292022-009925-A	<1	FT-FY23-12292022-009925-B	<1
WS- 009928	3/8/2022	3/8/2023	1	Combo Fountain	In classroom 119 Right	WF-03082022-009928	1/23/2023	FT-FY23-12292022-009928-A	<1	FT-FY23-12292022-009928-B	<1
WS- 009929	9/19/2022	9/19/2023	1	Combo Faucet	In classroom 119 Left	WF-09192022-009929	1/23/2023	FT-FY23-12292022-009929-A	<1	FT-FY23-12292022-009929-B	<1
WS- 009930	9/19/2022	9/19/2023	1	Combo Faucet	In classroom 114 Left	WF-09192022-009930	1/23/2023	FT-FY23-12292022-009930-A	2.0	FT-FY23-12292022-009930-B	<1
WS- 009931	3/8/2022	3/8/2023	1	Combo Fountain	In classroom 114 Right	WF-03082022-009931	1/23/2023	FT-FY23-12292022-009931-A	<1	FT-FY23-12292022-009931-B	<1
WS- 009936	3/8/2022	3/8/2023	1	Cooler	In hallway adjacent to room 131	WF-03082022-009936	1/23/2023	FT-FY23-12292022-009936-A	<1	FT-FY23-12292022-009936-B	<1
WS- 009937	3/8/2022	3/8/2023	2	Cooler	In hallway across from room 245 High Left	WF-03082022-009937	1/23/2023	FT-FY23-12292022-009937-A	<1	FT-FY23-12292022-009937-B	<1
WS- 009938	3/8/2022	3/8/2023	2	Cooler	In hallway across from room 245 Low Right	WF-03082022-009938	1/23/2023	FT-FY23-12292022-009938-A	<1	FT-FY23-12292022-009938-B	<1
WS- 009939	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to room 232 High Left	WF-03082022-009939	1/23/2023	FT-FY23-12292022-009939-A	<1	FT-FY23-12292022-009939-B	<1
WS- 009940	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to room 232 Low Right	WF-03082022-009940	1/23/2023	FT-FY23-12292022-009940-A	<1	FT-FY23-12292022-009940-B	<1
WS- 009951	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to room 226 High Left	WF-03082022-009951	1/23/2023	FT-FY23-12292022-009951-A	<1	FT-FY23-12292022-009951-B	<1
WS- 009952	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to room 226 Low Right	WF-03082022-009952	1/23/2023	FT-FY23-12292022-009952-A	<1	FT-FY23-12292022-009952-B	<1
WS- 009953	3/8/2022	3/8/2023	2	Break Room	In break room 218	WF-03082022-009953	1/23/2023	FT-FY23-12292022-009953-A	<1	FT-FY23-12292022-009953-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009917	2/9/2022	2/9/2023	Basement	Food Prep Sink	In kitchen first clock wise from entry door Left	WF-02092022-009917	1/23/2023	FT-FY23-12292022-009917-A	<1	FT-FY23-12292022-009917-B	<1

FY23 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004386	3/8/2022	3/8/2023	2	Cooler	In hallway adjacent to room 206 High Left	WF-03082022-004386	1/23/2023	FT-FY23-12292022-004386-A	2.0	FT-FY23-12292022-004386-B	5.1

First Re-test (After Plumbing Check)

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004386	3/1/2023	3/1/2024	2	Cooler	In hallway adjacent to room 206	High	Left	WF-03012023-004386	3/7/2023	FT-FY23-03012023-004386-A	<1	FT-FY23-03012023-004386-B	<1