



Hart Middle School Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation														
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004406	5/25/17	5/25/18	3	Cooler	In hallway adjacent to room 321	Left	High	WF-52017-004406	12/7/17	FT-FY18--52017-004406-A	<1	FT-FY18--52017-004406-B	<1	
WS- 004407	5/25/17	5/25/18	3	Cooler	In hallway adjacent to room 321	Right	Low	WF-52017-004407	12/7/17	FT-FY18--52017-004407-A	<1	FT-FY18--52017-004407-B	<1	
WS- 009923	11/15/17	11/15/18	1	Combo Faucet	In classroom 117	Left		WF-112017-009923	12/7/17	FT-FY18-112017-009923-A	2.2	FT-FY18-112017-009923-B	<1	
WS- 009925	5/25/17	5/25/18	1	Combo Fountain	In classroom 116	Right		WF-52017-009925	12/7/17	FT-FY18--52017-009925-A	<1	FT-FY18--52017-009925-B	<1	
WS- 009926	11/15/17	11/15/18	1	Combo Faucet	In classroom 118	Left		WF-112017-009926	12/7/17	FT-FY18-112017-009926-A	<1	FT-FY18-112017-009926-B	<1	
WS- 009930	11/15/17	11/15/18	1	Combo Faucet	In classroom 114	Left		WF-112017-009930	12/7/17	FT-FY18-112017-009930-A	<1	FT-FY18-112017-009930-B	<1	
WS- 009932	5/25/17	5/25/18	1	Cooler	In girls' locker room			WF-52017-009932	12/7/17	FT-FY18--52017-009932-A	<1	FT-FY18--52017-009932-B	<1	
WS- 009934	5/25/17	5/25/18	1	Cooler	In hallway adjacent to room 123			WF-52017-009934	12/7/17	FT-FY18--52017-009934-A	<1	FT-FY18--52017-009934-B	<1	
WS- 009935	5/25/17	5/25/18	1	Cooler	In hallway adjacent to room 123			WF-52017-009935	12/7/17	FT-FY18--52017-009935-A	<1	FT-FY18--52017-009935-B	<1	
WS- 009936	5/25/17	5/25/18	1	Cooler	In hallway adjacent to room 131			WF-52017-009936	12/7/17	FT-FY18--52017-009936-A	<1	FT-FY18--52017-009936-B	<1	
WS- 009951	5/25/17	5/25/18	2	Cooler	In hallway adjacent to room 226	Left	High	WF-52017-009951	12/7/17	FT-FY18--52017-009951-A	<1	FT-FY18--52017-009951-B	<1	
WS- 009953	5/25/17	5/25/18	2	Break Room	In break room 218			WF-52017-009953	12/7/17	FT-FY18--52017-009953-A	<1	FT-FY18--52017-009953-B	<1	
WS- 011597	5/25/17	5/25/18	1	Cooler	In boys' locker room			WF-52017-011597	12/7/17	FT-FY18--52017-011597-A	<1	FT-FY18--52017-011597-B	<1	

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009917	Basement	Food Prep Sink	In kitchen first clock wise from entry door	Left			12/7/17	FT-FY18-102017-009917-A	1.7	FT-FY18-102017-009917-B	<1