



Hart MS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000415	4/11/2018	4/11/2019	1	Health Suite	In health suite	WF-04112018-000415	12/18/2018	FT-FY19-122018-000415-A	<1	FT-FY19-122018-000415-B	<1
WS- 004386	4/11/2018	4/11/2019	2	Cooler	In hallway adjacent to room 206 High Left	WF-04112018-004386	12/18/2018	FT-FY19-122018-004386-A	<1	FT-FY19-122018-004386-B	<1
WS- 004387	4/11/2018	4/11/2019	2	Cooler	In hallway adjacent to room 206 Low Right	WF-04112018-004387	12/18/2018	FT-FY19-122018-004387-A	<1	FT-FY19-122018-004387-B	<1
WS- 004404	4/11/2018	4/11/2019	3	Cooler	In hallway adjacent to room 305	WF-04112018-004404	12/18/2018	FT-FY19-122018-004404-A	<1	FT-FY19-122018-004404-B	<1
WS- 004405	4/11/2018	4/11/2019	3	Break Room	In break room 312	WF-04112018-004405	12/18/2018	FT-FY19-122018-004405-A	<1	FT-FY19-122018-004405-B	<1
WS- 004406	4/11/2018	4/11/2019	3	Cooler	In hallway adjacent to room 321 High Left	WF-04112018-004406	12/18/2018	FT-FY19-122018-004406-A	<1	FT-FY19-122018-004406-B	<1
WS- 004407	4/11/2018	4/11/2019	3	Cooler	In hallway adjacent to room 321 Low Right	WF-04112018-004407	12/18/2018	FT-FY19-122018-004407-A	<1	FT-FY19-122018-004407-B	<1
WS- 004409	4/11/2018	4/11/2019	2	Combo Fountain	In classroom 235 Left	WF-04112018-004409	12/18/2018	FT-FY19-122018-004409-A	<1	FT-FY19-122018-004409-B	<1
WS- 004410	10/23/2018	10/23/2019	2	Combo Faucet	In classroom 235 Right	WF-10232018-004410	12/18/2018	FT-FY19-122018-004410-A	<1	FT-FY19-122018-004410-B	<1
WS- 009120	4/11/2018	4/11/2019	1	Break Room	In break room 101	WF-04112018-009120	12/18/2018	FT-FY19-122018-009120-A	<1	FT-FY19-122018-009120-B	<1
WS- 009912	4/11/2018	4/11/2019	Basement	Cooler	In hallway adjacent to room 023	WF-04112018-009912	12/18/2018	FT-FY19-122018-009912-A	<1	FT-FY19-122018-009912-B	<1
WS- 009916	4/11/2018	4/11/2019	Basement	Cooler	In cafeteria	WF-04112018-009916	12/18/2018	FT-FY19-122018-009916-A	<1	FT-FY19-122018-009916-B	<1
WS- 009920	4/11/2018	4/11/2019	1	Cooler	In hallway adjacent to room 103	WF-04112018-009920	12/18/2018	FT-FY19-122018-009920-A	<1	FT-FY19-122018-009920-B	<1
WS- 009922	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 117 Right	WF-04112018-009922	12/18/2018	FT-FY19-122018-009922-A	<1	FT-FY19-122018-009922-B	<1
WS- 009923	10/23/2018	10/23/2019	1	Combo Faucet	In classroom 117 Left	WF-10232018-009923	12/18/2018	FT-FY19-122018-009923-A	<1	FT-FY19-122018-009923-B	<1
WS- 009924	10/23/2018	10/23/2019	1	Combo Faucet	In classroom 116 Left	WF-10232018-009924	12/18/2018	FT-FY19-122018-009924-A	<1	FT-FY19-122018-009924-B	<1
WS- 009925	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 116 Right	WF-04112018-009925	12/18/2018	FT-FY19-122018-009925-A	<1	FT-FY19-122018-009925-B	<1
WS- 009926	10/23/2018	10/23/2019	1	Combo Faucet	In classroom 118 Left	WF-10232018-009926	12/18/2018	FT-FY19-122018-009926-A	<1	FT-FY19-122018-009926-B	<1
WS- 009927	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 118 Right	WF-04112018-009927	12/18/2018	FT-FY19-122018-009927-A	<1	FT-FY19-122018-009927-B	<1
WS- 009928	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 119 Right	WF-04112018-009928	12/18/2018	FT-FY19-122018-009928-A	<1	FT-FY19-122018-009928-B	1
WS- 009929	10/23/2018	10/23/2019	1	Combo Faucet	In classroom 119 Left	WF-10232018-009929	12/18/2018	FT-FY19-122018-009929-A	<1	FT-FY19-122018-009929-B	<1
WS- 009930	10/23/2018	10/23/2019	1	Combo Faucet	In classroom 114 Left	WF-10232018-009930	12/18/2018	FT-FY19-122018-009930-A	<1	FT-FY19-122018-009930-B	<1
WS- 009931	4/11/2018	4/11/2019	1	Combo Fountain	In classroom 114 Right	WF-04112018-009931	12/18/2018	FT-FY19-122018-009931-A	<1	FT-FY19-122018-009931-B	<1
WS- 009932	4/11/2018	4/11/2019	1	Cooler	In girls' locker room	WF-04112018-009932	12/18/2018	FT-FY19-122018-009932-A	<1	FT-FY19-122018-009932-B	<1
WS- 009933	4/11/2018	4/11/2019	1	Cooler	In hallway adjacent to room 119	WF-04112018-009933	12/18/2018	FT-FY19-122018-009933-A	<1	FT-FY19-122018-009933-B	<1
WS- 009936	4/11/2018	4/11/2019	1	Cooler	In hallway adjacent to room 131	WF-04112018-009936	12/18/2018	FT-FY19-122018-009936-A	<1	FT-FY19-122018-009936-B	<1
WS- 009937	4/11/2018	4/11/2019	2	Cooler	In hallway across from room 245 High Left	WF-04112018-009937	12/18/2018	FT-FY19-122018-009937-A	<1	FT-FY19-122018-009937-B	<1
WS- 009938	4/11/2018	4/11/2019	2	Cooler	In hallway across from room 245 Low Right	WF-04112018-009938	12/18/2018	FT-FY19-122018-009938-A	<1	FT-FY19-122018-009938-B	<1
WS- 009939	4/11/2018	4/11/2019	2	Cooler	In hallway adjacent to room 232 High Left	WF-04112018-009939	12/18/2018	FT-FY19-122018-009939-A	<1	FT-FY19-122018-009939-B	<1
WS- 009940	4/11/2018	4/11/2019	2	Cooler	In hallway adjacent to room 232 Low Right	WF-04112018-009940	12/18/2018	FT-FY19-122018-009940-A	<1	FT-FY19-122018-009940-B	<1
WS- 009951	4/11/2018	4/11/2019	2	Cooler	In hallway adjacent to room 226 High Left	WF-04112018-009951	12/18/2018	FT-FY19-122018-009951-A	<1	FT-FY19-122018-009951-B	<1
WS- 009952	4/11/2018	4/11/2019	2	Cooler	In hallway adjacent to room 226 Low Right	WF-04112018-009952	12/18/2018	FT-FY19-122018-009952-A	<1	FT-FY19-122018-009952-B	<1
WS- 009953	4/11/2018	4/11/2019	2	Break Room	In break room 218	WF-04112018-009953	12/18/2018	FT-FY19-122018-009953-A	<1	FT-FY19-122018-009953-B	<1
WS- 011597	4/11/2018	4/11/2019	1	Cooler	In boys' locker room	WF-04112018-011597	12/18/2018	FT-FY19-122018-011597-A	<1	FT-FY19-122018-011597-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009919	Basement	Food Prep Sink	In kitchen third clock wise from entry door	12/18/2018	FT-FY19-122018-009919-A	<1	FT-FY19-122018-009919-B	<1