



Hearst Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004742	2/27/2022	2/27/2023	1	Health Suite	In health suite	WF-02272022-004742	12/30/2022	FT-FY23-11182022-004742-A	1.9	FT-FY23-11182022-004742-B	2.3	
WS- 004743	2/27/2022	2/27/2023	1	Combo Fountain	In health suite	WF-02272022-004743	12/30/2022	FT-FY23-11182022-004743-A	1.0	FT-FY23-11182022-004743-B	2.7	
WS- 004744	2/27/2022	2/27/2023	1	Health Suite	In health suite in exam room 2	WF-02272022-004744	12/30/2022	FT-FY23-11182022-004744-A	1.6	FT-FY23-11182022-004744-B	<1	
WS- 004745	2/27/2022	2/27/2023	1	Combo Fountain	In exam room 2 in health suite	WF-02272022-004745	12/30/2022	FT-FY23-11182022-004745-A	2.8	FT-FY23-11182022-004745-B	4.0	
WS- 004746	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 122	WF-08222022-004746	12/30/2022	FT-FY23-11182022-004746-A	3.6	FT-FY23-11182022-004746-B	1.5	
WS- 004747	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 122	WF-02272022-004747	12/30/2022	FT-FY23-11182022-004747-A	1.4	FT-FY23-11182022-004747-B	3.0	
WS- 004748	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 110	WF-08222022-004748	12/30/2022	FT-FY23-11182022-004748-A	<1	FT-FY23-11182022-004748-B	2.8	
WS- 004749	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 110	WF-02272022-004749	12/30/2022	FT-FY23-11182022-004749-A	3.8	FT-FY23-11182022-004749-B	1.0	
WS- 004750	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 114	WF-08222022-004750	12/30/2022	FT-FY23-11182022-004750-A	1.5	FT-FY23-11182022-004750-B	<1	
WS- 004751	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 114	WF-02272022-004751	12/30/2022	FT-FY23-11182022-004751-A	2.4	FT-FY23-11182022-004751-B	1.3	
WS- 004752	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 118	WF-08222022-004752	12/30/2022	FT-FY23-11182022-004752-A	<1	FT-FY23-11182022-004752-B	3.6	
WS- 004753	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 118	WF-02272022-004753	12/30/2022	FT-FY23-11182022-004753-A	<1	FT-FY23-11182022-004753-B	<1	
WS- 004754	8/22/2022	8/22/2023	1	Classroom Faucet	In art room 173	Left	WF-08222022-004754	12/30/2022	FT-FY23-11182022-004754-A	2.8	FT-FY23-11182022-004754-B	1.4
WS- 004755	8/22/2022	8/22/2023	1	Classroom Faucet	In art room 173	Right	WF-08222022-004755	12/30/2022	FT-FY23-11182022-004755-A	2.6	FT-FY23-11182022-004755-B	1.5
WS- 004756	8/22/2022	8/22/2023	1	Classroom Faucet	In parent resource room 169		WF-08222022-004756	12/30/2022	FT-FY23-11182022-004756-A	<1	FT-FY23-11182022-004756-B	<1
WS- 004759	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 167	Left	WF-08222022-004759	12/30/2022	FT-FY23-11182022-004759-A	1.5	FT-FY23-11182022-004759-B	4.3
WS- 004760	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 167	Right	WF-02272022-004760	12/30/2022	FT-FY23-11182022-004760-A	1.8	FT-FY23-11182022-004760-B	3.4
WS- 004761	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 166		WF-08222022-004761	12/30/2022	FT-FY23-11182022-004761-A	<1	FT-FY23-11182022-004761-B	4.3
WS- 004762	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 166		WF-02272022-004762	12/30/2022	FT-FY23-11182022-004762-A	1.4	FT-FY23-11182022-004762-B	2.9
WS- 004763	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 165		WF-08222022-004763	12/30/2022	FT-FY23-11182022-004763-A	<1	FT-FY23-11182022-004763-B	3.5
WS- 004764	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 165		WF-02272022-004764	12/30/2022	FT-FY23-11182022-004764-A	1.5	FT-FY23-11182022-004764-B	<1
WS- 004765	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 164	Left	WF-08222022-004765	12/30/2022	FT-FY23-11182022-004765-A	<1	FT-FY23-11182022-004765-B	<1
WS- 004766	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 164	Right	WF-02272022-004766	12/30/2022	FT-FY23-11182022-004766-A	1.4	FT-FY23-11182022-004766-B	<1
WS- 004767	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 161		WF-08222022-004767	12/30/2022	FT-FY23-11182022-004767-A	1.0	FT-FY23-11182022-004767-B	<1
WS- 004768	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 161		WF-02272022-004768	12/30/2022	FT-FY23-11182022-004768-A	<1	FT-FY23-11182022-004768-B	2.0
WS- 004769	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 160	Left	WF-08222022-004769	12/30/2022	FT-FY23-11182022-004769-A	1.7	FT-FY23-11182022-004769-B	<1
WS- 004770	2/27/2022	2/27/2023	1	Combo Fountain	In classroom 160	Right	WF-02272022-004770	12/30/2022	FT-FY23-11182022-004770-A	<1	FT-FY23-11182022-004770-B	4.2
WS- 004776	2/27/2022	2/27/2023	Basement	Ice Maker	In kitchen (ice maker)		WF-02272022-004776	12/30/2022	FT-FY23-11182022-004776-A	4.1	FT-FY23-11182022-004776-B	<1
WS- 004777	2/27/2022	2/27/2023	Basement	Cooler	In gym	Low Right	WF-02272022-004777	12/30/2022	FT-FY23-11182022-004777-A	1.5	FT-FY23-11182022-004777-B	<1
WS- 004778	2/27/2022	2/27/2023	Basement	Cooler	In gym	High Left	WF-02272022-004778	12/30/2022	FT-FY23-11182022-004778-A	<1	FT-FY23-11182022-004778-B	1.6
WS- 004779	2/27/2022	2/27/2023	2	Break Room	In teacher work room 221		WF-02272022-004779	12/30/2022	FT-FY23-11182022-004779-A	2.1	FT-FY23-11182022-004779-B	<1
WS- 004781	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 219	Right	WF-08222022-004781	12/30/2022	FT-FY23-11182022-004781-A	1.7	FT-FY23-11182022-004781-B	<1
WS- 004783	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 210		WF-08222022-004783	12/30/2022	FT-FY23-11182022-004783-A	<1	FT-FY23-11182022-004783-B	<1
WS- 004784	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 210		WF-02272022-004784	12/30/2022	FT-FY23-11182022-004784-A	<1	FT-FY23-11182022-004784-B	<1
WS- 004785	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 214	Right	WF-08222022-004785	12/30/2022	FT-FY23-11182022-004785-A	2.0	FT-FY23-11182022-004785-B	<1

WS-004787	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 218		WF-08222022-004787	12/30/2022	FT-FY23-11182022-004787-A	1.1	FT-FY23-11182022-004787-B	<1
WS-004788	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 218		WF-02272022-004788	12/30/2022	FT-FY23-11182022-004788-A	<1	FT-FY23-11182022-004788-B	4.0
WS-004789	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 260		WF-08222022-004789	12/30/2022	FT-FY23-11182022-004789-A	<1	FT-FY23-11182022-004789-B	<1
WS-004790	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 260		WF-02272022-004790	12/30/2022	FT-FY23-11182022-004790-A	<1	FT-FY23-11182022-004790-B	1.8
WS-004791	2/27/2022	2/27/2023	2	Cooler	In entrance to boy/girl restroom near room 220	High Left	WF-02272022-004791	12/30/2022	FT-FY23-11182022-004791-A	3.0	FT-FY23-11182022-004791-B	<1
WS-004792	2/27/2022	2/27/2023	2	Cooler	In entrance to boy/girl restroom near room 220	Low Right	WF-02272022-004792	12/30/2022	FT-FY23-11182022-004792-A	4.2	FT-FY23-11182022-004792-B	<1
WS-004793	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 261		WF-08222022-004793	12/30/2022	FT-FY23-11182022-004793-A	2.9	FT-FY23-11182022-004793-B	<1
WS-004794	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 261		WF-02272022-004794	12/30/2022	FT-FY23-11182022-004794-A	<1	FT-FY23-11182022-004794-B	<1
WS-004795	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 264		WF-08222022-004795	12/30/2022	FT-FY23-11182022-004795-A	<1	FT-FY23-11182022-004795-B	4.4
WS-004796	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 264		WF-02272022-004796	12/30/2022	FT-FY23-11182022-004796-A	<1	FT-FY23-11182022-004796-B	1.8
WS-004797	8/22/2022	8/22/2023	2	Combo Faucet	In classroom 265	Left	WF-08222022-004797	12/30/2022	FT-FY23-11182022-004797-A	<1	FT-FY23-11182022-004797-B	<1
WS-004798	2/27/2022	2/27/2023	2	Combo Fountain	In classroom 265	Right	WF-02272022-004798	12/30/2022	FT-FY23-11182022-004798-A	<1	FT-FY23-11182022-004798-B	<1
WS-004799	2/27/2022	2/27/2023	2	Break Room	In teacher work room 285		WF-02272022-004799	12/30/2022	FT-FY23-11182022-004799-A	<1	FT-FY23-11182022-004799-B	1.2
WS-004800	2/27/2022	2/27/2023	1	Cooler	In entrance to boy/girl restroom near main lobby	High Left	WF-02272022-004800	12/30/2022	FT-FY23-11182022-004800-A	<1	FT-FY23-11182022-004800-B	<1
WS-004801	2/27/2022	2/27/2023	1	Cooler	In entrance to boy/girl restroom near main lobby	Low Right	WF-02272022-004801	12/30/2022	FT-FY23-11182022-004801-A	<1	FT-FY23-11182022-004801-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004772	1/12/2022	1/12/2023	Basement	Food Prep Sink	In kitchen on east wall	Left	WF-01122022-004772	12/30/2022	FT-FY23-11182022-004772-A	4.7	FT-FY23-11182022-004772-B	1.4
WS-004773	1/12/2022	1/12/2023	Basement	Food Prep Sink	In kitchen on east wall	Right	WF-01122022-004773	12/30/2022	FT-FY23-11182022-004773-A	2.2	FT-FY23-11182022-004773-B	1.3
WS-004774	1/12/2022	1/12/2023	Basement	Food Prep Sink	In kitchen on island	Left	WF-01122022-004774	12/30/2022	FT-FY23-11182022-004774-A	1.7	FT-FY23-11182022-004774-B	2.1
WS-004775	1/12/2022	1/12/2023	Basement	Food Prep Sink	In kitchen on island	Right	WF-01122022-004775	12/30/2022	FT-FY23-11182022-004775-A	3.6	FT-FY23-11182022-004775-B	2.8