



# Hearst Elementary School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004742	3/8/2021	3/8/2022	1	Health Suite	In health suite	WF-03082021-004742	3/28/2021	FT-FY21-032021-004742-A	<1	FT-FY21-032021-004742-B	<1	
WS- 004743	3/8/2021	3/8/2022	1	Combo Fountain	In health suite	WF-03082021-004743	3/28/2021	FT-FY21-032021-004743-A	<1	FT-FY21-032021-004743-B	<1	
WS- 004744	3/8/2021	3/8/2022	1	Health Suite	In health suite in exam room 2	WF-03082021-004744	3/28/2021	FT-FY21-032021-004744-A	<1	FT-FY21-032021-004744-B	<1	
WS- 004745	3/8/2021	3/8/2022	1	Combo Fountain	In exam room 2 in health suite	WF-03082021-004745	3/28/2021	FT-FY21-032021-004745-A	<1	FT-FY21-032021-004745-B	<1	
WS- 004746	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 122	WF-09082020-004746	3/28/2021	FT-FY21-032021-004746-A	<1	FT-FY21-032021-004746-B	<1	
WS- 004747	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 122	WF-03082021-004747	3/28/2021	FT-FY21-032021-004747-A	<1	FT-FY21-032021-004747-B	<1	
WS- 004748	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 110	WF-09082020-004748	3/28/2021	FT-FY21-032021-004748-A	<1	FT-FY21-032021-004748-B	<1	
WS- 004749	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 110	WF-03082021-004749	3/28/2021	FT-FY21-032021-004749-A	<1	FT-FY21-032021-004749-B	<1	
WS- 004750	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 114	WF-09082020-004750	3/28/2021	FT-FY21-032021-004750-A	<1	FT-FY21-032021-004750-B	<1	
WS- 004751	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 114	WF-03082021-004751	3/28/2021	FT-FY21-032021-004751-A	<1	FT-FY21-032021-004751-B	<1	
WS- 004752	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 118	WF-09082020-004752	3/28/2021	FT-FY21-032021-004752-A	<1	FT-FY21-032021-004752-B	<1	
WS- 004753	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 118	WF-03082021-004753	3/28/2021	FT-FY21-032021-004753-A	<1	FT-FY21-032021-004753-B	<1	
WS- 004754	9/8/2020	9/8/2021	1	Classroom Faucet	In art room 173	Left	WF-09082020-004754	3/28/2021	FT-FY21-032021-004754-A	<1	FT-FY21-032021-004754-B	<1
WS- 004755	9/8/2020	9/8/2021	1	Classroom Faucet	In art room 173	Right	WF-09082020-004755	3/28/2021	FT-FY21-032021-004755-A	<1	FT-FY21-032021-004755-B	<1
WS- 004756	9/8/2020	9/8/2021	1	Classroom Faucet	In parent resource room 169		WF-09082020-004756	3/28/2021	FT-FY21-032021-004756-A	<1	FT-FY21-032021-004756-B	<1
WS- 004759	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 167	Left	WF-09082020-004759	3/28/2021	FT-FY21-032021-004759-A	3.7	FT-FY21-032021-004759-B	<1
WS- 004760	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 167	Right	WF-03082021-004760	3/28/2021	FT-FY21-032021-004760-A	<1	FT-FY21-032021-004760-B	<1
WS- 004761	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 166		WF-09082020-004761	3/28/2021	FT-FY21-032021-004761-A	1.1	FT-FY21-032021-004761-B	<1
WS- 004762	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 166		WF-03082021-004762	3/28/2021	FT-FY21-032021-004762-A	<1	FT-FY21-032021-004762-B	<1
WS- 004763	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 165		WF-09082020-004763	3/28/2021	FT-FY21-032021-004763-A	<1	FT-FY21-032021-004763-B	<1
WS- 004764	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 165		WF-03082021-004764	3/28/2021	FT-FY21-032021-004764-A	<1	FT-FY21-032021-004764-B	<1
WS- 004765	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 164	Left	WF-09082020-004765	3/28/2021	FT-FY21-032021-004765-A	2.6	FT-FY21-032021-004765-B	<1
WS- 004766	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 164	Right	WF-03082021-004766	3/28/2021	FT-FY21-032021-004766-A	<1	FT-FY21-032021-004766-B	<1
WS- 004767	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 161		WF-09082020-004767	3/28/2021	FT-FY21-032021-004767-A	<1	FT-FY21-032021-004767-B	<1
WS- 004768	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 161		WF-03082021-004768	3/28/2021	FT-FY21-032021-004768-A	<1	FT-FY21-032021-004768-B	<1
WS- 004769	9/8/2020	9/8/2021	1	Combo Faucet	In classroom 160	Left	WF-09082020-004769	3/28/2021	FT-FY21-032021-004769-A	1.0	FT-FY21-032021-004769-B	<1
WS- 004770	3/8/2021	3/8/2022	1	Combo Fountain	In classroom 160	Right	WF-03082021-004770	3/28/2021	FT-FY21-032021-004770-A	<1	FT-FY21-032021-004770-B	<1
WS- 004779	3/8/2021	3/8/2022	2	Break Room	In teacher work room 221		WF-03082021-004779	3/28/2021	FT-FY21-032021-004779-A	<1	FT-FY21-032021-004779-B	<1
WS- 004781	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 219	Right	WF-09082020-004781	3/28/2021	FT-FY21-032021-004781-A	<1	FT-FY21-032021-004781-B	<1
WS- 004782	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 219	Left	WF-03082021-004782	3/28/2021	FT-FY21-032021-004782-A	<1	FT-FY21-032021-004782-B	<1
WS- 004783	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 210		WF-09082020-004783	3/28/2021	FT-FY21-032021-004783-A	<1	FT-FY21-032021-004783-B	<1
WS- 004784	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 210		WF-03082021-004784	3/28/2021	FT-FY21-032021-004784-A	<1	FT-FY21-032021-004784-B	<1
WS- 004785	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 214	Right	WF-09082020-004785	3/28/2021	FT-FY21-032021-004785-A	<1	FT-FY21-032021-004785-B	<1
WS- 004786	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 214	Left	WF-03082021-004786	3/28/2021	FT-FY21-032021-004786-A	<1	FT-FY21-032021-004786-B	<1
WS- 004787	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 218		WF-09082020-004787	3/28/2021	FT-FY21-032021-004787-A	<1	FT-FY21-032021-004787-B	<1

WS-004788	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 218			WF-03082021-004788	3/28/2021	FT-FY21-032021-004788-A	<1	FT-FY21-032021-004788-B	<1
WS-004789	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 260			WF-09082020-004789	3/28/2021	FT-FY21-032021-004789-A	<1	FT-FY21-032021-004789-B	<1
WS-004790	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 260			WF-03082021-004790	3/28/2021	FT-FY21-032021-004790-A	<1	FT-FY21-032021-004790-B	<1
WS-004791	3/8/2021	3/8/2022	2	Cooler	In entrance to boy/girl restroom near room 220	High	Left	WF-03082021-004791	3/28/2021	FT-FY21-032021-004791-A	<1	FT-FY21-032021-004791-B	<1
WS-004792	3/8/2021	3/8/2022	2	Cooler	In entrance to boy/girl restroom near room 220	Low	Right	WF-03082021-004792	3/28/2021	FT-FY21-032021-004792-A	<1	FT-FY21-032021-004792-B	<1
WS-004793	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 261			WF-09082020-004793	3/28/2021	FT-FY21-032021-004793-A	<1	FT-FY21-032021-004793-B	<1
WS-004794	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 261			WF-03082021-004794	3/28/2021	FT-FY21-032021-004794-A	<1	FT-FY21-032021-004794-B	<1
WS-004795	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 264			WF-09082020-004795	3/28/2021	FT-FY21-032021-004795-A	<1	FT-FY21-032021-004795-B	<1
WS-004796	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 264			WF-03082021-004796	3/28/2021	FT-FY21-032021-004796-A	<1	FT-FY21-032021-004796-B	<1
WS-004797	9/8/2020	9/8/2021	2	Combo Faucet	In classroom 265		Left	WF-09082020-004797	3/28/2021	FT-FY21-032021-004797-A	<1	FT-FY21-032021-004797-B	<1
WS-004798	3/8/2021	3/8/2022	2	Combo Fountain	In classroom 265		Right	WF-03082021-004798	3/28/2021	FT-FY21-032021-004798-A	<1	FT-FY21-032021-004798-B	<1
WS-004799	3/8/2021	3/8/2022	2	Break Room	In teacher work room 285			WF-03082021-004799	3/28/2021	FT-FY21-032021-004799-A	<1	FT-FY21-032021-004799-B	<1
WS-004800	3/8/2021	3/8/2022	1	Cooler	In entrance to boy/girl restroom near main lobby	High	Left	WF-03082021-004800	3/28/2021	FT-FY21-032021-004800-A	<1	FT-FY21-032021-004800-B	<1
WS-004801	3/8/2021	3/8/2022	1	Cooler	In entrance to boy/girl restroom near main lobby	Low	Right	WF-03082021-004801	3/28/2021	FT-FY21-032021-004801-A	<1	FT-FY21-032021-004801-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004772	1/22/2021	1/22/2022	Basement	Food Prep Sink	In kitchen on east wall	Left	WF-01222021-004772	3/28/2021	FT-FY21-032021-004772-A	<1	FT-FY21-032021-004772-B	<1
WS-004773	1/22/2021	1/22/2022	Basement	Food Prep Sink	In kitchen on east wall	Right	WF-01222021-004773	3/28/2021	FT-FY21-032021-004773-A	<1	FT-FY21-032021-004773-B	<1
WS-004774	1/22/2021	1/22/2022	Basement	Food Prep Sink	In kitchen on island	Left	WF-01222021-004774	3/28/2021	FT-FY21-032021-004774-A	<1	FT-FY21-032021-004774-B	<1
WS-004775	1/21/2021	1/21/2022	Basement	Food Prep Sink	In kitchen on island	Right	WF-01212021-004775	3/28/2021	FT-FY21-032021-004775-A	<1	FT-FY21-032021-004775-B	<1