



# Hearst Elementary School Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004742	2/21/2024	2/21/2025	1	Health Suite	In health suite	WF-02212024-004742	11/1/2024	FT-FY25-10082024-004742-A	<2	FT-FY25-10082024-004742-B	<2	
WS-004743	2/21/2024	2/21/2025	1	Combo Fountain	In health suite	WF-02212024-004743	11/1/2024	FT-FY25-10082024-004743-A	<2	FT-FY25-10082024-004743-B	<2	
WS-004744	2/21/2024	2/21/2025	1	Health Suite	In health suite in exam room 2	WF-02212024-004744	11/1/2024	FT-FY25-10082024-004744-A	<2	FT-FY25-10082024-004744-B	<2	
WS-004745	2/21/2024	2/21/2025	1	Combo Fountain	In exam room 2 in health suite	WF-02212024-004745	11/1/2024	FT-FY25-10082024-004745-A	<2	FT-FY25-10082024-004745-B	<2	
WS-004746	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 122	WF-08132024-004746	11/1/2024	FT-FY25-10082024-004746-A	<2	FT-FY25-10082024-004746-B	<2	
WS-004747	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 122	WF-02212024-004747	11/1/2024	FT-FY25-10082024-004747-A	<2	FT-FY25-10082024-004747-B	<2	
WS-004748	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 110	WF-08132024-004748	11/1/2024	FT-FY25-10082024-004748-A	<2	FT-FY25-10082024-004748-B	<2	
WS-004749	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 110	WF-02212024-004749	11/1/2024	FT-FY25-10082024-004749-A	<2	FT-FY25-10082024-004749-B	<2	
WS-004750	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 114	WF-08132024-004750	11/1/2024	FT-FY25-10082024-004750-A	<2	FT-FY25-10082024-004750-B	<2	
WS-004751	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 114	WF-02212024-004751	11/1/2024	FT-FY25-10082024-004751-A	<2	FT-FY25-10082024-004751-B	<2	
WS-004752	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 118	WF-08132024-004752	11/1/2024	FT-FY25-10082024-004752-A	<2	FT-FY25-10082024-004752-B	<2	
WS-004753	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 118	WF-02212024-004753	11/1/2024	FT-FY25-10082024-004753-A	<2	FT-FY25-10082024-004753-B	<2	
WS-004754	8/13/2024	8/13/2025	1	Classroom Faucet	In art room 173	Left	WF-08132024-004754	11/1/2024	FT-FY25-10082024-004754-A	<2	FT-FY25-10082024-004754-B	<2
WS-004755	8/13/2024	8/13/2025	1	Classroom Faucet	In art room 173	Right	WF-08132024-004755	11/1/2024	FT-FY25-10082024-004755-A	<2	FT-FY25-10082024-004755-B	<2
WS-004756	8/13/2024	8/13/2025	1	Classroom Faucet	In parent resource room 169		WF-08132024-004756	11/1/2024	FT-FY25-10082024-004756-A	<2	FT-FY25-10082024-004756-B	<2
WS-004759	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 167	Left	WF-08132024-004759	11/1/2024	FT-FY25-10082024-004759-A	<2	FT-FY25-10082024-004759-B	<2
WS-004760	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 167	Right	WF-02212024-004760	11/1/2024	FT-FY25-10082024-004760-A	<2	FT-FY25-10082024-004760-B	<2
WS-004761	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 166		WF-08132024-004761	11/1/2024	FT-FY25-10082024-004761-A	<2	FT-FY25-10082024-004761-B	<2
WS-004762	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 166		WF-02212024-004762	11/1/2024	FT-FY25-10082024-004762-A	<2	FT-FY25-10082024-004762-B	<2
WS-004763	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 165		WF-08132024-004763	11/1/2024	FT-FY25-10082024-004763-A	<2	FT-FY25-10082024-004763-B	<2
WS-004764	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 165		WF-02212024-004764	11/1/2024	FT-FY25-10082024-004764-A	<2	FT-FY25-10082024-004764-B	<2
WS-004765	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 164	Left	WF-08132024-004765	11/1/2024	FT-FY25-10082024-004765-A	<2	FT-FY25-10082024-004765-B	<2
WS-004766	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 164	Right	WF-02212024-004766	11/1/2024	FT-FY25-10082024-004766-A	<2	FT-FY25-10082024-004766-B	<2
WS-004767	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 161		WF-08132024-004767	11/1/2024	FT-FY25-10082024-004767-A	<2	FT-FY25-10082024-004767-B	<2
WS-004768	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 161		WF-02212024-004768	11/1/2024	FT-FY25-10082024-004768-A	<2	FT-FY25-10082024-004768-B	<2
WS-004769	8/13/2024	8/13/2025	1	Combo Faucet	In classroom 160	Left	WF-08132024-004769	11/1/2024	FT-FY25-10082024-004769-A	<2	FT-FY25-10082024-004769-B	<2
WS-004770	2/21/2024	2/21/2025	1	Combo Fountain	In classroom 160	Right	WF-02212024-004770	11/1/2024	FT-FY25-10082024-004770-A	<2	FT-FY25-10082024-004770-B	<2
WS-004776	2/21/2024	2/21/2025	Basement	Ice Maker	In kitchen (ice maker)		WF-02212024-004776	11/1/2024	FT-FY25-10082024-004776-A	<2	FT-FY25-10082024-004776-B	<2
WS-004777	2/21/2024	2/21/2025	Basement	Cooler	In gym	Low Right	WF-02212024-004777	11/1/2024	FT-FY25-10082024-004777-A	<2	FT-FY25-10082024-004777-B	<2
WS-004778	2/21/2024	2/21/2025	Basement	Cooler	In gym	High Left	WF-02212024-004778	11/1/2024	FT-FY25-10082024-004778-A	<2	FT-FY25-10082024-004778-B	<2
WS-004779	2/21/2024	2/21/2025	2	Break Room	In teacher work room 221		WF-02212024-004779	11/1/2024	FT-FY25-10082024-004779-A	<2	FT-FY25-10082024-004779-B	<2
WS-004781	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 219	Right	WF-08132024-004781	11/1/2024	FT-FY25-10082024-004781-A	<2	FT-FY25-10082024-004781-B	<2
WS-004782	2/21/2024	2/21/2025	2	Combo Fountain	In classroom 219	Left	WF-02212024-004782	11/1/2024	FT-FY25-10082024-004782-A	<2	FT-FY25-10082024-004782-B	<2

WS- 004783	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 210		WF-08132024-004783	11/1/2024	FT-FY25-10082024-004783-A	<2	FT-FY25-10082024-004783-B	<2
WS- 004784	2/21/2024	2/21/2025	2	Combo Fountain	In classroom 210		WF-02212024-004784	11/1/2024	FT-FY25-10082024-004784-A	<2	FT-FY25-10082024-004784-B	<2
WS- 004785	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 214	Right	WF-08132024-004785	11/1/2024	FT-FY25-10082024-004785-A	<2	FT-FY25-10082024-004785-B	<2
WS- 004786	2/21/2024	2/21/2025	2	Combo Fountain	In classroom 214	Left	WF-02212024-004786	11/1/2024	FT-FY25-10082024-004786-A	<2	FT-FY25-10082024-004786-B	<2
WS- 004787	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 218		WF-08132024-004787	11/1/2024	FT-FY25-10082024-004787-A	<2	FT-FY25-10082024-004787-B	<2
WS- 004788	2/21/2024	2/21/2025	2	Combo Fountain	In classroom 218		WF-02212024-004788	11/1/2024	FT-FY25-10082024-004788-A	<2	FT-FY25-10082024-004788-B	<2
WS- 004789	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 260		WF-08132024-004789	11/1/2024	FT-FY25-10082024-004789-A	<2	FT-FY25-10082024-004789-B	<2
WS- 004790	2/21/2024	2/21/2025	2	Combo Fountain	In classroom 260		WF-02212024-004790	11/1/2024	FT-FY25-10082024-004790-A	<2	FT-FY25-10082024-004790-B	<2
WS- 004791	2/21/2024	2/21/2025	2	Cooler	In entrance to boy/girl restroom near room 220	High Left	WF-02212024-004791	11/1/2024	FT-FY25-10082024-004791-A	<2	FT-FY25-10082024-004791-B	<2
WS- 004792	2/21/2024	2/21/2025	2	Cooler	In entrance to boy/girl restroom near room 220	Low Right	WF-02212024-004792	11/1/2024	FT-FY25-10082024-004792-A	<2	FT-FY25-10082024-004792-B	<2
WS- 004793	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 261		WF-08132024-004793	11/1/2024	FT-FY25-10082024-004793-A	<2	FT-FY25-10082024-004793-B	<2
WS- 004794	2/21/2024	2/21/2025	2	Combo Fountain	In classroom 261		WF-02212024-004794	11/1/2024	FT-FY25-10082024-004794-A	<2	FT-FY25-10082024-004794-B	<2
WS- 004795	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 264		WF-08132024-004795	11/1/2024	FT-FY25-10082024-004795-A	<2	FT-FY25-10082024-004795-B	<2
WS- 004796	2/21/2024	2/21/2025	2	Combo Fountain	In classroom 264		WF-02212024-004796	11/1/2024	FT-FY25-10082024-004796-A	<2	FT-FY25-10082024-004796-B	<2
WS- 004797	8/13/2024	8/13/2025	2	Combo Faucet	In classroom 265	Left	WF-08132024-004797	11/1/2024	FT-FY25-10082024-004797-A	<2	FT-FY25-10082024-004797-B	<2
WS- 004798	2/21/2024	2/21/2025	2	Combo Fountain	In classroom 265	Right	WF-02212024-004798	11/1/2024	FT-FY25-10082024-004798-A	<2	FT-FY25-10082024-004798-B	<2
WS- 004799	2/21/2024	2/21/2025	2	Break Room	In teacher work room 285		WF-02212024-004799	11/1/2024	FT-FY25-10082024-004799-A	<2	FT-FY25-10082024-004799-B	<2
WS- 004800	2/21/2024	2/21/2025	1	Cooler	In entrance to boy/girl restroom near main lobby	High Left	WF-02212024-004800	11/1/2024	FT-FY25-10082024-004800-A	<2	FT-FY25-10082024-004800-B	<2
WS- 004801	2/21/2024	2/21/2025	1	Cooler	In entrance to boy/girl restroom near main lobby	Low Right	WF-02212024-004801	11/1/2024	FT-FY25-10082024-004801-A	<2	FT-FY25-10082024-004801-B	<2

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004772	11/20/2023	11/20/2024	Basement	Food Prep Sink	In kitchen on east wall	Left	WF-11202023-004772	11/1/2024	FT-FY25-10082024-004772-A	<2	FT-FY25-10082024-004772-B	<2
WS- 004773	11/20/2023	11/20/2024	Basement	Food Prep Sink	In kitchen on east wall	Right	WF-11202023-004773	11/1/2024	FT-FY25-10082024-004773-A	<2	FT-FY25-10082024-004773-B	<2
WS- 004774	11/20/2023	11/20/2024	Basement	Food Prep Sink	In kitchen on island	Left	WF-11202023-004774	11/1/2024	FT-FY25-10082024-004774-A	<2	FT-FY25-10082024-004774-B	<2
WS- 004775	11/20/2023	11/20/2024	Basement	Food Prep Sink	In kitchen on island	Right	WF-11202023-004775	11/1/2024	FT-FY25-10082024-004775-A	<2	FT-FY25-10082024-004775-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.