



# Hearst ES Lead Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004742	3/25/2019	3/25/2020	1	Health Suite	In health suite	WF-03252019-004742	10/27/2019	FT-FY20-102019-004742-A	<1	FT-FY20-102019-004742-B	<1
WS- 004743	3/25/2019	3/25/2020	1	Combo Fountain	In health suite	WF-03252019-004743	10/27/2019	FT-FY20-102019-004743-A	<1	FT-FY20-102019-004743-B	<1
WS- 004744	3/25/2019	3/25/2020	1	Health Suite	In health suite in exam room 2	WF-03252019-004744	10/27/2019	FT-FY20-102019-004744-A	<1	FT-FY20-102019-004744-B	<1
WS- 004745	3/25/2019	3/25/2020	1	Combo Fountain	In exam room 2 in health suite	WF-03252019-004745	10/27/2019	FT-FY20-102019-004745-A	<1	FT-FY20-102019-004745-B	<1
WS- 004748	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 110	WF-09162019-004748	10/27/2019	FT-FY20-102019-004748-A	1.1	FT-FY20-102019-004748-B	<1
WS- 004749	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 110	WF-03252019-004749	10/27/2019	FT-FY20-102019-004749-A	<1	FT-FY20-102019-004749-B	<1
WS- 004750	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 114	WF-09162019-004750	10/27/2019	FT-FY20-102019-004750-A	<1	FT-FY20-102019-004750-B	<1
WS- 004751	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 114	WF-03252019-004751	10/27/2019	FT-FY20-102019-004751-A	<1	FT-FY20-102019-004751-B	<1
WS- 004752	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 118	WF-09162019-004752	10/27/2019	FT-FY20-102019-004752-A	<1	FT-FY20-102019-004752-B	<1
WS- 004753	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 118	WF-03252019-004753	10/27/2019	FT-FY20-102019-004753-A	<1	FT-FY20-102019-004753-B	<1
WS- 004754	9/16/2019	9/16/2020	1	Classroom Faucet	In art room 173	Left WF-09162019-004754	10/27/2019	FT-FY20-102019-004754-A	<1	FT-FY20-102019-004754-B	<1
WS- 004755	9/16/2019	9/16/2020	1	Classroom Faucet	In art room 173	Right WF-09162019-004755	10/27/2019	FT-FY20-102019-004755-A	<1	FT-FY20-102019-004755-B	<1
WS- 004756	9/16/2019	9/16/2020	1	Classroom Faucet	In parent resource room 169	WF-09162019-004756	10/27/2019	FT-FY20-102019-004756-A	1.1	FT-FY20-102019-004756-B	<1
WS- 004757	3/25/2019	3/25/2020	1	Cooler	In hallway adjacent room 170	High Left WF-03252019-004757	10/27/2019	FT-FY20-102019-004757-A	<1	FT-FY20-102019-004757-B	<1
WS- 004758	3/25/2019	3/25/2020	1	Cooler	In hallway adjacent room 170	Low Right WF-03252019-004758	10/27/2019	FT-FY20-102019-004758-A	<1	FT-FY20-102019-004758-B	<1
WS- 004761	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 166	WF-09162019-004761	10/27/2019	FT-FY20-102019-004761-A	2.1	FT-FY20-102019-004761-B	<1
WS- 004762	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 166	WF-03252019-004762	10/27/2019	FT-FY20-102019-004762-A	<1	FT-FY20-102019-004762-B	<1
WS- 004763	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 165	WF-09162019-004763	10/27/2019	FT-FY20-102019-004763-A	1.6	FT-FY20-102019-004763-B	<1
WS- 004764	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 165	WF-03252019-004764	10/27/2019	FT-FY20-102019-004764-A	<1	FT-FY20-102019-004764-B	<1
WS- 004765	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 164	Left WF-09162019-004765	10/27/2019	FT-FY20-102019-004765-A	2.1	FT-FY20-102019-004765-B	<1
WS- 004766	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 164	Right WF-03252019-004766	10/27/2019	FT-FY20-102019-004766-A	<1	FT-FY20-102019-004766-B	<1
WS- 004767	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 161	WF-09162019-004767	10/27/2019	FT-FY20-102019-004767-A	<1	FT-FY20-102019-004767-B	<1
WS- 004768	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 161	WF-03252019-004768	10/27/2019	FT-FY20-102019-004768-A	1.3	FT-FY20-102019-004768-B	<1
WS- 004769	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 160	Left WF-09162019-004769	10/27/2019	FT-FY20-102019-004769-A	<1	FT-FY20-102019-004769-B	<1
WS- 004770	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 160	Right WF-03252019-004770	10/27/2019	FT-FY20-102019-004770-A	<1	FT-FY20-102019-004770-B	<1
WS- 004776	3/25/2019	3/25/2020	Basement	Ice Maker	In kitchen (ice maker)	WF-03252019-004776	10/27/2019	FT-FY20-102019-004776-A	<1	FT-FY20-102019-004776-B	<1
WS- 004778	3/25/2019	3/25/2020	Basement	Cooler	In gym	High Left WF-03252019-004778	10/27/2019	FT-FY20-102019-004778-A	<1	FT-FY20-102019-004778-B	<1
WS- 004779	3/25/2019	3/25/2020	2	Break Room	In teacher work room 221	WF-03252019-004779	10/27/2019	FT-FY20-102019-004779-A	<1	FT-FY20-102019-004779-B	<1
WS- 004781	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 219	Right WF-09162019-004781	10/27/2019	FT-FY20-102019-004781-A	<1	FT-FY20-102019-004781-B	<1
WS- 004782	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 219	Left WF-03252019-004782	10/27/2019	FT-FY20-102019-004782-A	<1	FT-FY20-102019-004782-B	<1
WS- 004783	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 210	WF-09162019-004783	10/27/2019	FT-FY20-102019-004783-A	<1	FT-FY20-102019-004783-B	<1
WS- 004784	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 210	WF-03252019-004784	10/27/2019	FT-FY20-102019-004784-A	<1	FT-FY20-102019-004784-B	<1
WS- 004785	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 214	Right WF-09162019-004785	10/27/2019	FT-FY20-102019-004785-A	<1	FT-FY20-102019-004785-B	<1
WS- 004786	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 214	Left WF-03252019-004786	10/27/2019	FT-FY20-102019-004786-A	<1	FT-FY20-102019-004786-B	<1
WS- 004787	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 218	WF-09162019-004787	10/27/2019	FT-FY20-102019-004787-A	<1	FT-FY20-102019-004787-B	<1

WS- 004788	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 218		WF-03252019-004788	10/27/2019	FT-FY20-102019-004788-A	<1	FT-FY20-102019-004788-B	<1
WS- 004789	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 260		WF-09162019-004789	10/27/2019	FT-FY20-102019-004789-A	<1	FT-FY20-102019-004789-B	<1
WS- 004790	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 260		WF-03252019-004790	10/27/2019	FT-FY20-102019-004790-A	<1	FT-FY20-102019-004790-B	<1
WS- 004791	3/25/2019	3/25/2020	2	Cooler	In entrance to boy/girl restroom near room 220	High Left	WF-03252019-004791	10/27/2019	FT-FY20-102019-004791-A	<1	FT-FY20-102019-004791-B	<1
WS- 004792	3/25/2019	3/25/2020	2	Cooler	In entrance to boy/girl restroom near room 220	Low Right	WF-03252019-004792	10/27/2019	FT-FY20-102019-004792-A	<1	FT-FY20-102019-004792-B	<1
WS- 004793	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 261		WF-09162019-004793	10/27/2019	FT-FY20-102019-004793-A	<1	FT-FY20-102019-004793-B	<1
WS- 004794	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 261		WF-03252019-004794	10/27/2019	FT-FY20-102019-004794-A	<1	FT-FY20-102019-004794-B	<1
WS- 004795	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 264		WF-09162019-004795	10/27/2019	FT-FY20-102019-004795-A	<1	FT-FY20-102019-004795-B	<1
WS- 004796	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 264		WF-03252019-004796	10/27/2019	FT-FY20-102019-004796-A	<1	FT-FY20-102019-004796-B	<1
WS- 004797	9/16/2019	9/16/2020	2	Combo Faucet	In classroom 265	Left	WF-09162019-004797	10/27/2019	FT-FY20-102019-004797-A	<1	FT-FY20-102019-004797-B	<1
WS- 004798	3/25/2019	3/25/2020	2	Combo Fountain	In classroom 265	Right	WF-03252019-004798	10/27/2019	FT-FY20-102019-004798-A	<1	FT-FY20-102019-004798-B	<1
WS- 004799	3/25/2019	3/25/2020	2	Break Room	In teacher work room 285		WF-03252019-004799	10/27/2019	FT-FY20-102019-004799-A	<1	FT-FY20-102019-004799-B	<1
WS- 004800	3/25/2019	3/25/2020	1	Cooler	In entrance to boy/girl restroom near main lobby	High Left	WF-03252019-004800	10/27/2019	FT-FY20-102019-004800-A	<1	FT-FY20-102019-004800-B	<1
WS- 004801	3/25/2019	3/25/2020	1	Cooler	In entrance to boy/girl restroom near main lobby	Low Right	WF-03252019-004801	10/27/2019	FT-FY20-102019-004801-A	<1	FT-FY20-102019-004801-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004772	7/18/2019	7/18/2020	Basement	Food Prep Sink	In kitchen on east wall	Left	WF-07182019-004772	10/27/2019	FT-FY20-102019-004772-A	<1	FT-FY20-102019-004772-B	<1
WS- 004773	7/18/2019	7/18/2020	Basement	Food Prep Sink	In kitchen on east wall	Right	WF-07182019-004773	10/27/2019	FT-FY20-102019-004773-A	<1	FT-FY20-102019-004773-B	<1
WS- 004774	7/18/2019	7/18/2020	Basement	Food Prep Sink	In kitchen on island	Left	WF-07182019-004774	10/27/2019	FT-FY20-102019-004774-A	<1	FT-FY20-102019-004774-B	<1
WS- 004775	7/18/2019	7/18/2020	Basement	Food Prep Sink	In kitchen on island	Right	WF-07182019-004775	10/27/2019	FT-FY20-102019-004775-A	<1	FT-FY20-102019-004775-B	<1

### FY20 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004746	9/16/2019	9/16/2020	1	Combo Faucet	In classroom 122		WF-09162019-004746	10/27/2019	FT-FY20-102019-004746-A	5.5	FT-FY20-102019-004746-B	2.9
WS- 004747	3/25/2019	3/25/2020	1	Combo Fountain	In classroom 122		WF-03252019-004747	10/27/2019	FT-FY20-102019-004747-A	5.2	FT-FY20-102019-004747-B	4.5