



# Hearst Elementary School Lead in Water Test Results

## FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004742	2/22/2023	2/22/2024	1	Health Suite	In health suite	WF-02222023-004742	10/29/2023	FT-FY24-09282023-004742-A	<1	FT-FY24-09282023-004742-B	<1	
WS- 004743	2/22/2023	2/22/2024	1	Combo Fountain	In health suite	WF-02222023-004743	10/29/2023	FT-FY24-09282023-004743-A	1.2	FT-FY24-09282023-004743-B	<1	
WS- 004744	2/22/2023	2/22/2024	1	Health Suite	In health suite in exam room 2	WF-02222023-004744	10/29/2023	FT-FY24-09282023-004744-A	<1	FT-FY24-09282023-004744-B	<1	
WS- 004745	2/22/2023	2/22/2024	1	Combo Fountain	In exam room 2 in health suite	WF-02222023-004745	10/29/2023	FT-FY24-09282023-004745-A	2.1	FT-FY24-09282023-004745-B	<1	
WS- 004746	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 122	WF-08152023-004746	10/29/2023	FT-FY24-09282023-004746-A	3.0	FT-FY24-09282023-004746-B	<1	
WS- 004747	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 122	WF-02222023-004747	10/29/2023	FT-FY24-09282023-004747-A	2.2	FT-FY24-09282023-004747-B	<1	
WS- 004748	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 110	WF-08152023-004748	10/29/2023	FT-FY24-09282023-004748-A	2.3	FT-FY24-09282023-004748-B	<1	
WS- 004749	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 110	WF-02222023-004749	10/29/2023	FT-FY24-09282023-004749-A	<1	FT-FY24-09282023-004749-B	<1	
WS- 004750	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 114	WF-08152023-004750	10/29/2023	FT-FY24-09282023-004750-A	1.9	FT-FY24-09282023-004750-B	<1	
WS- 004751	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 114	WF-02222023-004751	10/29/2023	FT-FY24-09282023-004751-A	<1	FT-FY24-09282023-004751-B	<1	
WS- 004752	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 118	WF-08152023-004752	10/29/2023	FT-FY24-09282023-004752-A	1.4	FT-FY24-09282023-004752-B	<1	
WS- 004753	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 118	WF-02222023-004753	10/29/2023	FT-FY24-09282023-004753-A	<1	FT-FY24-09282023-004753-B	<1	
WS- 004754	8/15/2023	8/15/2024	1	Classroom Faucet	In art room 173	Left	WF-08152023-004754	10/29/2023	FT-FY24-09282023-004754-A	<1	FT-FY24-09282023-004754-B	<1
WS- 004755	8/15/2023	8/15/2024	1	Classroom Faucet	In art room 173	Right	WF-08152023-004755	10/29/2023	FT-FY24-09282023-004755-A	2.0	FT-FY24-09282023-004755-B	1.4
WS- 004756	8/15/2023	8/15/2024	1	Classroom Faucet	In parent resource room 169		WF-08152023-004756	10/29/2023	FT-FY24-09282023-004756-A	<1	FT-FY24-09282023-004756-B	<1
WS- 004759	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 167	Left	WF-08152023-004759	10/29/2023	FT-FY24-09282023-004759-A	2.2	FT-FY24-09282023-004759-B	<1
WS- 004760	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 167	Right	WF-02222023-004760	10/29/2023	FT-FY24-09282023-004760-A	1.1	FT-FY24-09282023-004760-B	<1
WS- 004761	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 166		WF-08152023-004761	10/29/2023	FT-FY24-09282023-004761-A	<1	FT-FY24-09282023-004761-B	<1
WS- 004762	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 166		WF-02222023-004762	10/29/2023	FT-FY24-09282023-004762-A	<1	FT-FY24-09282023-004762-B	<1
WS- 004763	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 165		WF-08152023-004763	10/29/2023	FT-FY24-09282023-004763-A	1.2	FT-FY24-09282023-004763-B	<1
WS- 004764	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 165		WF-02222023-004764	10/29/2023	FT-FY24-09282023-004764-A	<1	FT-FY24-09282023-004764-B	<1
WS- 004765	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 164	Left	WF-08152023-004765	10/29/2023	FT-FY24-09282023-004765-A	2.9	FT-FY24-09282023-004765-B	<1
WS- 004766	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 164	Right	WF-02222023-004766	10/29/2023	FT-FY24-09282023-004766-A	<1	FT-FY24-09282023-004766-B	<1
WS- 004767	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 161		WF-08152023-004767	10/29/2023	FT-FY24-09282023-004767-A	2.0	FT-FY24-09282023-004767-B	<1
WS- 004768	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 161		WF-02222023-004768	10/29/2023	FT-FY24-09282023-004768-A	<1	FT-FY24-09282023-004768-B	<1
WS- 004769	8/15/2023	8/15/2024	1	Combo Faucet	In classroom 160	Left	WF-08152023-004769	10/29/2023	FT-FY24-09282023-004769-A	1.4	FT-FY24-09282023-004769-B	<1
WS- 004770	2/22/2023	2/22/2024	1	Combo Fountain	In classroom 160	Right	WF-02222023-004770	10/29/2023	FT-FY24-09282023-004770-A	<1	FT-FY24-09282023-004770-B	<1
WS- 004776	2/22/2023	2/22/2024	Basement	Ice Maker	In kitchen (ice maker)		WF-02222023-004776	10/29/2023	FT-FY24-09282023-004776-A	<1	FT-FY24-09282023-004776-B	<1
WS- 004777	2/22/2023	2/22/2024	Basement	Cooler	In gym	Low Right	WF-02222023-004777	10/29/2023	FT-FY24-09282023-004777-A	<1	FT-FY24-09282023-004777-B	<1
WS- 004778	2/22/2023	2/22/2024	Basement	Cooler	In gym	High Left	WF-02222023-004778	10/29/2023	FT-FY24-09282023-004778-A	<1	FT-FY24-09282023-004778-B	<1
WS- 004779	2/22/2023	2/22/2024	2	Break Room	In teacher work room 221		WF-02222023-004779	10/29/2023	FT-FY24-09282023-004779-A	<1	FT-FY24-09282023-004779-B	<1
WS- 004781	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 219	Right	WF-08152023-004781	10/29/2023	FT-FY24-09282023-004781-A	<1	FT-FY24-09282023-004781-B	<1
WS- 004782	2/22/2023	2/22/2024	2	Combo Fountain	In classroom 219	Left	WF-02222023-004782	10/29/2023	FT-FY24-09282023-004782-A	<1	FT-FY24-09282023-004782-B	<1
WS- 004783	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 210		WF-08152023-004783	10/29/2023	FT-FY24-09282023-004783-A	2.1	FT-FY24-09282023-004783-B	<1
WS- 004784	2/22/2023	2/22/2024	2	Combo Fountain	In classroom 210		WF-02222023-004784	10/29/2023	FT-FY24-09282023-004784-A	<1	FT-FY24-09282023-004784-B	<1

WS- 004785	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 214	Right	WF-08152023-004785	10/29/2023	FT-FY24-09282023-004785-A	<1	FT-FY24-09282023-004785-B	<1
WS- 004787	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 218		WF-08152023-004787	10/29/2023	FT-FY24-09282023-004787-A	2.4	FT-FY24-09282023-004787-B	<1
WS- 004788	2/22/2023	2/22/2024	2	Combo Fountain	In classroom 218		WF-02222023-004788	10/29/2023	FT-FY24-09282023-004788-A	<1	FT-FY24-09282023-004788-B	<1
WS- 004789	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 260		WF-08152023-004789	10/29/2023	FT-FY24-09282023-004789-A	1.6	FT-FY24-09282023-004789-B	<1
WS- 004790	2/22/2023	2/22/2024	2	Combo Fountain	In classroom 260		WF-02222023-004790	10/29/2023	FT-FY24-09282023-004790-A	<1	FT-FY24-09282023-004790-B	<1
WS- 004791	2/22/2023	2/22/2024	2	Cooler	In entrance to boy/girl restroom near room 220	High Left	WF-02222023-004791	10/29/2023	FT-FY24-09282023-004791-A	<1	FT-FY24-09282023-004791-B	<1
WS- 004792	2/22/2023	2/22/2024	2	Cooler	In entrance to boy/girl restroom near room 220	Low Right	WF-02222023-004792	10/29/2023	FT-FY24-09282023-004792-A	<1	FT-FY24-09282023-004792-B	<1
WS- 004793	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 261		WF-08152023-004793	10/29/2023	FT-FY24-09282023-004793-A	2.2	FT-FY24-09282023-004793-B	<1
WS- 004794	2/22/2023	2/22/2024	2	Combo Fountain	In classroom 261		WF-02222023-004794	10/29/2023	FT-FY24-09282023-004794-A	<1	FT-FY24-09282023-004794-B	<1
WS- 004795	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 264		WF-08152023-004795	10/29/2023	FT-FY24-09282023-004795-A	2.1	FT-FY24-09282023-004795-B	<1
WS- 004796	2/22/2023	2/22/2024	2	Combo Fountain	In classroom 264		WF-02222023-004796	10/29/2023	FT-FY24-09282023-004796-A	<1	FT-FY24-09282023-004796-B	<1
WS- 004797	8/15/2023	8/15/2024	2	Combo Faucet	In classroom 265	Left	WF-08152023-004797	10/29/2023	FT-FY24-09282023-004797-A	2.3	FT-FY24-09282023-004797-B	<1
WS- 004798	2/22/2023	2/22/2024	2	Combo Fountain	In classroom 265	Right	WF-02222023-004798	10/29/2023	FT-FY24-09282023-004798-A	<1	FT-FY24-09282023-004798-B	<1
WS- 004799	2/22/2023	2/22/2024	2	Break Room	In teacher work room 285		WF-02222023-004799	10/29/2023	FT-FY24-09282023-004799-A	<1	FT-FY24-09282023-004799-B	<1
WS- 004801	2/22/2023	2/22/2024	1	Cooler	In entrance to boy/girl restroom near main lobby	Low Right	WF-02222023-004801	10/29/2023	FT-FY24-09282023-004801-A	<1	FT-FY24-09282023-004801-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004772	12/22/2022	12/22/2023	Basement	Food Prep Sink	In kitchen on east wall	Left	WF-12222022-004772	10/29/2023	FT-FY24-09282023-004772-A	1.0	FT-FY24-09282023-004772-B	<1
WS- 004773	12/22/2022	12/22/2023	Basement	Food Prep Sink	In kitchen on east wall	Right	WF-12222022-004773	10/29/2023	FT-FY24-09282023-004773-A	<1	FT-FY24-09282023-004773-B	<1
WS- 004774	12/22/2022	12/22/2023	Basement	Food Prep Sink	In kitchen on island	Left	WF-12222022-004774	10/29/2023	FT-FY24-09282023-004774-A	3.5	FT-FY24-09282023-004774-B	<1
WS- 004775	12/22/2022	12/22/2023	Basement	Food Prep Sink	In kitchen on island	Right	WF-12222022-004775	10/29/2023	FT-FY24-09282023-004775-A	<1	FT-FY24-09282023-004775-B	<1