



Hearst ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004742	2/10/2025	2/10/2026	1	Health Suite	In health suite	WF-02102025-004742	10/29/2025	FT-FY26-09302025-004742-A	<2	FT-FY26-09302025-004742-B	<2
WS- 004743	2/10/2025	2/10/2026	1	Combo Fountain	In health suite	WF-02102025-004743	10/29/2025	FT-FY26-09302025-004743-A	<2	FT-FY26-09302025-004743-B	<2
WS- 004744	2/10/2025	2/10/2026	1	Health Suite	In health suite in exam room 2	WF-02102025-004744	10/29/2025	FT-FY26-09302025-004744-A	<2	FT-FY26-09302025-004744-B	<2
WS- 004745	2/10/2025	2/10/2026	1	Combo Fountain	In exam room 2 in health suite	WF-02102025-004745	10/29/2025	FT-FY26-09302025-004745-A	<2	FT-FY26-09302025-004745-B	<2
WS- 004747	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 122	WF-02102025-004747	10/29/2025	FT-FY26-09302025-004747-A	2.1	FT-FY26-09302025-004747-B	<2
WS- 004748	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 110	WF-08042025-004748	10/29/2025	FT-FY26-09302025-004748-A	2.1	FT-FY26-09302025-004748-B	<2
WS- 004749	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 110	WF-02102025-004749	10/29/2025	FT-FY26-09302025-004749-A	<2	FT-FY26-09302025-004749-B	<2
WS- 004750	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 114	WF-08042025-004750	10/29/2025	FT-FY26-09302025-004750-A	<2	FT-FY26-09302025-004750-B	<2
WS- 004751	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 114	WF-02102025-004751	10/29/2025	FT-FY26-09302025-004751-A	<2	FT-FY26-09302025-004751-B	<2
WS- 004752	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 118	WF-08042025-004752	10/29/2025	FT-FY26-09302025-004752-A	<2	FT-FY26-09302025-004752-B	<2
WS- 004753	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 118	WF-02102025-004753	10/29/2025	FT-FY26-09302025-004753-A	<2	FT-FY26-09302025-004753-B	<2
WS- 004754	8/4/2025	8/4/2026	1	Classroom Faucet	In art room 173	Left WF-08042025-004754	10/29/2025	FT-FY26-09302025-004754-A	<2	FT-FY26-09302025-004754-B	<2
WS- 004755	8/4/2025	8/4/2026	1	Classroom Faucet	In art room 173	Right WF-08042025-004755	10/29/2025	FT-FY26-09302025-004755-A	<2	FT-FY26-09302025-004755-B	<2
WS- 004756	8/4/2025	8/4/2026	1	Classroom Faucet	In parent resource room 169	WF-08042025-004756	10/29/2025	FT-FY26-09302025-004756-A	<2	FT-FY26-09302025-004756-B	<2
WS- 004757	2/10/2025	2/10/2026	1	Cooler	In hallway adjacent room 170	High Left WF-02102025-004757	10/29/2025	FT-FY26-09302025-004757-A	<2	FT-FY26-09302025-004757-B	<2
WS- 004758	2/10/2025	2/10/2026	1	Cooler	In hallway adjacent room 170	Low Right WF-02102025-004758	10/29/2025	FT-FY26-09302025-004758-A	<2	FT-FY26-09302025-004758-B	<2
WS- 004759	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 167	Left WF-08042025-004759	10/29/2025	FT-FY26-09302025-004759-A	2.0	FT-FY26-09302025-004759-B	<2
WS- 004760	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 167	Right WF-02102025-004760	10/29/2025	FT-FY26-09302025-004760-A	<2	FT-FY26-09302025-004760-B	<2
WS- 004761	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 166	WF-08042025-004761	10/29/2025	FT-FY26-09302025-004761-A	<2	FT-FY26-09302025-004761-B	<2
WS- 004762	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 166	WF-02102025-004762	10/29/2025	FT-FY26-09302025-004762-A	<2	FT-FY26-09302025-004762-B	<2
WS- 004763	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 165	WF-08042025-004763	10/29/2025	FT-FY26-09302025-004763-A	<2	FT-FY26-09302025-004763-B	<2
WS- 004764	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 165	WF-02102025-004764	10/29/2025	FT-FY26-09302025-004764-A	<2	FT-FY26-09302025-004764-B	<2
WS- 004765	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 164	Left WF-08042025-004765	10/29/2025	FT-FY26-09302025-004765-A	2.7	FT-FY26-09302025-004765-B	<2
WS- 004766	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 164	Right WF-02102025-004766	10/29/2025	FT-FY26-09302025-004766-A	<2	FT-FY26-09302025-004766-B	<2
WS- 004767	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 161	WF-08042025-004767	10/29/2025	FT-FY26-09302025-004767-A	<2	FT-FY26-09302025-004767-B	<2
WS- 004768	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 161	WF-02102025-004768	10/29/2025	FT-FY26-09302025-004768-A	<2	FT-FY26-09302025-004768-B	<2
WS- 004769	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 160	Left WF-08042025-004769	10/29/2025	FT-FY26-09302025-004769-A	<2	FT-FY26-09302025-004769-B	<2
WS- 004770	2/10/2025	2/10/2026	1	Combo Fountain	In classroom 160	Right WF-02102025-004770	10/29/2025	FT-FY26-09302025-004770-A	<2	FT-FY26-09302025-004770-B	<2
WS- 004776	2/10/2025	2/10/2026	Basement	Ice Maker	In kitchen (ice maker)	WF-02102025-004776	10/29/2025	FT-FY26-09302025-004776-A	<2	FT-FY26-09302025-004776-B	<2
WS- 004777	2/10/2025	2/10/2026	Basement	Cooler	In gym	Low Right WF-02102025-004777	10/29/2025	FT-FY26-09302025-004777-A	<2	FT-FY26-09302025-004777-B	<2
WS- 004778	2/10/2025	2/10/2026	Basement	Cooler	In gym	High Left WF-02102025-004778	10/29/2025	FT-FY26-09302025-004778-A	<2	FT-FY26-09302025-004778-B	<2
WS- 004779	2/10/2025	2/10/2026	2	Break Room	In teacher work room 221	WF-02102025-004779	10/29/2025	FT-FY26-09302025-004779-A	<2	FT-FY26-09302025-004779-B	<2
WS- 004781	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 219	Right WF-08042025-004781	10/29/2025	FT-FY26-09302025-004781-A	<2	FT-FY26-09302025-004781-B	<2
WS- 004782	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 219	Left WF-02102025-004782	10/29/2025	FT-FY26-09302025-004782-A	<2	FT-FY26-09302025-004782-B	<2

WS-004783	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 210		WF-08042025-004783	10/29/2025	FT-FY26-09302025-004783-A	3.2	FT-FY26-09302025-004783-B	<2
WS-004784	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 210		WF-02102025-004784	10/29/2025	FT-FY26-09302025-004784-A	<2	FT-FY26-09302025-004784-B	<2
WS-004787	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 218		WF-08042025-004787	10/29/2025	FT-FY26-09302025-004787-A	<2	FT-FY26-09302025-004787-B	<2
WS-004788	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 218		WF-02102025-004788	10/29/2025	FT-FY26-09302025-004788-A	<2	FT-FY26-09302025-004788-B	<2
WS-004789	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 260		WF-08042025-004789	10/29/2025	FT-FY26-09302025-004789-A	<2	FT-FY26-09302025-004789-B	<2
WS-004790	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 260		WF-02102025-004790	10/29/2025	FT-FY26-09302025-004790-A	<2	FT-FY26-09302025-004790-B	<2
WS-004791	2/10/2025	2/10/2026	2	Cooler	In entrance to boy/girl restroom near room 220	High Left	WF-02102025-004791	10/29/2025	FT-FY26-09302025-004791-A	<2	FT-FY26-09302025-004791-B	<2
WS-004792	2/10/2025	2/10/2026	2	Cooler	In entrance to boy/girl restroom near room 220	Low Right	WF-02102025-004792	10/29/2025	FT-FY26-09302025-004792-A	<2	FT-FY26-09302025-004792-B	<2
WS-004793	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 261		WF-08042025-004793	10/29/2025	FT-FY26-09302025-004793-A	<2	FT-FY26-09302025-004793-B	<2
WS-004794	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 261		WF-02102025-004794	10/29/2025	FT-FY26-09302025-004794-A	<2	FT-FY26-09302025-004794-B	<2
WS-004795	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 264		WF-08042025-004795	10/29/2025	FT-FY26-09302025-004795-A	<2	FT-FY26-09302025-004795-B	<2
WS-004796	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 264		WF-02102025-004796	10/29/2025	FT-FY26-09302025-004796-A	<2	FT-FY26-09302025-004796-B	<2
WS-004797	8/4/2025	8/4/2026	2	Combo Faucet	In classroom 265	Left	WF-08042025-004797	10/29/2025	FT-FY26-09302025-004797-A	<2	FT-FY26-09302025-004797-B	<2
WS-004798	2/10/2025	2/10/2026	2	Combo Fountain	In classroom 265	Right	WF-02102025-004798	10/29/2025	FT-FY26-09302025-004798-A	<2	FT-FY26-09302025-004798-B	<2
WS-004799	2/10/2025	2/10/2026	2	Break Room	In teacher work room 285		WF-02102025-004799	10/29/2025	FT-FY26-09302025-004799-A	<2	FT-FY26-09302025-004799-B	<2
WS-004800	2/10/2025	2/10/2026	1	Cooler	In entrance to boy/girl restroom near main lobby	High Left	WF-02102025-004800	10/29/2025	FT-FY26-09302025-004800-A	<2	FT-FY26-09302025-004800-B	<2
WS-004801	2/10/2025	2/10/2026	1	Cooler	In entrance to boy/girl restroom near main lobby	Low Right	WF-02102025-004801	10/29/2025	FT-FY26-09302025-004801-A	<2	FT-FY26-09302025-004801-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004772	11/19/2024	11/19/2025	Basement	Food Prep Sink	In kitchen on east wall	Left	WF-11192024-004772	10/29/2025	FT-FY26-09302025-004772-A	<2	FT-FY26-09302025-004772-B	<2
WS-004773	11/19/2024	11/19/2025	Basement	Food Prep Sink	In kitchen on east wall	Right	WF-11192024-004773	10/29/2025	FT-FY26-09302025-004773-A	<2	FT-FY26-09302025-004773-B	<2
WS-004774	11/19/2024	11/19/2025	Basement	Food Prep Sink	In kitchen on island	Left	WF-11192024-004774	10/29/2025	FT-FY26-09302025-004774-A	<2	FT-FY26-09302025-004774-B	<2
WS-004775	11/19/2024	11/19/2025	Basement	Food Prep Sink	In kitchen on island	Right	WF-11192024-004775	10/29/2025	FT-FY26-09302025-004775-A	<2	FT-FY26-09302025-004775-B	<2

FY26 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004746	8/4/2025	8/4/2026	1	Combo Faucet	In classroom 122	WF-08042025-004746	10/29/2025	FT-FY26-09302025-004746-A	5.3	FT-FY26-09302025-004746-B	<2	

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.