



Hearst ES Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
|------------|-----------------------|------------------------|----------|------------------|--------------------------------|------------------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| WS- 004742 | 2/10/2025 | 2/10/2026 | 1 | Health Suite | In health suite | WF-02102025-004742 | 10/29/2025 | FT-FY26-09302025-004742-A | <2 | FT-FY26-09302025-004742-B | <2 |
| WS- 004743 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In health suite | WF-02102025-004743 | 10/29/2025 | FT-FY26-09302025-004743-A | <2 | FT-FY26-09302025-004743-B | <2 |
| WS- 004744 | 2/10/2025 | 2/10/2026 | 1 | Health Suite | In health suite in exam room 2 | WF-02102025-004744 | 10/29/2025 | FT-FY26-09302025-004744-A | <2 | FT-FY26-09302025-004744-B | <2 |
| WS- 004745 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In exam room 2 in health suite | WF-02102025-004745 | 10/29/2025 | FT-FY26-09302025-004745-A | <2 | FT-FY26-09302025-004745-B | <2 |
| WS- 004747 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 122 | WF-02102025-004747 | 10/29/2025 | FT-FY26-09302025-004747-A | 2.1 | FT-FY26-09302025-004747-B | <2 |
| WS- 004748 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 110 | WF-08042025-004748 | 10/29/2025 | FT-FY26-09302025-004748-A | 2.1 | FT-FY26-09302025-004748-B | <2 |
| WS- 004749 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 110 | WF-02102025-004749 | 10/29/2025 | FT-FY26-09302025-004749-A | <2 | FT-FY26-09302025-004749-B | <2 |
| WS- 004750 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 114 | WF-08042025-004750 | 10/29/2025 | FT-FY26-09302025-004750-A | <2 | FT-FY26-09302025-004750-B | <2 |
| WS- 004751 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 114 | WF-02102025-004751 | 10/29/2025 | FT-FY26-09302025-004751-A | <2 | FT-FY26-09302025-004751-B | <2 |
| WS- 004752 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 118 | WF-08042025-004752 | 10/29/2025 | FT-FY26-09302025-004752-A | <2 | FT-FY26-09302025-004752-B | <2 |
| WS- 004753 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 118 | WF-02102025-004753 | 10/29/2025 | FT-FY26-09302025-004753-A | <2 | FT-FY26-09302025-004753-B | <2 |
| WS- 004754 | 8/4/2025 | 8/4/2026 | 1 | Classroom Faucet | In art room 173 | Left WF-08042025-004754 | 10/29/2025 | FT-FY26-09302025-004754-A | <2 | FT-FY26-09302025-004754-B | <2 |
| WS- 004755 | 8/4/2025 | 8/4/2026 | 1 | Classroom Faucet | In art room 173 | Right WF-08042025-004755 | 10/29/2025 | FT-FY26-09302025-004755-A | <2 | FT-FY26-09302025-004755-B | <2 |
| WS- 004756 | 8/4/2025 | 8/4/2026 | 1 | Classroom Faucet | In parent resource room 169 | WF-08042025-004756 | 10/29/2025 | FT-FY26-09302025-004756-A | <2 | FT-FY26-09302025-004756-B | <2 |
| WS- 004757 | 2/10/2025 | 2/10/2026 | 1 | Cooler | In hallway adjacent room 170 | High Left WF-02102025-004757 | 10/29/2025 | FT-FY26-09302025-004757-A | <2 | FT-FY26-09302025-004757-B | <2 |
| WS- 004758 | 2/10/2025 | 2/10/2026 | 1 | Cooler | In hallway adjacent room 170 | Low Right WF-02102025-004758 | 10/29/2025 | FT-FY26-09302025-004758-A | <2 | FT-FY26-09302025-004758-B | <2 |
| WS- 004759 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 167 | Left WF-08042025-004759 | 10/29/2025 | FT-FY26-09302025-004759-A | 2.0 | FT-FY26-09302025-004759-B | <2 |
| WS- 004760 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 167 | Right WF-02102025-004760 | 10/29/2025 | FT-FY26-09302025-004760-A | <2 | FT-FY26-09302025-004760-B | <2 |
| WS- 004761 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 166 | WF-08042025-004761 | 10/29/2025 | FT-FY26-09302025-004761-A | <2 | FT-FY26-09302025-004761-B | <2 |
| WS- 004762 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 166 | WF-02102025-004762 | 10/29/2025 | FT-FY26-09302025-004762-A | <2 | FT-FY26-09302025-004762-B | <2 |
| WS- 004763 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 165 | WF-08042025-004763 | 10/29/2025 | FT-FY26-09302025-004763-A | <2 | FT-FY26-09302025-004763-B | <2 |
| WS- 004764 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 165 | WF-02102025-004764 | 10/29/2025 | FT-FY26-09302025-004764-A | <2 | FT-FY26-09302025-004764-B | <2 |
| WS- 004765 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 164 | Left WF-08042025-004765 | 10/29/2025 | FT-FY26-09302025-004765-A | 2.7 | FT-FY26-09302025-004765-B | <2 |
| WS- 004766 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 164 | Right WF-02102025-004766 | 10/29/2025 | FT-FY26-09302025-004766-A | <2 | FT-FY26-09302025-004766-B | <2 |
| WS- 004767 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 161 | WF-08042025-004767 | 10/29/2025 | FT-FY26-09302025-004767-A | <2 | FT-FY26-09302025-004767-B | <2 |
| WS- 004768 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 161 | WF-02102025-004768 | 10/29/2025 | FT-FY26-09302025-004768-A | <2 | FT-FY26-09302025-004768-B | <2 |
| WS- 004769 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 160 | Left WF-08042025-004769 | 10/29/2025 | FT-FY26-09302025-004769-A | <2 | FT-FY26-09302025-004769-B | <2 |
| WS- 004770 | 2/10/2025 | 2/10/2026 | 1 | Combo Fountain | In classroom 160 | Right WF-02102025-004770 | 10/29/2025 | FT-FY26-09302025-004770-A | <2 | FT-FY26-09302025-004770-B | <2 |
| WS- 004776 | 2/10/2025 | 2/10/2026 | Basement | Ice Maker | In kitchen (ice maker) | WF-02102025-004776 | 10/29/2025 | FT-FY26-09302025-004776-A | <2 | FT-FY26-09302025-004776-B | <2 |
| WS- 004777 | 2/10/2025 | 2/10/2026 | Basement | Cooler | In gym | Low Right WF-02102025-004777 | 10/29/2025 | FT-FY26-09302025-004777-A | <2 | FT-FY26-09302025-004777-B | <2 |
| WS- 004778 | 2/10/2025 | 2/10/2026 | Basement | Cooler | In gym | High Left WF-02102025-004778 | 10/29/2025 | FT-FY26-09302025-004778-A | <2 | FT-FY26-09302025-004778-B | <2 |
| WS- 004779 | 2/10/2025 | 2/10/2026 | 2 | Break Room | In teacher work room 221 | WF-02102025-004779 | 10/29/2025 | FT-FY26-09302025-004779-A | <2 | FT-FY26-09302025-004779-B | <2 |
| WS- 004781 | 8/4/2025 | 8/4/2026 | 2 | Combo Faucet | In classroom 219 | Right WF-08042025-004781 | 10/29/2025 | FT-FY26-09302025-004781-A | <2 | FT-FY26-09302025-004781-B | <2 |
| WS- 004782 | 2/10/2025 | 2/10/2026 | 2 | Combo Fountain | In classroom 219 | Left WF-02102025-004782 | 10/29/2025 | FT-FY26-09302025-004782-A | <2 | FT-FY26-09302025-004782-B | <2 |

| | | | | | | | | | | | | |
|-----------|-----------|-----------|---|----------------|--|-----------|--------------------|------------|---------------------------|-----|---------------------------|----|
| WS-004783 | 8/4/2025 | 8/4/2026 | 2 | Combo Faucet | In classroom 210 | | WF-08042025-004783 | 10/29/2025 | FT-FY26-09302025-004783-A | 3.2 | FT-FY26-09302025-004783-B | <2 |
| WS-004784 | 2/10/2025 | 2/10/2026 | 2 | Combo Fountain | In classroom 210 | | WF-02102025-004784 | 10/29/2025 | FT-FY26-09302025-004784-A | <2 | FT-FY26-09302025-004784-B | <2 |
| WS-004787 | 8/4/2025 | 8/4/2026 | 2 | Combo Faucet | In classroom 218 | | WF-08042025-004787 | 10/29/2025 | FT-FY26-09302025-004787-A | <2 | FT-FY26-09302025-004787-B | <2 |
| WS-004788 | 2/10/2025 | 2/10/2026 | 2 | Combo Fountain | In classroom 218 | | WF-02102025-004788 | 10/29/2025 | FT-FY26-09302025-004788-A | <2 | FT-FY26-09302025-004788-B | <2 |
| WS-004789 | 8/4/2025 | 8/4/2026 | 2 | Combo Faucet | In classroom 260 | | WF-08042025-004789 | 10/29/2025 | FT-FY26-09302025-004789-A | <2 | FT-FY26-09302025-004789-B | <2 |
| WS-004790 | 2/10/2025 | 2/10/2026 | 2 | Combo Fountain | In classroom 260 | | WF-02102025-004790 | 10/29/2025 | FT-FY26-09302025-004790-A | <2 | FT-FY26-09302025-004790-B | <2 |
| WS-004791 | 2/10/2025 | 2/10/2026 | 2 | Cooler | In entrance to boy/girl restroom near room 220 | High Left | WF-02102025-004791 | 10/29/2025 | FT-FY26-09302025-004791-A | <2 | FT-FY26-09302025-004791-B | <2 |
| WS-004792 | 2/10/2025 | 2/10/2026 | 2 | Cooler | In entrance to boy/girl restroom near room 220 | Low Right | WF-02102025-004792 | 10/29/2025 | FT-FY26-09302025-004792-A | <2 | FT-FY26-09302025-004792-B | <2 |
| WS-004793 | 8/4/2025 | 8/4/2026 | 2 | Combo Faucet | In classroom 261 | | WF-08042025-004793 | 10/29/2025 | FT-FY26-09302025-004793-A | <2 | FT-FY26-09302025-004793-B | <2 |
| WS-004794 | 2/10/2025 | 2/10/2026 | 2 | Combo Fountain | In classroom 261 | | WF-02102025-004794 | 10/29/2025 | FT-FY26-09302025-004794-A | <2 | FT-FY26-09302025-004794-B | <2 |
| WS-004795 | 8/4/2025 | 8/4/2026 | 2 | Combo Faucet | In classroom 264 | | WF-08042025-004795 | 10/29/2025 | FT-FY26-09302025-004795-A | <2 | FT-FY26-09302025-004795-B | <2 |
| WS-004796 | 2/10/2025 | 2/10/2026 | 2 | Combo Fountain | In classroom 264 | | WF-02102025-004796 | 10/29/2025 | FT-FY26-09302025-004796-A | <2 | FT-FY26-09302025-004796-B | <2 |
| WS-004797 | 8/4/2025 | 8/4/2026 | 2 | Combo Faucet | In classroom 265 | Left | WF-08042025-004797 | 10/29/2025 | FT-FY26-09302025-004797-A | <2 | FT-FY26-09302025-004797-B | <2 |
| WS-004798 | 2/10/2025 | 2/10/2026 | 2 | Combo Fountain | In classroom 265 | Right | WF-02102025-004798 | 10/29/2025 | FT-FY26-09302025-004798-A | <2 | FT-FY26-09302025-004798-B | <2 |
| WS-004799 | 2/10/2025 | 2/10/2026 | 2 | Break Room | In teacher work room 285 | | WF-02102025-004799 | 10/29/2025 | FT-FY26-09302025-004799-A | <2 | FT-FY26-09302025-004799-B | <2 |
| WS-004800 | 2/10/2025 | 2/10/2026 | 1 | Cooler | In entrance to boy/girl restroom near main lobby | High Left | WF-02102025-004800 | 10/29/2025 | FT-FY26-09302025-004800-A | <2 | FT-FY26-09302025-004800-B | <2 |
| WS-004801 | 2/10/2025 | 2/10/2026 | 1 | Cooler | In entrance to boy/girl restroom near main lobby | Low Right | WF-02102025-004801 | 10/29/2025 | FT-FY26-09302025-004801-A | <2 | FT-FY26-09302025-004801-B | <2 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | |
|---|-----------------------|------------------------|----------|----------------|-------------------------|---------------------|--------------------|----------------------|----------------------------------|----------------------|----------------------------------|----|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) | |
| WS-004772 | 11/19/2024 | 11/19/2025 | Basement | Food Prep Sink | In kitchen on east wall | Left | WF-11192024-004772 | 10/29/2025 | FT-FY26-09302025-004772-A | <2 | FT-FY26-09302025-004772-B | <2 |
| WS-004773 | 11/19/2024 | 11/19/2025 | Basement | Food Prep Sink | In kitchen on east wall | Right | WF-11192024-004773 | 10/29/2025 | FT-FY26-09302025-004773-A | <2 | FT-FY26-09302025-004773-B | <2 |
| WS-004774 | 11/19/2024 | 11/19/2025 | Basement | Food Prep Sink | In kitchen on island | Left | WF-11192024-004774 | 10/29/2025 | FT-FY26-09302025-004774-A | <2 | FT-FY26-09302025-004774-B | <2 |
| WS-004775 | 11/19/2024 | 11/19/2025 | Basement | Food Prep Sink | In kitchen on island | Right | WF-11192024-004775 | 10/29/2025 | FT-FY26-09302025-004775-A | <2 | FT-FY26-09302025-004775-B | <2 |

FY26 Filter Test

| Greater than 5ppb - Devices requiring remediation | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|--------------|------------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|--|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) | |
| WS-004746 | 8/4/2025 | 8/4/2026 | 1 | Combo Faucet | In classroom 122 | WF-08042025-004746 | 10/29/2025 | FT-FY26-09302025-004746-A | 5.3 | FT-FY26-09302025-004746-B | <2 | |

After First Re-test (Plumbing Check)

FY26 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|--------------|------------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|--|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) | |
| WS-004746 | 10/31/2025 | 10/31/2026 | 1 | Combo Faucet | In classroom 122 | WF-10312025-004746 | 11/6/2025 | FT-FY26-10312025-004746-A | <2 | FT-FY26-10312025-004746-B | <2 | |

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.