



HEARST ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	HEARST ELEMENTARY SCHOOL	WS- 004742	8/20/2016	1	Fountain	In health suite	FT-82016-004742-A	< 1	FT-82016-004742-B	< 1
2	HEARST ELEMENTARY SCHOOL	WS- 004743	8/20/2016	1	Health Suite	In health suite	FT-82016-004743-A	< 1	FT-82016-004743-B	< 1
3	HEARST ELEMENTARY SCHOOL	WS- 004744	8/20/2016	1	Health Suite	In exam room 2 in health suite	FT-82016-004744-A	< 1	FT-82016-004744-B	< 1
4	HEARST ELEMENTARY SCHOOL	WS- 004745	8/20/2016	1	Fountain	In exam room 2 in health suite	FT-82016-004745-A	< 1	FT-82016-004745-B	< 1
5	HEARST ELEMENTARY SCHOOL	WS- 004747	8/20/2016	1	Fountain	In classroom 122	FT-72016-004747-A	< 1	FT-72016-004747-B	< 1
6	HEARST ELEMENTARY SCHOOL	WS- 004751	8/20/2016	1	Fountain	In classroom 114	FT-72016-004751-A	< 1	FT-72016-004751-B	< 1
7	HEARST ELEMENTARY SCHOOL	WS- 004753	8/20/2016	1	Fountain	In classroom 118	FT-72016-004753-A	< 1	FT-72016-004753-B	< 1
8	HEARST ELEMENTARY SCHOOL	WS- 004757	8/20/2016	1	Cooler	In hallway adjacent room 170 High Left	FT-72016-004757-A	< 1	FT-72016-004757-B	< 1
9	HEARST ELEMENTARY SCHOOL	WS- 004758	8/20/2016	1	Cooler	In hallway adjacent room 170 Low Right	FT-72016-004758-A	< 1	FT-72016-004758-B	< 1
10	HEARST ELEMENTARY SCHOOL	WS- 004760	8/20/2016	1	Fountain	In classroom 167 Right	FT-72016-004760-A	< 1	FT-72016-004760-B	< 1
11	HEARST ELEMENTARY SCHOOL	WS- 004762	8/20/2016	1	Fountain	In classroom 166	FT-72016-004762-A	< 1	FT-72016-004762-B	< 1
12	HEARST ELEMENTARY SCHOOL	WS- 004764	8/20/2016	1	Fountain	In classroom 165	FT-72016-004764-A	< 1	FT-72016-004764-B	< 1
13	HEARST ELEMENTARY SCHOOL	WS- 004766	8/20/2016	1	Fountain	In classroom 164 Right	FT-72016-004766-A	< 1	FT-72016-004766-B	< 1
14	HEARST ELEMENTARY SCHOOL	WS- 004768	8/20/2016	1	Fountain	In classroom 161	FT-72016-004768-A	< 1	FT-72016-004768-B	< 1
15	HEARST ELEMENTARY SCHOOL	WS- 004770	8/20/2016	1	Fountain	In classroom 160 Right	FT-72016-004770-A	< 1	FT-72016-004770-B	< 1
16	HEARST ELEMENTARY SCHOOL	WS- 004774	8/20/2016	Basement	Food Prep Sink	In kitchen on island Left	FT-82016-004774-A	< 1	FT-82016-004774-B	< 1
17	HEARST ELEMENTARY SCHOOL	WS- 004775	8/20/2016	Basement	Food Prep Sink	In kitchen on island Right	FT-82016-004775-A	< 1	FT-82016-004775-B	< 1
18	HEARST ELEMENTARY SCHOOL	WS- 004776	8/20/2016	Basement	Ice Maker	In kitchen (ice maker)	FT-82016-004776-A	< 1	FT-82016-004776-B	< 1
19	HEARST ELEMENTARY SCHOOL	WS- 004777	8/20/2016	Basement	Cooler	In gym Low Right	FT-72016-004777-A	< 1	FT-72016-004777-B	< 1
20	HEARST ELEMENTARY SCHOOL	WS- 004778	8/20/2016	Basement	Cooler	In gym High Left	FT-72016-004778-A	< 1	FT-72016-004778-B	< 1
21	HEARST ELEMENTARY SCHOOL	WS- 004782	8/20/2016	2	Fountain	In classroom 219 Left	FT-82016-004782-A	< 1	FT-82016-004782-B	< 1
22	HEARST ELEMENTARY SCHOOL	WS- 004784	8/20/2016	2	Fountain	In classroom 210	FT-72016-004784-A	< 1	FT-72016-004784-B	< 1
23	HEARST ELEMENTARY SCHOOL	WS- 004786	8/20/2016	2	Fountain	In classroom 214 Left	FT-82016-004786-A	< 1	FT-82016-004786-B	< 1
24	HEARST ELEMENTARY SCHOOL	WS- 004788	8/20/2016	2	Fountain	In classroom 218	FT-72016-004788-A	< 1	FT-72016-004788-B	< 1
25	HEARST ELEMENTARY SCHOOL	WS- 004790	8/20/2016	2	Fountain	In classroom 260	FT-72016-004790-A	< 1	FT-72016-004790-B	< 1
26	HEARST ELEMENTARY SCHOOL	WS- 004791	8/20/2016	2	Cooler	In hallway adjacent to room 220 High Left	FT-72016-004791-A	< 1	FT-72016-004791-B	< 1
27	HEARST ELEMENTARY SCHOOL	WS- 004792	8/20/2016	2	Cooler	In hallway adjacent to room 220 Low Right	FT-72016-004792-A	< 1	FT-72016-004792-B	< 1
28	HEARST ELEMENTARY SCHOOL	WS- 004794	8/20/2016	2	Fountain	In classroom 261	FT-72016-004794-A	< 1	FT-72016-004794-B	< 1
29	HEARST ELEMENTARY SCHOOL	WS- 004796	8/20/2016	2	Fountain	In classroom 264	FT-72016-004796-A	< 1	FT-72016-004796-B	< 1
30	HEARST ELEMENTARY SCHOOL	WS- 004798	8/20/2016	2	Fountain	In classroom 265 Right	FT-72016-004798-A	< 1	FT-72016-004798-B	< 1
31	HEARST ELEMENTARY SCHOOL	WS- 004800	8/20/2016	1	Cooler	In hallway entering building 2 High Left	FT-72016-004800-A	< 1	FT-72016-004800-B	< 1
32	HEARST ELEMENTARY SCHOOL	WS- 004801	8/20/2016	1	Cooler	In hallway entering building 2 Low Right	FT-72016-004801-A	< 1	FT-72016-004801-B	< 1