



HEARST LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004801	Cooler	1	In hallway entering building 2	Right	WT-042916-4818-A	< 1				
2	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004800	Fountain	1	In hallway entering building 2	High	WT-042916-4817-A	< 1				
3	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004799	Break Room	2	In 285		WT-042916-4816-A	< 1				
4	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004798	Fountain	2	In classroom 265	Right	WT-042916-4815-A	< 1				
5	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004797	Classroom	2	In classroom 265	Left	WT-042916-4814-A	< 1				2.97
6	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004796	Fountain	2	In room 264		WT-042916-4813-A	< 1				
7	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004795	Classroom	2	In room 264		WT-042916-4812-A	< 1				
8	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004794	Fountain	2	In room 261		WT-042916-4811-A	< 1				
9	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004793	Classroom	2	In room 261		WT-042916-4810-A	< 1				
10	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004792	Cooler	2	In hallway adjacent to room 220	Right Low	WT-042916-4809-A	< 1				
11	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004791	Cooler	2	In hallway adjacent to room 220	Left High	WT-042916-4808-A	< 1				
12	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004790	Fountain	2	In room 260		WT-042916-4807-A	< 1				
13	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004789	Classroom	2	In room 260		WT-042916-4806-A	< 1				
14	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004788	Fountain	2	In room 218		WT-042916-4805-A	< 1				
15	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004787	Classroom	2	In room 218		WT-042916-4804-A	6.98				
16	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004786	Fountain	2	In classroom 214	Left	WT-042916-4803-A	< 1				
17	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004785	Classroom	2	In classroom 214	Right	WT-042916-4802-A	< 1				
18	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004784	Fountain	2	In room 210		WT-042916-4801-A	< 1				
19	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004783	Classroom	2	In room 210		WT-042916-4800-A	< 1				
20	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004782	Fountain	2	In classroom 219	Left	WT-042916-4799-A	< 1				
21	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004781	Classroom	2	In classroom 219	Right	WT-042916-4798-A	1.51				
22	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004780	Break Room	2	In room 220 life skill		WT-042916-4797-A	< 1				
23	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004779	Break Room	2	In room 221		WT-042916-4796-A	< 1				
24	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004778	Cooler	Basement	In gymnasium	Left High	WT-042916-4795-A	< 1				
25	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004777	Cooler	Basement	In gymnasium	Right Low	WT-042916-4794-A	< 1				
26	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004776	Kitchen	Basement	Ice maker adjacent to storage 23A		WT-042916-4793-A	< 1				
27	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004775	Kitchen	Basement	West wall sink	Mid	WT-042916-4792-A	< 1				
28	HEARST ELEMENTARY SCHOOL	5/4/2016	WS-004774	Kitchen	Basement	West wall sink		WT-042916-4791-A	< 1				
29	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004773	Kitchen	Basement	East Walls sink	Right High	WT-042916-4790-A	< 1				
30	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004772	Kitchen	Basement	East wall sink	Left	WT-042916-4789-A	< 1				
31	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004771	Kitchen	Basement	Eats wall dishwasher		WT-042916-4788-A	< 1				
32	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004770	Fountain	1	In classroom 160	Right	WT-042916-4787-A	< 1				
33	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004769	Classroom	1	In classroom 160	Left	WT-042916-4786-A	< 1				
34	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004768	Fountain	1	In room 161		WT-042916-4785-A	< 1				
35	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004767	Classroom	1	In room 161		WT-042916-4784-A	< 1				
36	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004766	Fountain	1	In classroom 164	Right	WT-042916-4783-A	< 1				
37	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004765	Classroom	1	In classroom 164	Left	WT-042916-4782-A	< 1				
38	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004764	Fountain	1	In room 165		WT-042916-4781-A	< 1				
39	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004763	Classroom	1	In room 165		WT-042916-4780-A	1.09				
40	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004762	Fountain	1	In room 166		WT-042916-4779-A	< 1				
41	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004761	Classroom	1	In room 166		WT-042916-4778-A	< 1				
42	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004760	Fountain	1	In classroom 167	Right	WT-042916-4777-A	< 1				
43	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004759	Classroom	1	In classroom 167	Left	WT-042916-4776-A	< 1				
44	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004758	Cooler	1	Adjacent to room 170	Right	WT-042916-4775-A	< 1				
45	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004757	Cooler	1	In hallway adjacent room 170	Left	WT-042916-4774-A	< 1				
46	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004756	Classroom	1	In room 169		WT-042916-4773-A	< 1				
47	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004755	Classroom	1	In room 173	Right	WT-042916-4772-A	< 1				
48	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004754	Classroom	1	In classroom 173	Left	WT-042916-4771-A	< 1				
49	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004753	Fountain	1	In room 118		WT-042916-4770-A	< 1				
50	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004752	Classroom	1	In room 118		WT-042916-4769-A	< 1				
51	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004751	Fountain	1	In room 114		WT-042916-4768-A	< 1				
52	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004750	Classroom	1	In room 114		WT-042916-4767-A	< 1				
53	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004749	Classroom	1	In room 110		WT-042916-4766-A	< 1				
54	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004748	Classroom	1	In room 110		WT-042916-4765-A	< 1				
55	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004747	Fountain	1	In room 122		WT-042916-4764-A	< 1				
56	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004746	Classroom	1	In room 122		WT-042916-4763-A	< 1				
57	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004745	Health Suite	1	Fountain in exam room 2		WT-042916-4762-A	2.32				
58	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004744	Health Suite	1	Sink in exam room 2		WT-042916-4761-A	5.15				
59	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004743	Health Suite	1	Fountain in health suite		WT-042916-4760-A	< 1				
60	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004742	Health Suite	1	Sink in health suite		WT-042916-4759-A	< 1				
61	HEARST ELEMENTARY SCHOOL	5/5/2016	WS-004741	Utility	Basement	In basement		WT-042916-4758-A	88.5				

Non-drinking water source turned off until further analysis complete

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.