



Hearst ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004742	4/3/2018	4/3/2019	1	Health Suite	In health suite	WF-04032018-004742	10/28/2018	FT-FY19-102018-004742-A	< 1	FT-FY19-102018-004742-B	< 1
WS- 004743	4/3/2018	4/3/2019	1	Combo Fountain	In health suite	WF-04032018-004743	10/28/2018	FT-FY19-102018-004743-A	< 1	FT-FY19-102018-004743-B	< 1
WS- 004744	4/3/2018	4/3/2019	1	Health Suite	In health suite in exam room 2	WF-04032018-004744	10/28/2018	FT-FY19-102018-004744-A	< 1	FT-FY19-102018-004744-B	< 1
WS- 004745	4/3/2018	4/3/2019	1	Combo Fountain	In exam room 2 in health suite	WF-04032018-004745	10/28/2018	FT-FY19-102018-004745-A	< 1	FT-FY19-102018-004745-B	< 1
WS- 004746	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 122	WF-09252018-004746	10/28/2018	FT-FY19-102018-004746-A	< 1	FT-FY19-102018-004746-B	< 1
WS- 004747	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 122	WF-04032018-004747	10/28/2018	FT-FY19-102018-004747-A	< 1	FT-FY19-102018-004747-B	< 1
WS- 004748	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 110	WF-09252018-004748	10/28/2018	FT-FY19-102018-004748-A	< 1	FT-FY19-102018-004748-B	< 1
WS- 004749	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 110	WF-04032018-004749	10/28/2018	FT-FY19-102018-004749-A	< 1	FT-FY19-102018-004749-B	< 1
WS- 004750	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 114	WF-09252018-004750	10/28/2018	FT-FY19-102018-004750-A	< 1	FT-FY19-102018-004750-B	< 1
WS- 004751	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 114	WF-04032018-004751	10/28/2018	FT-FY19-102018-004751-A	< 1	FT-FY19-102018-004751-B	< 1
WS- 004752	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 118	WF-09252018-004752	10/28/2018	FT-FY19-102018-004752-A	< 1	FT-FY19-102018-004752-B	< 1
WS- 004753	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 118	WF-04032018-004753	10/28/2018	FT-FY19-102018-004753-A	< 1	FT-FY19-102018-004753-B	< 1
WS- 004754	9/25/2018	9/25/2019	1	Classroom Faucet	In art room 173	WF-09252018-004754	10/28/2018	FT-FY19-102018-004754-A	< 1	FT-FY19-102018-004754-B	< 1
WS- 004755	9/25/2018	9/25/2019	1	Classroom Faucet	In art room 173	WF-09252018-004755	10/28/2018	FT-FY19-102018-004755-A	< 1	FT-FY19-102018-004755-B	< 1
WS- 004756	9/25/2018	9/25/2019	1	Classroom Faucet	In parent resource room 169	WF-09252018-004756	10/28/2018	FT-FY19-102018-004756-A	< 1	FT-FY19-102018-004756-B	< 1
WS- 004757	4/3/2018	4/3/2019	1	Cooler	In hallway adjacent room 170	WF-04032018-004757	10/28/2018	FT-FY19-102018-004757-A	< 1	FT-FY19-102018-004757-B	< 1
WS- 004758	4/3/2018	4/3/2019	1	Cooler	In hallway adjacent room 170	WF-04032018-004758	10/28/2018	FT-FY19-102018-004758-A	< 1	FT-FY19-102018-004758-B	< 1
WS- 004759	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 167	WF-09252018-004759	10/28/2018	FT-FY19-102018-004759-A	< 1	FT-FY19-102018-004759-B	< 1
WS- 004760	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 167	WF-04032018-004760	10/28/2018	FT-FY19-102018-004760-A	< 1	FT-FY19-102018-004760-B	< 1
WS- 004761	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 166	WF-09252018-004761	10/28/2018	FT-FY19-102018-004761-A	< 1	FT-FY19-102018-004761-B	< 1
WS- 004762	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 166	WF-04032018-004762	10/28/2018	FT-FY19-102018-004762-A	< 1	FT-FY19-102018-004762-B	< 1
WS- 004763	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 165	WF-09252018-004763	10/28/2018	FT-FY19-102018-004763-A	< 1	FT-FY19-102018-004763-B	< 1
WS- 004764	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 165	WF-04032018-004764	10/28/2018	FT-FY19-102018-004764-A	< 1	FT-FY19-102018-004764-B	< 1
WS- 004765	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 164	WF-09252018-004765	10/28/2018	FT-FY19-102018-004765-A	< 1	FT-FY19-102018-004765-B	< 1
WS- 004766	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 164	WF-04032018-004766	10/28/2018	FT-FY19-102018-004766-A	< 1	FT-FY19-102018-004766-B	< 1
WS- 004767	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 161	WF-09252018-004767	10/28/2018	FT-FY19-102018-004767-A	< 1	FT-FY19-102018-004767-B	< 1
WS- 004768	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 161	WF-04032018-004768	10/28/2018	FT-FY19-102018-004768-A	< 1	FT-FY19-102018-004768-B	< 1
WS- 004769	9/25/2018	9/25/2019	1	Combo Faucet	In classroom 160	WF-09252018-004769	10/28/2018	FT-FY19-102018-004769-A	< 1	FT-FY19-102018-004769-B	< 1
WS- 004770	4/3/2018	4/3/2019	1	Combo Fountain	In classroom 160	WF-04032018-004770	10/28/2018	FT-FY19-102018-004770-A	< 1	FT-FY19-102018-004770-B	< 1
WS- 004776	4/3/2018	4/3/2019	Basement	Ice Maker	In kitchen (ice maker)	WF-04032018-004776	10/28/2018	FT-FY19-102018-004776-A	< 1	FT-FY19-102018-004776-B	< 1
WS- 004777	4/3/2018	4/3/2019	Basement	Cooler	In gym	WF-04032018-004777	10/28/2018	FT-FY19-102018-004777-A	< 1	FT-FY19-102018-004777-B	< 1
WS- 004778	4/3/2018	4/3/2019	Basement	Cooler	In gym	WF-04032018-004778	10/28/2018	FT-FY19-102018-004778-A	< 1	FT-FY19-102018-004778-B	< 1
WS- 004779	4/3/2018	4/3/2019	2	Break Room	In teacher work room 221	WF-04032018-004779	10/28/2018	FT-FY19-102018-004779-A	< 1	FT-FY19-102018-004779-B	< 1
WS- 004781	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 219	WF-09252018-004781	10/28/2018	FT-FY19-102018-004781-A	< 1	FT-FY19-102018-004781-B	< 1
WS- 004782	4/3/2018	4/3/2019	2	Combo Fountain	In classroom 219	WF-04032018-004782	10/28/2018	FT-FY19-102018-004782-A	< 1	FT-FY19-102018-004782-B	< 1
WS- 004783	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 210	WF-09252018-004783	10/28/2018	FT-FY19-102018-004783-A	< 1	FT-FY19-102018-004783-B	< 1

WS- 004784	4/3/2018	4/3/2019	2	Combo Fountain	In classroom 210		WF-04032018-004784	10/28/2018	FT-FY19-102018-004784-A	< 1	FT-FY19-102018-004784-B	< 1
WS- 004785	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 214	Right	WF-09252018-004785	10/28/2018	FT-FY19-102018-004785-A	< 1	FT-FY19-102018-004785-B	< 1
WS- 004786	4/3/2018	4/3/2019	2	Combo Fountain	In classroom 214	Left	WF-04032018-004786	10/28/2018	FT-FY19-102018-004786-A	< 1	FT-FY19-102018-004786-B	< 1
WS- 004787	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 218		WF-09252018-004787	10/28/2018	FT-FY19-102018-004787-A	< 1	FT-FY19-102018-004787-B	< 1
WS- 004788	4/3/2018	4/3/2019	2	Combo Fountain	In classroom 218		WF-04032018-004788	10/28/2018	FT-FY19-102018-004788-A	< 1	FT-FY19-102018-004788-B	< 1
WS- 004789	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 260		WF-09252018-004789	10/28/2018	FT-FY19-102018-004789-A	< 1	FT-FY19-102018-004789-B	< 1
WS- 004790	4/3/2018	4/3/2019	2	Combo Fountain	In classroom 260		WF-04032018-004790	10/28/2018	FT-FY19-102018-004790-A	< 1	FT-FY19-102018-004790-B	< 1
WS- 004791	4/3/2018	4/3/2019	2	Cooler	In entrance to boy/girl restroom near room 220	High Left	WF-04032018-004791	10/28/2018	FT-FY19-102018-004791-A	< 1	FT-FY19-102018-004791-B	< 1
WS- 004792	4/3/2018	4/3/2019	2	Cooler	In entrance to boy/girl restroom near room 220	Low Right	WF-04032018-004792	10/28/2018	FT-FY19-102018-004792-A	< 1	FT-FY19-102018-004792-B	< 1
WS- 004793	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 261		WF-09252018-004793	10/28/2018	FT-FY19-102018-004793-A	< 1	FT-FY19-102018-004793-B	< 1
WS- 004794	4/3/2018	4/3/2019	2	Combo Fountain	In classroom 261		WF-04032018-004794	10/28/2018	FT-FY19-102018-004794-A	< 1	FT-FY19-102018-004794-B	< 1
WS- 004795	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 264		WF-09252018-004795	10/28/2018	FT-FY19-102018-004795-A	< 1	FT-FY19-102018-004795-B	< 1
WS- 004796	4/3/2018	4/3/2019	2	Combo Fountain	In classroom 264		WF-04032018-004796	10/28/2018	FT-FY19-102018-004796-A	< 1	FT-FY19-102018-004796-B	< 1
WS- 004797	9/25/2018	9/25/2019	2	Combo Faucet	In classroom 265	Left	WF-09252018-004797	10/28/2018	FT-FY19-102018-004797-A	< 1	FT-FY19-102018-004797-B	< 1
WS- 004798	4/3/2018	4/3/2019	2	Combo Fountain	In classroom 265	Right	WF-04032018-004798	10/28/2018	FT-FY19-102018-004798-A	< 1	FT-FY19-102018-004798-B	< 1
WS- 004799	4/3/2018	4/3/2019	2	Break Room	In teacher work room 285		WF-04032018-004799	10/28/2018	FT-FY19-102018-004799-A	< 1	FT-FY19-102018-004799-B	< 1
WS- 004800	4/3/2018	4/3/2019	1	Cooler	In entrance to boy/girl restroom near main lobby	High Left	WF-04032018-004800	10/28/2018	FT-FY19-102018-004800-A	< 1	FT-FY19-102018-004800-B	< 1
WS- 004801	4/3/2018	4/3/2019	1	Cooler	In entrance to boy/girl restroom near main lobby	Low Right	WF-04032018-004801	10/28/2018	FT-FY19-102018-004801-A	< 1	FT-FY19-102018-004801-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004774	Basement	Food Prep Sink	In kitchen on island		Left	10/28/2018	FT-FY19-102018-004774-A	< 1	FT-FY19-102018-004774-B	< 1
WS- 004775	Basement	Food Prep Sink	In kitchen on island		Right	10/28/2018	FT-FY19-102018-004775-A	< 1	FT-FY19-102018-004775-B	< 1