



# Hendley ES Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002696	3/18/2025	3/18/2026	1	Bottle Filler	In hallway adjacent to resource room 109	WF-03182025-002696	12/11/2025	FT-FY26-12012025-002696-A	<2	FT-FY26-12012025-002696-B	<2	
WS-002802	3/18/2025	3/18/2026	Ground Floor	Cooler	In cafeteria	WF-03182025-002802	12/11/2025	FT-FY26-12012025-002802-A	<2	FT-FY26-12012025-002802-B	<2	
WS-002803	3/18/2025	3/18/2026	Ground Floor	Cooler	In hallway adjacent to room G10	WF-03182025-002803	12/11/2025	FT-FY26-12012025-002803-A	<2	FT-FY26-12012025-002803-B	<2	
WS-002804	7/28/2025	7/28/2026	Ground Floor	Combo Faucet	In classroom G11	WF-07282025-002804	12/11/2025	FT-FY26-12012025-002804-A	<2	FT-FY26-12012025-002804-B	<2	
WS-002805	3/18/2025	3/18/2026	Ground Floor	Combo Fountain	In classroom G11	WF-03182025-002805	12/11/2025	FT-FY26-12012025-002805-A	<2	FT-FY26-12012025-002805-B	<2	
WS-002806	7/28/2025	7/28/2026	Ground Floor	Combo Faucet	In classroom G13	WF-07282025-002806	12/11/2025	FT-FY26-12012025-002806-A	<2	FT-FY26-12012025-002806-B	<2	
WS-002807	3/18/2025	3/18/2026	Ground Floor	Combo Fountain	In classroom G13	WF-03182025-002807	12/11/2025	FT-FY26-12012025-002807-A	<2	FT-FY26-12012025-002807-B	<2	
WS-002808	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 110	WF-07282025-002808	12/11/2025	FT-FY26-12012025-002808-A	<2	FT-FY26-12012025-002808-B	<2	
WS-002809	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 110	WF-03182025-002809	12/11/2025	FT-FY26-12012025-002809-A	<2	FT-FY26-12012025-002809-B	<2	
WS-002810	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 108	Left	WF-03182025-002810	12/11/2025	FT-FY26-12012025-002810-A	<2	FT-FY26-12012025-002810-B	<2
WS-002811	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 108	Right	WF-07282025-002811	12/11/2025	FT-FY26-12012025-002811-A	<2	FT-FY26-12012025-002811-B	<2
WS-002812	7/28/2025	7/28/2026	1	Combo Faucet	In classroom 107		WF-07282025-002812	12/11/2025	FT-FY26-12012025-002812-A	<2	FT-FY26-12012025-002812-B	<2
WS-002813	3/18/2025	3/18/2026	1	Combo Fountain	In classroom 107		WF-03182025-002813	12/11/2025	FT-FY26-12012025-002813-A	<2	FT-FY26-12012025-002813-B	<2
WS-002814	3/18/2025	3/18/2026	1	Break Room	In break room 105		WF-03182025-002814	12/11/2025	FT-FY26-12012025-002814-A	<2	FT-FY26-12012025-002814-B	<2
WS-002816	3/18/2025	3/18/2026	1	Health Suite	In health suite 104		WF-03182025-002816	12/11/2025	FT-FY26-12012025-002816-A	<2	FT-FY26-12012025-002816-B	<2
WS-002820	3/18/2025	3/18/2026	1	Cooler	In hallway adjacent to resource room 109		WF-03182025-002820	12/11/2025	FT-FY26-12012025-002820-A	<2	FT-FY26-12012025-002820-B	<2
WS-002821	3/18/2025	3/18/2026	2	Cooler	In hallway adjacent to girls' restroom	High Left	WF-03182025-002821	12/11/2025	FT-FY26-12012025-002821-A	<2	FT-FY26-12012025-002821-B	<2
WS-002822	3/18/2025	3/18/2026	2	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-03182025-002822	12/11/2025	FT-FY26-12012025-002822-A	<2	FT-FY26-12012025-002822-B	<2
WS-002823	3/18/2025	3/18/2026	2	Cooler	In hallway adjacent to room 201	Low Right	WF-03182025-002823	12/11/2025	FT-FY26-12012025-002823-A	<2	FT-FY26-12012025-002823-B	<2
WS-002824	3/18/2025	3/18/2026	2	Cooler	In hallway adjacent to room 201	High Left	WF-03182025-002824	12/11/2025	FT-FY26-12012025-002824-A	<2	FT-FY26-12012025-002824-B	<2
WS-002826	3/18/2025	3/18/2026	3	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-03182025-002826	12/11/2025	FT-FY26-12012025-002826-A	<2	FT-FY26-12012025-002826-B	<2
WS-002828	3/18/2025	3/18/2026	3	Cooler	In hallway adjacent to boys' restroom	Low Right	WF-03182025-002828	12/11/2025	FT-FY26-12012025-002828-A	<2	FT-FY26-12012025-002828-B	<2
WS-002829	3/18/2025	3/18/2026	Ground Floor	Cooler	Annex, in hallway adjacent to classroom G17		WF-03182025-002829	12/11/2025	FT-FY26-12012025-002829-A	<2	FT-FY26-12012025-002829-B	<2
WS-002830	7/28/2025	7/28/2026	Ground Floor	Combo Faucet	Annex, in classroom G17		WF-07282025-002830	12/11/2025	FT-FY26-12012025-002830-A	<2	FT-FY26-12012025-002830-B	<2
WS-002831	3/18/2025	3/18/2026	Ground Floor	Combo Fountain	Annex, in classroom G17		WF-03182025-002831	12/11/2025	FT-FY26-12012025-002831-A	2.2	FT-FY26-12012025-002831-B	<2
WS-002832	3/18/2025	3/18/2026	Ground Floor	Combo Fountain	Annex, in classroom G16		WF-03182025-002832	12/11/2025	FT-FY26-12012025-002832-A	<2	FT-FY26-12012025-002832-B	<2
WS-002833	7/28/2025	7/28/2026	Ground Floor	Combo Faucet	Annex, in classroom G16		WF-07282025-002833	12/11/2025	FT-FY26-12012025-002833-A	<2	FT-FY26-12012025-002833-B	<2
WS-002834	3/18/2025	3/18/2026	Ground Floor	Combo Fountain	Annex, in classroom G14		WF-03182025-002834	12/11/2025	FT-FY26-12012025-002834-A	<2	FT-FY26-12012025-002834-B	<2
WS-002835	7/28/2025	7/28/2026	Ground Floor	Combo Faucet	Annex, in classroom G14		WF-07282025-002835	12/11/2025	FT-FY26-12012025-002835-A	<2	FT-FY26-12012025-002835-B	<2
WS-002836	7/28/2025	7/28/2026	Ground Floor	Combo Faucet	Annex, in music room G15		WF-07282025-002836	12/11/2025	FT-FY26-12012025-002836-A	<2	FT-FY26-12012025-002836-B	<2
WS-002837	3/18/2025	3/18/2026	Ground Floor	Combo Fountain	Annex, in music room G15		WF-03182025-002837	12/11/2025	FT-FY26-12012025-002837-A	<2	FT-FY26-12012025-002837-B	<2
WS-002838	3/18/2025	3/18/2026	1	Cooler	Annex, in hallway adjacent to staff restroom		WF-03182025-002838	12/11/2025	FT-FY26-12012025-002838-A	<2	FT-FY26-12012025-002838-B	<2
WS-002839	7/28/2025	7/28/2026	1	Combo Faucet	Annex, in classroom 118 first clockwise from entry door	Right	WF-07282025-002839	12/11/2025	FT-FY26-12012025-002839-A	<2	FT-FY26-12012025-002839-B	<2
WS-002840	3/18/2025	3/18/2026	1	Combo Fountain	Annex, in classroom 118 second clockwise from entry door	Right	WF-03182025-002840	12/11/2025	FT-FY26-12012025-002840-A	<2	FT-FY26-12012025-002840-B	<2

WS- 002841	7/28/2025	7/28/2026	1	Combo Faucet	Annex, in classroom 118 third clockwise from entry door	Left	WF-07282025-002841	12/11/2025	FT-FY26-12012025-002841-A	<2	FT-FY26-12012025-002841-B	<2
WS- 002842	3/18/2025	3/18/2026	1	Combo Fountain	Annex, in classroom 118 fourth clockwise from entry door	Right	WF-03182025-002842	12/11/2025	FT-FY26-12012025-002842-A	<2	FT-FY26-12012025-002842-B	<2
WS- 002844	7/28/2025	7/28/2026	1	Combo Faucet	Annex, in classroom 118 sixth clockwise from entry door		WF-07282025-002844	12/11/2025	FT-FY26-12012025-002844-A	<2	FT-FY26-12012025-002844-B	<2

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002800	11/25/2025	11/25/2026	Ground Floor	Food Prep Sink	In kitchen on north wall	WF-11252025-002800	12/11/2025	FT-FY26-12012025-002800-A	<2	FT-FY26-12012025-002800-B	<2
WS- 002801	11/25/2025	11/25/2026	Ground Floor	Food Prep Sink	In kitchen on south wall	WF-11252025-002801	12/11/2025	FT-FY26-12012025-002801-A	<2	FT-FY26-12012025-002801-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.