



Hendley Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002803	4/12/2021	4/12/2022	Ground Floor	Cooler	In hallway adjacent to room G10	WF-04122021-002803	2/11/2022	FT-FY22-01182022-002803-A	<1	FT-FY22-01182022-002803-B	<1	
WS-002804	8/25/2021	8/25/2022	Ground Floor	Combo Faucet	In classroom G11	WF-08252021-002804	2/11/2022	FT-FY22-01182022-002804-A	1.4	FT-FY22-01182022-002804-B	<1	
WS-002805	4/12/2021	4/12/2022	Ground Floor	Combo Fountain	In classroom G11	WF-04122021-002805	2/11/2022	FT-FY22-01182022-002805-A	1.1	FT-FY22-01182022-002805-B	<1	
WS-002806	8/25/2021	8/25/2022	Ground Floor	Combo Faucet	In classroom G13	WF-08252021-002806	2/11/2022	FT-FY22-01182022-002806-A	<1	FT-FY22-01182022-002806-B	<1	
WS-002807	4/12/2021	4/12/2022	Ground Floor	Combo Fountain	In classroom G13	WF-04122021-002807	2/11/2022	FT-FY22-01182022-002807-A	<1	FT-FY22-01182022-002807-B	<1	
WS-002808	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 110	WF-08252021-002808	2/11/2022	FT-FY22-01182022-002808-A	<1	FT-FY22-01182022-002808-B	<1	
WS-002809	4/12/2021	4/12/2022	1	Combo Fountain	In classroom 110	WF-04122021-002809	2/11/2022	FT-FY22-01182022-002809-A	<1	FT-FY22-01182022-002809-B	<1	
WS-002810	4/12/2021	4/12/2022	1	Combo Fountain	In classroom 108	Left	WF-04122021-002810	2/11/2022	FT-FY22-01182022-002810-A	1.7	FT-FY22-01182022-002810-B	<1
WS-002811	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 108	Right	WF-08252021-002811	2/11/2022	FT-FY22-01182022-002811-A	<1	FT-FY22-01182022-002811-B	<1
WS-002812	8/25/2021	8/25/2022	1	Combo Faucet	In classroom 107		WF-08252021-002812	2/11/2022	FT-FY22-01182022-002812-A	1.7	FT-FY22-01182022-002812-B	<1
WS-002813	4/12/2021	4/12/2022	1	Combo Fountain	In classroom 107		WF-04122021-002813	2/11/2022	FT-FY22-01182022-002813-A	<1	FT-FY22-01182022-002813-B	<1
WS-002816	4/12/2021	4/12/2022	1	Health Suite	In health suite 104		WF-04122021-002816	2/11/2022	FT-FY22-01182022-002816-A	<1	FT-FY22-01182022-002816-B	<1
WS-002822	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-04122021-002822	2/11/2022	FT-FY22-01182022-002822-A	<1	FT-FY22-01182022-002822-B	<1
WS-002823	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to room 201	Low Right	WF-04122021-002823	2/11/2022	FT-FY22-01182022-002823-A	<1	FT-FY22-01182022-002823-B	<1
WS-002824	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to room 201	High Left	WF-04122021-002824	2/11/2022	FT-FY22-01182022-002824-A	<1	FT-FY22-01182022-002824-B	<1
WS-002825	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to girls' restroom	High Left	WF-04122021-002825	2/11/2022	FT-FY22-01182022-002825-A	<1	FT-FY22-01182022-002825-B	<1
WS-002826	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-04122021-002826	2/11/2022	FT-FY22-01182022-002826-A	<1	FT-FY22-01182022-002826-B	<1
WS-002827	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to boys' restroom	High Left	WF-04122021-002827	2/11/2022	FT-FY22-01182022-002827-A	<1	FT-FY22-01182022-002827-B	<1
WS-002828	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to boys' restroom	Low Right	WF-04122021-002828	2/11/2022	FT-FY22-01182022-002828-A	<1	FT-FY22-01182022-002828-B	<1
WS-002830	8/25/2021	8/25/2022	Ground Floor	Combo Faucet	Annex, in classroom G17		WF-08252021-002830	2/11/2022	FT-FY22-01182022-002830-A	<1	FT-FY22-01182022-002830-B	<1
WS-002831	4/12/2021	4/12/2022	Ground Floor	Combo Fountain	Annex, in classroom G17		WF-04122021-002831	2/11/2022	FT-FY22-01182022-002831-A	<1	FT-FY22-01182022-002831-B	<1
WS-002832	4/12/2021	4/12/2022	Ground Floor	Combo Fountain	Annex, in classroom G16		WF-04122021-002832	2/11/2022	FT-FY22-01182022-002832-A	<1	FT-FY22-01182022-002832-B	<1
WS-002833	8/25/2021	8/25/2022	Ground Floor	Combo Faucet	Annex, in classroom G16		WF-08252021-002833	2/11/2022	FT-FY22-01182022-002833-A	<1	FT-FY22-01182022-002833-B	<1
WS-002834	4/12/2021	4/12/2022	Ground Floor	Combo Fountain	Annex, in classroom G14		WF-04122021-002834	2/11/2022	FT-FY22-01182022-002834-A	1.0	FT-FY22-01182022-002834-B	<1
WS-002835	8/25/2021	8/25/2022	Ground Floor	Combo Faucet	Annex, in classroom G14		WF-08252021-002835	2/11/2022	FT-FY22-01182022-002835-A	<1	FT-FY22-01182022-002835-B	<1
WS-002836	8/25/2021	8/25/2022	Ground Floor	Combo Faucet	Annex, in music room G15		WF-08252021-002836	2/11/2022	FT-FY22-01182022-002836-A	<1	FT-FY22-01182022-002836-B	<1
WS-002839	8/25/2021	8/25/2022	1	Combo Faucet	Annex, in classroom 118 first clockwise from entry door	Right	WF-08252021-002839	2/11/2022	FT-FY22-01182022-002839-A	<1	FT-FY22-01182022-002839-B	<1
WS-002840	4/12/2021	4/12/2022	1	Combo Fountain	Annex, in classroom 118 second clockwise from entry door	Right	WF-04122021-002840	2/11/2022	FT-FY22-01182022-002840-A	<1	FT-FY22-01182022-002840-B	<1
WS-002841	8/25/2021	8/25/2022	1	Combo Faucet	Annex, in classroom 118 third clockwise from entry door	Left	WF-08252021-002841	2/11/2022	FT-FY22-01182022-002841-A	<1	FT-FY22-01182022-002841-B	<1
WS-002842	4/12/2021	4/12/2022	1	Combo Fountain	Annex, in classroom 118 fourth clockwise from entry door	Right	WF-04122021-002842	2/11/2022	FT-FY22-01182022-002842-A	<1	FT-FY22-01182022-002842-B	<1
WS-002843	4/12/2021	4/12/2022	1	Combo Fountain	Annex, in classroom 118 fifth clockwise from entry door		WF-04122021-002843	2/11/2022	FT-FY22-01182022-002843-A	<1	FT-FY22-01182022-002843-B	<1
WS-002844	8/25/2021	8/25/2022	1	Combo Faucet	Annex, in classroom 118 sixth clockwise from entry door		WF-08252021-002844	2/11/2022	FT-FY22-01182022-002844-A	<1	FT-FY22-01182022-002844-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002801	2/17/2021	2/17/2022	Ground Floor	Food Prep Sink	In kitchen on south wall	WF-02172021-002801	2/11/2022	FT-FY22-01182022-002801-A	<1	FT-FY22-01182022-002801-B	<1

FY22 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002800	2/17/2021	2/17/2022	Ground Floor	Food Prep Sink	In kitchen on north wall	WF-02172021-002800	2/11/2022	FT-FY22-01182022-002800-A	6.6	FT-FY22-01182022-002800-B	<1
WS-002837	4/12/2021	4/12/2022	Ground Floor	Combo Fountain	Annex, in music room G15	WF-04122021-002837	2/11/2022	FT-FY22-01182022-002837-A	5.5	FT-FY22-01182022-002837-B	<1