



Hendley Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002696	3/25/2024	3/25/2025	1	Bottle Filler	In hallway adjacent to resource room 109	WF-03252024-002696	2/6/2025	FT-FY25-12262024-002696-A	<2	FT-FY25-12262024-002696-B	<2	
WS-002802	3/25/2024	3/25/2025	Ground Floor	Cooler	In cafeteria	WF-03252024-002802	2/6/2025	FT-FY25-12262024-002802-A	<2	FT-FY25-12262024-002802-B	<2	
WS-002803	3/25/2024	3/25/2025	Ground Floor	Cooler	In hallway adjacent to room G10	WF-03252024-002803	2/6/2025	FT-FY25-12262024-002803-A	<2	FT-FY25-12262024-002803-B	<2	
WS-002804	8/5/2024	8/5/2025	Ground Floor	Combo Faucet	In classroom G11	WF-08052024-002804	2/6/2025	FT-FY25-12262024-002804-A	<2	FT-FY25-12262024-002804-B	<2	
WS-002805	3/25/2024	3/25/2025	Ground Floor	Combo Fountain	In classroom G11	WF-03252024-002805	2/6/2025	FT-FY25-12262024-002805-A	<2	FT-FY25-12262024-002805-B	<2	
WS-002806	8/5/2024	8/5/2025	Ground Floor	Combo Faucet	In classroom G13	WF-08052024-002806	2/6/2025	FT-FY25-12262024-002806-A	<2	FT-FY25-12262024-002806-B	<2	
WS-002807	3/25/2024	3/25/2025	Ground Floor	Combo Fountain	In classroom G13	WF-03252024-002807	2/6/2025	FT-FY25-12262024-002807-A	<2	FT-FY25-12262024-002807-B	<2	
WS-002808	8/5/2024	8/5/2025	1	Combo Faucet	In classroom 110	WF-08052024-002808	2/6/2025	FT-FY25-12262024-002808-A	<2	FT-FY25-12262024-002808-B	<2	
WS-002809	3/25/2024	3/25/2025	1	Combo Fountain	In classroom 110	WF-03252024-002809	2/6/2025	FT-FY25-12262024-002809-A	<2	FT-FY25-12262024-002809-B	<2	
WS-002810	3/25/2024	3/25/2025	1	Combo Fountain	In classroom 108	Left	WF-03252024-002810	2/6/2025	FT-FY25-12262024-002810-A	<2	FT-FY25-12262024-002810-B	<2
WS-002811	8/5/2024	8/5/2025	1	Combo Faucet	In classroom 108	Right	WF-08052024-002811	2/6/2025	FT-FY25-12262024-002811-A	<2	FT-FY25-12262024-002811-B	<2
WS-002812	8/5/2024	8/5/2025	1	Combo Faucet	In classroom 107		WF-08052024-002812	2/6/2025	FT-FY25-12262024-002812-A	<2	FT-FY25-12262024-002812-B	<2
WS-002813	3/25/2024	3/25/2025	1	Combo Fountain	In classroom 107		WF-03252024-002813	2/6/2025	FT-FY25-12262024-002813-A	<2	FT-FY25-12262024-002813-B	<2
WS-002814	3/25/2024	3/25/2025	1	Break Room	In break room 105		WF-03252024-002814	2/6/2025	FT-FY25-12262024-002814-A	<2	FT-FY25-12262024-002814-B	<2
WS-002816	3/25/2024	3/25/2025	1	Health Suite	In health suite 104		WF-03252024-002816	2/6/2025	FT-FY25-12262024-002816-A	<2	FT-FY25-12262024-002816-B	<2
WS-002820	3/25/2024	3/25/2025	1	Cooler	In hallway adjacent to resource room 109		WF-03252024-002820	2/6/2025	FT-FY25-12262024-002820-A	<2	FT-FY25-12262024-002820-B	<2
WS-002821	3/25/2024	3/25/2025	2	Cooler	In hallway adjacent to girls' restroom	High Left	WF-03252024-002821	2/6/2025	FT-FY25-12262024-002821-A	<2	FT-FY25-12262024-002821-B	<2
WS-002822	3/25/2024	3/25/2025	2	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-03252024-002822	2/6/2025	FT-FY25-12262024-002822-A	<2	FT-FY25-12262024-002822-B	<2
WS-002823	3/25/2024	3/25/2025	2	Cooler	In hallway adjacent to room 201	Low Right	WF-03252024-002823	2/6/2025	FT-FY25-12262024-002823-A	<2	FT-FY25-12262024-002823-B	<2
WS-002825	3/25/2024	3/25/2025	3	Cooler	In hallway adjacent to girls' restroom	High Left	WF-03252024-002825	2/6/2025	FT-FY25-12262024-002825-A	<2	FT-FY25-12262024-002825-B	<2
WS-002829	3/25/2024	3/25/2025	Ground Floor	Cooler	Annex, in hallway adjacent to classroom G17		WF-03252024-002829	2/6/2025	FT-FY25-12262024-002829-A	<2	FT-FY25-12262024-002829-B	<2
WS-002830	8/5/2024	8/5/2025	Ground Floor	Combo Faucet	Annex, in classroom G17		WF-08052024-002830	2/6/2025	FT-FY25-12262024-002830-A	<2	FT-FY25-12262024-002830-B	<2
WS-002831	3/25/2024	3/25/2025	Ground Floor	Combo Fountain	Annex, in classroom G17		WF-03252024-002831	2/6/2025	FT-FY25-12262024-002831-A	<2	FT-FY25-12262024-002831-B	<2
WS-002832	3/25/2024	3/25/2025	Ground Floor	Combo Fountain	Annex, in classroom G16		WF-03252024-002832	2/6/2025	FT-FY25-12262024-002832-A	<2	FT-FY25-12262024-002832-B	<2
WS-002833	8/5/2024	8/5/2025	Ground Floor	Combo Faucet	Annex, in classroom G16		WF-08052024-002833	2/6/2025	FT-FY25-12262024-002833-A	<2	FT-FY25-12262024-002833-B	<2
WS-002834	3/25/2024	3/25/2025	Ground Floor	Combo Fountain	Annex, in classroom G14		WF-03252024-002834	2/6/2025	FT-FY25-12262024-002834-A	<2	FT-FY25-12262024-002834-B	<2
WS-002835	8/5/2024	8/5/2025	Ground Floor	Combo Faucet	Annex, in classroom G14		WF-08052024-002835	2/6/2025	FT-FY25-12262024-002835-A	<2	FT-FY25-12262024-002835-B	<2
WS-002836	8/5/2024	8/5/2025	Ground Floor	Combo Faucet	Annex, in music room G15		WF-08052024-002836	2/6/2025	FT-FY25-12262024-002836-A	<2	FT-FY25-12262024-002836-B	<2
WS-002837	3/25/2024	3/25/2025	Ground Floor	Combo Fountain	Annex, in music room G15		WF-03252024-002837	2/6/2025	FT-FY25-12262024-002837-A	<2	FT-FY25-12262024-002837-B	<2
WS-002838	3/25/2024	3/25/2025	1	Cooler	Annex, in hallway adjacent to staff restroom		WF-03252024-002838	2/6/2025	FT-FY25-12262024-002838-A	<2	FT-FY25-12262024-002838-B	<2
WS-002839	8/5/2024	8/5/2025	1	Combo Faucet	Annex, in classroom 118 first clockwise from entry door	Right	WF-08052024-002839	2/6/2025	FT-FY25-12262024-002839-A	<2	FT-FY25-12262024-002839-B	<2
WS-002840	3/25/2024	3/25/2025	1	Combo Fountain	Annex, in classroom 118 second clockwise from entry door	Right	WF-03252024-002840	2/6/2025	FT-FY25-12262024-002840-A	<2	FT-FY25-12262024-002840-B	<2
WS-002841	8/5/2024	8/5/2025	1	Combo Faucet	Annex, in classroom 118 third clockwise from entry door	Left	WF-08052024-002841	2/6/2025	FT-FY25-12262024-002841-A	<2	FT-FY25-12262024-002841-B	<2
WS-002842	3/25/2024	3/25/2025	1	Combo Fountain	Annex, in classroom 118 fourth clockwise from entry door	Right	WF-03252024-002842	2/6/2025	FT-FY25-12262024-002842-A	<2	FT-FY25-12262024-002842-B	<2

WS- 002843	3/25/2024	3/25/2025	1	Combo Fountain	Annex, in classroom 118 fifth clockwise from entry door	WF-03252024-002843	2/6/2025	FT-FY25-12262024-002843-A	<2	FT-FY25-12262024-002843-B	<2
WS- 002844	8/5/2024	8/5/2025	1	Combo Faucet	Annex, in classroom 118 sixth clockwise from entry door	WF-08052024-002844	2/6/2025	FT-FY25-12262024-002844-A	<2	FT-FY25-12262024-002844-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002800	12/16/2024	12/16/2025	Ground Floor	Food Prep Sink	In kitchen on north wall	WF-12162024-002800	2/6/2025	FT-FY25-12262024-002800-A	<2	FT-FY25-12262024-002800-B	<2
WS- 002801	12/16/2024	12/16/2025	Ground Floor	Food Prep Sink	In kitchen on south wall	WF-12162024-002801	2/6/2025	FT-FY25-12262024-002801-A	<2	FT-FY25-12262024-002801-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.