



# Hendley ES Lead Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002802	5/22/2019	5/22/2020	Ground Floor	Cooler	In cafeteria	WF-05222019-002802	10/24/2019	FT-FY20-102019-002802-A	<1	FT-FY20-102019-002802-B	<1
WS-002803	5/22/2019	5/22/2020	Ground Floor	Cooler	In hallway adjacent to room G10	WF-05222019-002803	10/24/2019	FT-FY20-102019-002803-A	<1	FT-FY20-102019-002803-B	<1
WS-002804	9/11/2019	9/11/2020	Ground Floor	Combo Faucet	In classroom G11	WF-09112019-002804	10/24/2019	FT-FY20-102019-002804-A	<1	FT-FY20-102019-002804-B	<1
WS-002805	5/22/2019	5/22/2020	Ground Floor	Combo Fountain	In classroom G11	WF-05222019-002805	10/24/2019	FT-FY20-102019-002805-A	<1	FT-FY20-102019-002805-B	<1
WS-002806	9/11/2019	9/11/2020	Ground Floor	Combo Faucet	In classroom G13	WF-09112019-002806	10/24/2019	FT-FY20-102019-002806-A	<1	FT-FY20-102019-002806-B	<1
WS-002807	5/22/2019	5/22/2020	Ground Floor	Combo Fountain	In classroom G13	WF-05222019-002807	10/24/2019	FT-FY20-102019-002807-A	<1	FT-FY20-102019-002807-B	<1
WS-002808	9/11/2019	9/11/2020	1	Combo Faucet	In classroom 110	WF-09112019-002808	10/24/2019	FT-FY20-102019-002808-A	<1	FT-FY20-102019-002808-B	<1
WS-002809	5/22/2019	5/22/2020	1	Combo Fountain	In classroom 110	WF-05222019-002809	10/24/2019	FT-FY20-102019-002809-A	<1	FT-FY20-102019-002809-B	<1
WS-002810	5/22/2019	5/22/2020	1	Combo Fountain	In classroom 108	Left WF-05222019-002810	10/24/2019	FT-FY20-102019-002810-A	<1	FT-FY20-102019-002810-B	<1
WS-002811	9/11/2019	9/11/2020	1	Combo Faucet	In classroom 108	Right WF-09112019-002811	10/24/2019	FT-FY20-102019-002811-A	1.1	FT-FY20-102019-002811-B	<1
WS-002812	9/11/2019	9/11/2020	1	Combo Faucet	In classroom 107	WF-09112019-002812	10/24/2019	FT-FY20-102019-002812-A	2.5	FT-FY20-102019-002812-B	<1
WS-002813	5/22/2019	5/22/2020	1	Combo Fountain	In classroom 107	WF-05222019-002813	10/24/2019	FT-FY20-102019-002813-A	<1	FT-FY20-102019-002813-B	<1
WS-002814	5/22/2019	5/22/2020	1	Break Room	In break room 105	WF-05222019-002814	10/24/2019	FT-FY20-102019-002814-A	<1	FT-FY20-102019-002814-B	<1
WS-002816	5/22/2019	5/22/2020	1	Health Suite	In health suite 104	WF-05222019-002816	10/24/2019	FT-FY20-102019-002816-A	<1	FT-FY20-102019-002816-B	<1
WS-002821	5/22/2019	5/22/2020	2	Cooler	In hallway adjacent to girls' restroom	High Left WF-05222019-002821	10/24/2019	FT-FY20-102019-002821-A	<1	FT-FY20-102019-002821-B	<1
WS-002823	5/22/2019	5/22/2020	2	Cooler	In hallway adjacent to room 201	Low Right WF-05222019-002823	10/24/2019	FT-FY20-102019-002823-A	<1	FT-FY20-102019-002823-B	<1
WS-002824	5/22/2019	5/22/2020	2	Cooler	In hallway adjacent to room 201	High Left WF-05222019-002824	10/24/2019	FT-FY20-102019-002824-A	<1	FT-FY20-102019-002824-B	<1
WS-002825	5/22/2019	5/22/2020	3	Cooler	In hallway adjacent to girls' restroom	High Left WF-05222019-002825	10/24/2019	FT-FY20-102019-002825-A	<1	FT-FY20-102019-002825-B	<1
WS-002826	5/22/2019	5/22/2020	3	Cooler	In hallway adjacent to girls' restroom	Low Right WF-05222019-002826	10/24/2019	FT-FY20-102019-002826-A	<1	FT-FY20-102019-002826-B	<1
WS-002827	5/22/2019	5/22/2020	3	Cooler	In hallway adjacent to boys' restroom	High Left WF-05222019-002827	10/24/2019	FT-FY20-102019-002827-A	<1	FT-FY20-102019-002827-B	<1
WS-002828	5/22/2019	5/22/2020	3	Cooler	In hallway adjacent to boys' restroom	Low Right WF-05222019-002828	10/24/2019	FT-FY20-102019-002828-A	<1	FT-FY20-102019-002828-B	<1
WS-002829	5/22/2019	5/22/2020	Ground Floor	Cooler	Annex, in hallway adjacent to classroom G17	WF-05222019-002829	10/24/2019	FT-FY20-102019-002829-A	<1	FT-FY20-102019-002829-B	<1
WS-002830	9/11/2019	9/11/2020	Ground Floor	Combo Faucet	Annex, in classroom G17	WF-09112019-002830	10/24/2019	FT-FY20-102019-002830-A	<1	FT-FY20-102019-002830-B	<1
WS-002831	5/22/2019	5/22/2020	Ground Floor	Combo Fountain	Annex, in classroom G17	WF-05222019-002831	10/24/2019	FT-FY20-102019-002831-A	<1	FT-FY20-102019-002831-B	<1
WS-002832	5/22/2019	5/22/2020	Ground Floor	Combo Fountain	Annex, in classroom G16	WF-05222019-002832	10/24/2019	FT-FY20-102019-002832-A	<1	FT-FY20-102019-002832-B	<1
WS-002833	9/11/2019	9/11/2020	Ground Floor	Combo Faucet	Annex, in classroom G16	WF-09112019-002833	10/24/2019	FT-FY20-102019-002833-A	<1	FT-FY20-102019-002833-B	<1
WS-002834	5/22/2019	5/22/2020	Ground Floor	Combo Fountain	Annex, in classroom G14	WF-05222019-002834	10/24/2019	FT-FY20-102019-002834-A	<1	FT-FY20-102019-002834-B	<1
WS-002835	9/11/2019	9/11/2020	Ground Floor	Combo Faucet	Annex, in classroom G14	WF-09112019-002835	10/24/2019	FT-FY20-102019-002835-A	<1	FT-FY20-102019-002835-B	<1
WS-002836	9/11/2019	9/11/2020	Ground Floor	Combo Faucet	Annex, in music room G15	WF-09112019-002836	10/24/2019	FT-FY20-102019-002836-A	<1	FT-FY20-102019-002836-B	<1
WS-002837	5/22/2019	5/22/2020	Ground Floor	Combo Fountain	Annex, in music room G15	WF-05222019-002837	10/24/2019	FT-FY20-102019-002837-A	<1	FT-FY20-102019-002837-B	<1
WS-002838	5/22/2019	5/22/2020	1	Cooler	Annex, in hallway adjacent to staff restroom	WF-05222019-002838	10/24/2019	FT-FY20-102019-002838-A	<1	FT-FY20-102019-002838-B	<1
WS-002839	9/11/2019	9/11/2020	1	Combo Faucet	Annex, in classroom 118 first clockwise from entry door	Right WF-09112019-002839	10/24/2019	FT-FY20-102019-002839-A	<1	FT-FY20-102019-002839-B	<1
WS-002840	5/22/2019	5/22/2020	1	Combo Fountain	Annex, in classroom 118 second clockwise from entry door	Right WF-05222019-002840	10/24/2019	FT-FY20-102019-002840-A	<1	FT-FY20-102019-002840-B	<1
WS-002841	9/11/2019	9/11/2020	1	Combo Faucet	Annex, in classroom 118 third clockwise from entry door	Left WF-09112019-002841	10/24/2019	FT-FY20-102019-002841-A	3.5	FT-FY20-102019-002841-B	<1
WS-002842	5/22/2019	5/22/2020	1	Combo Fountain	Annex, in classroom 118 fourth clockwise from entry door	Right WF-05222019-002842	10/24/2019	FT-FY20-102019-002842-A	<1	FT-FY20-102019-002842-B	<1
WS-002843	5/22/2019	5/22/2020	1	Combo Fountain	Annex, in classroom 118 fifth clockwise from entry door	WF-05222019-002843	10/24/2019	FT-FY20-102019-002843-A	<1	FT-FY20-102019-002843-B	<1

WS- 002844	9/11/2019	9/11/2020	1	Combo Faucet	Annex, in classroom 118 sixth clockwise from entry door	WF-09112019-002844	10/24/2019	FT-FY20-102019-002844-A	<1	FT-FY20-102019-002844-B	<1
------------	-----------	-----------	---	--------------	---	--------------------	------------	-------------------------	----	-------------------------	----

### Food Prep Sink

#### Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002801	7/11/2019	7/11/2020	Ground Floor	Food Prep Sink	In kitchen on south wall	WF-07112019-002801	10/24/2019	FT-FY20-102019-002801-A	<1	FT-FY20-102019-002801-B	<1

### Food Prep Sink

#### Greater than 5ppb - Devices requiring remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 002800	7/11/2019	7/11/2020	Ground Floor	Food Prep Sink	In kitchen on north wall	WF-07112019-002800	10/24/2019	FT-FY20-102019-002800-A	5.9	FT-FY20-102019-002800-B	<1