



# Hendley Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-002696	4/5/2022	4/5/2023	1	Bottle Filler	In hallway adjacent to resource room 109	WF-04052022-002696	10/31/2022	FT-FY23-10102022-002696-A	<1	FT-FY23-10102022-002696-B	<1	
WS-002802	4/5/2022	4/5/2023	Ground Floor	Cooler	In cafeteria	WF-04052022-002802	10/31/2022	FT-FY23-10102022-002802-A	<1	FT-FY23-10102022-002802-B	<1	
WS-002803	4/5/2022	4/5/2023	Ground Floor	Cooler	In hallway adjacent to room G10	WF-04052022-002803	10/31/2022	FT-FY23-10102022-002803-A	<1	FT-FY23-10102022-002803-B	<1	
WS-002804	8/16/2022	8/16/2023	Ground Floor	Combo Faucet	In classroom G11	WF-08162022-002804	10/31/2022	FT-FY23-10102022-002804-A	<1	FT-FY23-10102022-002804-B	<1	
WS-002805	4/5/2022	4/5/2023	Ground Floor	Combo Fountain	In classroom G11	WF-04052022-002805	10/31/2022	FT-FY23-10102022-002805-A	<1	FT-FY23-10102022-002805-B	<1	
WS-002806	8/16/2022	8/16/2023	Ground Floor	Combo Faucet	In classroom G13	WF-08162022-002806	10/31/2022	FT-FY23-10102022-002806-A	<1	FT-FY23-10102022-002806-B	<1	
WS-002807	4/5/2022	4/5/2023	Ground Floor	Combo Fountain	In classroom G13	WF-04052022-002807	10/31/2022	FT-FY23-10102022-002807-A	<1	FT-FY23-10102022-002807-B	<1	
WS-002808	8/16/2022	8/16/2023	1	Combo Faucet	In classroom 110	WF-08162022-002808	10/31/2022	FT-FY23-10102022-002808-A	1.3	FT-FY23-10102022-002808-B	<1	
WS-002809	4/5/2022	4/5/2023	1	Combo Fountain	In classroom 110	WF-04052022-002809	10/31/2022	FT-FY23-10102022-002809-A	<1	FT-FY23-10102022-002809-B	<1	
WS-002810	4/5/2022	4/5/2023	1	Combo Fountain	In classroom 108	Left	WF-04052022-002810	10/31/2022	FT-FY23-10102022-002810-A	<1	FT-FY23-10102022-002810-B	<1
WS-002811	8/16/2022	8/16/2023	1	Combo Faucet	In classroom 108	Right	WF-08162022-002811	10/31/2022	FT-FY23-10102022-002811-A	1.7	FT-FY23-10102022-002811-B	<1
WS-002812	8/16/2022	8/16/2023	1	Combo Faucet	In classroom 107		WF-08162022-002812	10/31/2022	FT-FY23-10102022-002812-A	1.4	FT-FY23-10102022-002812-B	<1
WS-002813	4/5/2022	4/5/2023	1	Combo Fountain	In classroom 107		WF-04052022-002813	10/31/2022	FT-FY23-10102022-002813-A	<1	FT-FY23-10102022-002813-B	<1
WS-002814	4/5/2022	4/5/2023	1	Break Room	In break room 105		WF-04052022-002814	10/31/2022	FT-FY23-10102022-002814-A	<1	FT-FY23-10102022-002814-B	<1
WS-002816	4/5/2022	4/5/2023	1	Health Suite	In health suite 104		WF-04052022-002816	10/31/2022	FT-FY23-10102022-002816-A	<1	FT-FY23-10102022-002816-B	<1
WS-002820	4/5/2022	4/5/2023	1	Cooler	In hallway adjacent to resource room 109		WF-04052022-002820	10/31/2022	FT-FY23-10102022-002820-A	<1	FT-FY23-10102022-002820-B	<1
WS-002821	4/5/2022	4/5/2023	2	Cooler	In hallway adjacent to girls' restroom	High Left	WF-04052022-002821	10/31/2022	FT-FY23-10102022-002821-A	<1	FT-FY23-10102022-002821-B	<1
WS-002822	4/5/2022	4/5/2023	2	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-04052022-002822	10/31/2022	FT-FY23-10102022-002822-A	<1	FT-FY23-10102022-002822-B	<1
WS-002823	4/5/2022	4/5/2023	2	Cooler	In hallway adjacent to room 201	Low Right	WF-04052022-002823	10/31/2022	FT-FY23-10102022-002823-A	<1	FT-FY23-10102022-002823-B	<1
WS-002824	4/5/2022	4/5/2023	2	Cooler	In hallway adjacent to room 201	High Left	WF-04052022-002824	10/31/2022	FT-FY23-10102022-002824-A	<1	FT-FY23-10102022-002824-B	<1
WS-002825	4/5/2022	4/5/2023	3	Cooler	In hallway adjacent to girls' restroom	High Left	WF-04052022-002825	10/31/2022	FT-FY23-10102022-002825-A	<1	FT-FY23-10102022-002825-B	<1
WS-002826	4/5/2022	4/5/2023	3	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-04052022-002826	10/31/2022	FT-FY23-10102022-002826-A	<1	FT-FY23-10102022-002826-B	<1
WS-002827	4/5/2022	4/5/2023	3	Cooler	In hallway adjacent to boys' restroom	High Left	WF-04052022-002827	10/31/2022	FT-FY23-10102022-002827-A	<1	FT-FY23-10102022-002827-B	<1
WS-002828	4/5/2022	4/5/2023	3	Cooler	In hallway adjacent to boys' restroom	Low Right	WF-04052022-002828	10/31/2022	FT-FY23-10102022-002828-A	<1	FT-FY23-10102022-002828-B	<1
WS-002829	4/5/2022	4/5/2023	Ground Floor	Cooler	Annex, in hallway adjacent to classroom G17		WF-04052022-002829	10/31/2022	FT-FY23-10102022-002829-A	<1	FT-FY23-10102022-002829-B	<1
WS-002830	8/16/2022	8/16/2023	Ground Floor	Combo Faucet	Annex, in classroom G17		WF-08162022-002830	10/31/2022	FT-FY23-10102022-002830-A	<1	FT-FY23-10102022-002830-B	<1
WS-002831	4/5/2022	4/5/2023	Ground Floor	Combo Fountain	Annex, in classroom G17		WF-04052022-002831	10/31/2022	FT-FY23-10102022-002831-A	<1	FT-FY23-10102022-002831-B	<1
WS-002832	4/5/2022	4/5/2023	Ground Floor	Combo Fountain	Annex, in classroom G16		WF-04052022-002832	10/31/2022	FT-FY23-10102022-002832-A	<1	FT-FY23-10102022-002832-B	<1
WS-002833	8/16/2022	8/16/2023	Ground Floor	Combo Faucet	Annex, in classroom G16		WF-08162022-002833	10/31/2022	FT-FY23-10102022-002833-A	<1	FT-FY23-10102022-002833-B	<1
WS-002834	4/5/2022	4/5/2023	Ground Floor	Combo Fountain	Annex, in classroom G14		WF-04052022-002834	10/31/2022	FT-FY23-10102022-002834-A	<1	FT-FY23-10102022-002834-B	<1
WS-002835	8/16/2022	8/16/2023	Ground Floor	Combo Faucet	Annex, in classroom G14		WF-08162022-002835	10/31/2022	FT-FY23-10102022-002835-A	<1	FT-FY23-10102022-002835-B	<1
WS-002836	8/16/2022	8/16/2023	Ground Floor	Combo Faucet	Annex, in music room G15		WF-08162022-002836	10/31/2022	FT-FY23-10102022-002836-A	<1	FT-FY23-10102022-002836-B	<1
WS-002837	4/5/2022	4/5/2023	Ground Floor	Combo Fountain	Annex, in music room G15		WF-04052022-002837	10/31/2022	FT-FY23-10102022-002837-A	<1	FT-FY23-10102022-002837-B	<1
WS-002838	4/5/2022	4/5/2023	1	Cooler	Annex, in hallway adjacent to staff restroom		WF-04052022-002838	10/31/2022	FT-FY23-10102022-002838-A	<1	FT-FY23-10102022-002838-B	<1
WS-002839	8/16/2022	8/16/2023	1	Combo Faucet	Annex, in classroom 118 first clockwise from entry door	Right	WF-08162022-002839	10/31/2022	FT-FY23-10102022-002839-A	<1	FT-FY23-10102022-002839-B	<1
WS-002840	4/5/2022	4/5/2023	1	Combo Fountain	Annex, in classroom 118 second clockwise from entry door	Right	WF-04052022-002840	10/31/2022	FT-FY23-10102022-002840-A	<1	FT-FY23-10102022-002840-B	<1

WS-002841	8/16/2022	8/16/2023	1	Combo Faucet	Annex, in classroom 118 third clockwise from entry door	Left	WF-08162022-002841	10/31/2022	FT-FY23-10102022-002841-A	<1	FT-FY23-10102022-002841-B	<1
WS-002842	4/5/2022	4/5/2023	1	Combo Fountain	Annex, in classroom 118 fourth clockwise from entry door	Right	WF-04052022-002842	10/31/2022	FT-FY23-10102022-002842-A	1.0	FT-FY23-10102022-002842-B	<1
WS-002843	4/5/2022	4/5/2023	1	Combo Fountain	Annex, in classroom 118 fifth clockwise from entry door		WF-04052022-002843	10/31/2022	FT-FY23-10102022-002843-A	<1	FT-FY23-10102022-002843-B	<1
WS-002844	8/16/2022	8/16/2023	1	Combo Faucet	Annex, in classroom 118 sixth clockwise from entry door		WF-08162022-002844	10/31/2022	FT-FY23-10102022-002844-A	<1	FT-FY23-10102022-002844-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002800	2/16/2022	2/16/2023	Ground Floor	Food Prep Sink	In kitchen on north wall	WF-02162022-002800	10/31/2022	FT-FY23-10102022-002800-A	<1	FT-FY23-10102022-002800-B	<1
WS-002801	2/9/2022	2/9/2023	Ground Floor	Food Prep Sink	In kitchen on south wall	WF-02092022-002801	10/31/2022	FT-FY23-10102022-002801-A	<1	FT-FY23-10102022-002801-B	<1