



# Hendley Elementary School Lead in Water Test Results



## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 002803	5/11/2020	5/11/2021	Ground Floor	Cooler	In hallway adjacent to room G10	WF-05112020-002803	1/7/2021	FT-FY21-012021-002803-A	<1	FT-FY21-012021-002803-B	<1	
WS- 002804	9/2/2020	9/2/2021	Ground Floor	Combo Faucet	In classroom G11	WF-09022020-002804	1/7/2021	FT-FY21-012021-002804-A	1.2	FT-FY21-012021-002804-B	<1	
WS- 002805	5/11/2020	5/11/2021	Ground Floor	Combo Fountain	In classroom G11	WF-05112020-002805	1/7/2021	FT-FY21-012021-002805-A	1.2	FT-FY21-012021-002805-B	<1	
WS- 002806	9/2/2020	9/2/2021	Ground Floor	Combo Faucet	In classroom G13	WF-09022020-002806	1/7/2021	FT-FY21-012021-002806-A	1.4	FT-FY21-012021-002806-B	<1	
WS- 002807	5/11/2020	5/11/2021	Ground Floor	Combo Fountain	In classroom G13	WF-05112020-002807	1/7/2021	FT-FY21-012021-002807-A	1.1	FT-FY21-012021-002807-B	<1	
WS- 002808	9/2/2020	9/2/2021	1	Combo Faucet	In classroom 110	WF-09022020-002808	1/7/2021	FT-FY21-012021-002808-A	<1	FT-FY21-012021-002808-B	<1	
WS- 002809	5/11/2020	5/11/2021	1	Combo Fountain	In classroom 110	WF-05112020-002809	1/7/2021	FT-FY21-012021-002809-A	<1	FT-FY21-012021-002809-B	<1	
WS- 002810	5/11/2020	5/11/2021	1	Combo Fountain	In classroom 108	Left	WF-05112020-002810	1/7/2021	FT-FY21-012021-002810-A	<1	FT-FY21-012021-002810-B	<1
WS- 002811	9/2/2020	9/2/2021	1	Combo Faucet	In classroom 108	Right	WF-09022020-002811	1/7/2021	FT-FY21-012021-002811-A	<1	FT-FY21-012021-002811-B	<1
WS- 002812	9/2/2020	9/2/2021	1	Combo Faucet	In classroom 107		WF-09022020-002812	1/7/2021	FT-FY21-012021-002812-A	1.6	FT-FY21-012021-002812-B	<1
WS- 002813	5/11/2020	5/11/2021	1	Combo Fountain	In classroom 107		WF-05112020-002813	1/7/2021	FT-FY21-012021-002813-A	1.1	FT-FY21-012021-002813-B	<1
WS- 002814	5/11/2020	5/11/2021	1	Break Room	In break room 105		WF-05112020-002814	1/7/2021	FT-FY21-012021-002814-A	<1	FT-FY21-012021-002814-B	<1
WS- 002816	5/11/2020	5/11/2021	1	Health Suite	In health suite 104		WF-05112020-002816	1/7/2021	FT-FY21-012021-002816-A	1.6	FT-FY21-012021-002816-B	<1
WS- 002820	5/11/2020	5/11/2021	1	Cooler	In hallway adjacent to resource room 109		WF-05112020-002820	1/7/2021	FT-FY21-012021-002820-A	<1	FT-FY21-012021-002820-B	<1
WS- 002821	5/11/2020	5/11/2021	2	Cooler	In hallway adjacent to girls' restroom	High Left	WF-05112020-002821	1/7/2021	FT-FY21-012021-002821-A	<1	FT-FY21-012021-002821-B	<1
WS- 002822	5/11/2020	5/11/2021	2	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-05112020-002822	1/7/2021	FT-FY21-012021-002822-A	<1	FT-FY21-012021-002822-B	<1
WS- 002823	5/11/2020	5/11/2021	2	Cooler	In hallway adjacent to room 201	Low Right	WF-05112020-002823	1/7/2021	FT-FY21-012021-002823-A	<1	FT-FY21-012021-002823-B	<1
WS- 002824	5/11/2020	5/11/2021	2	Cooler	In hallway adjacent to room 201	High Left	WF-05112020-002824	1/7/2021	FT-FY21-012021-002824-A	<1	FT-FY21-012021-002824-B	<1
WS- 002825	5/11/2020	5/11/2021	3	Cooler	In hallway adjacent to girls' restroom	High Left	WF-05112020-002825	1/7/2021	FT-FY21-012021-002825-A	<1	FT-FY21-012021-002825-B	<1
WS- 002826	5/11/2020	5/11/2021	3	Cooler	In hallway adjacent to girls' restroom	Low Right	WF-05112020-002826	1/7/2021	FT-FY21-012021-002826-A	<1	FT-FY21-012021-002826-B	<1
WS- 002827	5/11/2020	5/11/2021	3	Cooler	In hallway adjacent to boys' restroom	High Left	WF-05112020-002827	1/7/2021	FT-FY21-012021-002827-A	<1	FT-FY21-012021-002827-B	<1
WS- 002828	5/11/2020	5/11/2021	3	Cooler	In hallway adjacent to boys' restroom	Low Right	WF-05112020-002828	1/7/2021	FT-FY21-012021-002828-A	<1	FT-FY21-012021-002828-B	<1
WS- 002829	5/11/2020	5/11/2021	Ground Floor	Cooler	Annex, in hallway adjacent to classroom G17		WF-05112020-002829	1/7/2021	FT-FY21-012021-002829-A	<1	FT-FY21-012021-002829-B	<1
WS- 002830	9/2/2020	9/2/2021	Ground Floor	Combo Faucet	Annex, in classroom G17		WF-09022020-002830	1/7/2021	FT-FY21-012021-002830-A	<1	FT-FY21-012021-002830-B	<1
WS- 002831	5/11/2020	5/11/2021	Ground Floor	Combo Fountain	Annex, in classroom G17		WF-05112020-002831	1/7/2021	FT-FY21-012021-002831-A	<1	FT-FY21-012021-002831-B	<1
WS- 002832	5/11/2020	5/11/2021	Ground Floor	Combo Fountain	Annex, in classroom G16		WF-05112020-002832	1/7/2021	FT-FY21-012021-002832-A	<1	FT-FY21-012021-002832-B	<1
WS- 002833	9/2/2020	9/2/2021	Ground Floor	Combo Faucet	Annex, in classroom G16		WF-09022020-002833	1/7/2021	FT-FY21-012021-002833-A	<1	FT-FY21-012021-002833-B	<1
WS- 002834	5/11/2020	5/11/2021	Ground Floor	Combo Fountain	Annex, in classroom G14		WF-05112020-002834	1/7/2021	FT-FY21-012021-002834-A	<1	FT-FY21-012021-002834-B	<1
WS- 002835	9/2/2020	9/2/2021	Ground Floor	Combo Faucet	Annex, in classroom G14		WF-09022020-002835	1/7/2021	FT-FY21-012021-002835-A	<1	FT-FY21-012021-002835-B	<1
WS- 002836	9/2/2020	9/2/2021	Ground Floor	Combo Faucet	Annex, in music room G15		WF-09022020-002836	1/7/2021	FT-FY21-012021-002836-A	<1	FT-FY21-012021-002836-B	<1
WS- 002837	5/11/2020	5/11/2021	Ground Floor	Combo Fountain	Annex, in music room G15		WF-05112020-002837	1/7/2021	FT-FY21-012021-002837-A	<1	FT-FY21-012021-002837-B	<1
WS- 002838	5/11/2020	5/11/2021	1	Cooler	Annex, in hallway adjacent to staff restroom		WF-05112020-002838	1/7/2021	FT-FY21-012021-002838-A	<1	FT-FY21-012021-002838-B	<1
WS- 002839	9/2/2020	9/2/2021	1	Combo Faucet	Annex, in classroom 118 first clockwise from entry door	Right	WF-09022020-002839	1/7/2021	FT-FY21-012021-002839-A	<1	FT-FY21-012021-002839-B	<1
WS- 002840	5/11/2020	5/11/2021	1	Combo Fountain	Annex, in classroom 118 second clockwise from entry door	Right	WF-05112020-002840	1/7/2021	FT-FY21-012021-002840-A	<1	FT-FY21-012021-002840-B	<1

WS-002841	9/2/2020	9/2/2021	1	Combo Faucet	Annex, in classroom 118 third clockwise from entry door	Left	WF-09022020-002841	1/7/2021	FT-FY21-012021-002841-A	<1	FT-FY21-012021-002841-B	<1
WS-002842	5/11/2020	5/11/2021	1	Combo Fountain	Annex, in classroom 118 fourth clockwise from entry door	Right	WF-05112020-002842	1/7/2021	FT-FY21-012021-002842-A	<1	FT-FY21-012021-002842-B	<1
WS-002843	5/11/2020	5/11/2021	1	Combo Fountain	Annex, in classroom 118 fifth clockwise from entry door		WF-05112020-002843	1/7/2021	FT-FY21-012021-002843-A	<1	FT-FY21-012021-002843-B	<1
WS-002844	9/2/2020	9/2/2021	1	Combo Faucet	Annex, in classroom 118 sixth clockwise from entry door		WF-09022020-002844	1/7/2021	FT-FY21-012021-002844-A	<1	FT-FY21-012021-002844-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002800	2/25/2020	2/25/2021	Ground Floor	Food Prep Sink	In kitchen on north wall	WF-02252020-002800	1/7/2021	FT-FY21-012021-002800-A	<1	FT-FY21-012021-002800-B	<1

### Food Prep Sink

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002801	2/25/2020	2/25/2021	Ground Floor	Food Prep Sink	In kitchen on south wall	WF-02252020-002801	1/7/2021	FT-FY21-012021-002801-A	14	FT-FY21-012021-002801-B	<1

### First Re-test (After Plumbing Check)

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002801	1/11/2021	1/11/2022	Ground Floor	Food Prep Sink	In kitchen on south wall	WF-01112021-002801	1/23/2021	FT-FY21-012021-002801-A	<1	FT-FY21-012021-002801-B	<1