



HENDLEY ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	HENDLEY ELEMENTARY SCHOOL	WS- 002800	8/8/2016	Ground Floor	Food Prep Sink	In kitchen on north wall	FT-72016-002800-A	< 1	FT-72016-002800-B	< 1
2	HENDLEY ELEMENTARY SCHOOL	WS- 002802	8/8/2016	Ground Floor	Cooler	In cafeteria	FT-72016-002802-A	< 1	FT-72016-002802-B	< 1
3	HENDLEY ELEMENTARY SCHOOL	WS- 002803	8/8/2016	Ground Floor	Cooler	In hallway adjacent to room G10	FT-72016-002803-A	< 1	FT-72016-002803-B	< 1
4	HENDLEY ELEMENTARY SCHOOL	WS- 002805	8/8/2016	Ground Floor	Fountain	In classroom G11	FT-72016-002805-A	< 1	FT-72016-002805-B	< 1
5	HENDLEY ELEMENTARY SCHOOL	WS- 002807	8/8/2016	Ground Floor	Fountain	In classroom G13	FT-72016-002807-A	< 1	FT-72016-002807-B	< 1
6	HENDLEY ELEMENTARY SCHOOL	WS- 002809	8/8/2016	1	Fountain	In classroom 110	FT-82016-002809-A	< 1	FT-82016-002809-B	< 1
7	HENDLEY ELEMENTARY SCHOOL	WS- 002810	8/8/2016	1	Fountain	In classroom 108 Left	FT-72016-002810-A	< 1	FT-72016-002810-B	< 1
8	HENDLEY ELEMENTARY SCHOOL	WS- 002813	8/8/2016	1	Fountain	In classroom 107	FT-72016-002813-A	< 1	FT-72016-002813-B	< 1
9	HENDLEY ELEMENTARY SCHOOL	WS- 002816	8/8/2016	1	Health Suite	In health suite 104	FT-72016-002816-A	1	FT-72016-002816-B	< 1
10	HENDLEY ELEMENTARY SCHOOL	WS- 002820	8/8/2016	1	Cooler	In hallway adjacent to resource room 109	FT-72016-002820-A	< 1	FT-72016-002820-B	< 1
11	HENDLEY ELEMENTARY SCHOOL	WS- 002821	8/8/2016	2	Cooler	In hallway adjacent to girls' restroom High Left	FT-72016-002821-A	< 1	FT-72016-002821-B	< 1
12	HENDLEY ELEMENTARY SCHOOL	WS- 002822	8/8/2016	2	Cooler	In hallway adjacent to girls' restroom Low Right	FT-72016-002822-A	< 1	FT-72016-002822-B	< 1
13	HENDLEY ELEMENTARY SCHOOL	WS- 002823	8/8/2016	2	Cooler	In hallway adjacent to room 201 Low Right	FT-72016-002823-A	< 1	FT-72016-002823-B	< 1
14	HENDLEY ELEMENTARY SCHOOL	WS- 002824	8/8/2016	2	Cooler	In hallway adjacent to room 201 High Left	FT-72016-002824-A	< 1	FT-72016-002824-B	< 1
15	HENDLEY ELEMENTARY SCHOOL	WS- 002825	8/8/2016	3	Cooler	In hallway adjacent to girls' restroom High Left	FT-72016-002825-A	< 1	FT-72016-002825-B	< 1
16	HENDLEY ELEMENTARY SCHOOL	WS- 002826	8/8/2016	3	Cooler	In hallway adjacent to girls' restroom Low Right	FT-72016-002826-A	< 1	FT-72016-002826-B	< 1
17	HENDLEY ELEMENTARY SCHOOL	WS- 002827	8/8/2016	3	Cooler	In hallway adjacent to boys' restroom High Left	FT-72016-002827-A	< 1	FT-72016-002827-B	< 1
18	HENDLEY ELEMENTARY SCHOOL	WS- 002828	8/8/2016	3	Cooler	In hallway adjacent to boys' restroom Low Right	FT-72016-002828-A	< 1	FT-72016-002828-B	< 1
19	HENDLEY ELEMENTARY SCHOOL	WS- 002829	8/8/2016	Ground Floor	Cooler	Annex, in hallway adjacent to classroom G17	FT-72016-002829-A	< 1	FT-72016-002829-B	< 1
20	HENDLEY ELEMENTARY SCHOOL	WS- 002831	8/8/2016	Ground Floor	Fountain	Annex, in classroom G17	FT-72016-002831-A	< 1	FT-72016-002831-B	< 1
21	HENDLEY ELEMENTARY SCHOOL	WS- 002832	8/8/2016	Ground Floor	Fountain	Annex, in classroom G16	FT-72016-002832-A	< 1	FT-72016-002832-B	< 1
22	HENDLEY ELEMENTARY SCHOOL	WS- 002834	8/8/2016	Ground Floor	Fountain	Annex, in classroom G14	FT-82016-002834-A	< 1	FT-82016-002834-B	< 1
23	HENDLEY ELEMENTARY SCHOOL	WS- 002835	8/8/2016	Ground Floor	Classroom Faucet	Annex, in classroom G14	FT-72016-002835-A	< 1	FT-72016-002835-B	< 1
24	HENDLEY ELEMENTARY SCHOOL	WS- 002837	8/8/2016	Ground Floor	Fountain	Annex, in music room G15	FT-72016-002837-A	< 1	FT-72016-002837-B	< 1
25	HENDLEY ELEMENTARY SCHOOL	WS- 002838	8/8/2016	1	Fountain	Annex, in hallway adjacent to staff restroom Mid	FT-72016-002838-A	< 1	FT-72016-002838-B	< 1
26	HENDLEY ELEMENTARY SCHOOL	WS- 002840	8/8/2016	1	Fountain	Annex, in classroom 118 second clockwise from entry door Right	FT-72016-002840-A	< 1	FT-72016-002840-B	< 1
27	HENDLEY ELEMENTARY SCHOOL	WS- 002842	8/8/2016	1	Fountain	Annex, in classroom 118 fourth clockwise from entry door Right	FT-72016-002842-A	< 1	FT-72016-002842-B	< 1
28	HENDLEY ELEMENTARY SCHOOL	WS- 002843	8/8/2016	1	Fountain	Annex, in classroom 118 fifth clockwise from entry door	FT-72016-002843-A	< 1	FT-72016-002843-B	< 1