



Hillcrest RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005628	3/22/2021	3/22/2022	1	Bottle Filler	In hallway adjacent to multimedia 105	WF-03222021-005628	4/12/2021	FT-FY21-042021-005628-A	<1	FT-FY21-042021-005628-B	<1
WS- 005629	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to multimedia 105 High Left	WF-03222021-005629	4/12/2021	FT-FY21-042021-005629-A	<1	FT-FY21-042021-005629-B	<1
WS- 005639	3/22/2021	3/22/2022	1	Cooler	In hallway adjacent to multimedia 105 Low Right	WF-03222021-005639	4/12/2021	FT-FY21-042021-005639-A	<1	FT-FY21-042021-005639-B	<1
WS- 005640	3/22/2021	3/22/2022	1	Cooler	In hallway across from gym 100	WF-03222021-005640	4/12/2021	FT-FY21-042021-005640-A	<1	FT-FY21-042021-005640-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005641	1/28/2021	1/28/2022	1	Food Prep Sink	In pantry room 102 in kitchen	WF-01282021-005641	4/12/2021	FT-FY21-042021-005641-A	<1	FT-FY21-042021-005641-B	<1