



# Hillcrest RC Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

| RECORD ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type   | Device Location                       | WATER FILTERS Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
|-----------|-----------------------|------------------------|-------|---------------|---------------------------------------|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS-005628 | 1/18/18               | 1/18/19                | 1     | Bottle Filler | In hallway adjacent to multimedia 105 | WF-12018-005628    | 3/1/18        | FT-FY18--12018-005628-A | <1                               | FT-FY18--12018-005628-B | <1                               |
| WS-005640 | 6/7/17                | 6/7/18                 | 1     | Cooler        | In hallway across from gym 100        | WF-62017-005640    | 3/1/18        | FT-FY18--62017-005640-A | <1                               | FT-FY18--62017-005640-B | <1                               |

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

| RECORD ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type    | Device Location               | WATER FILTERS Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
|-----------|-----------------------|------------------------|-------|----------------|-------------------------------|--------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS-005641 | 6/7/17                | 6/7/18                 | 1     | Food Prep Sink | In pantry room 102 in kitchen | WF-62017-005641    | 3/1/18        | FT-FY18--62017-005641-A | <1                               | FT-FY18--62017-005641-B | <1                               |