



Hillcrest RC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005628	4/3/2019	4/3/2020	1	Bottle Filler	In hallway adjacent to multimedia 105	WF-04032019-005628	3/11/2020	FT-FY20-012020-005628-A	<1	FT-FY20-012020-005628-B	<1
WS- 005629	4/3/2019	4/3/2020	1	Cooler	In hallway adjacent to multimedia 105 High Left	WF-04032019-005629	3/11/2020	FT-FY20-012020-005629-A	<1	FT-FY20-012020-005629-B	<1
WS- 005639	4/3/2019	4/3/2020	1	Cooler	In hallway adjacent to multimedia 105 Low Right	WF-04032019-005639	3/11/2020	FT-FY20-012020-005639-A	<1	FT-FY20-012020-005639-B	<1
WS- 005640	4/3/2019	4/3/2020	1	Cooler	In hallway across from gym 100	WF-04032019-005640	3/11/2020	FT-FY20-012020-005640-A	<1	FT-FY20-012020-005640-B	<1
WS- 005641	4/3/2019	4/3/2020	1	Food Prep Sink	In pantry room 102 in kitchen	WF-04032019-005641	3/11/2020	FT-FY20-012020-005641-A	<1	FT-FY20-012020-005641-B	<1