



HILLCREST REC LEAD WATER TEST RESULTS



Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1 HILLCREST RECREATION CENTER	WS- 005639	9/20/2016	1	Cooler	In hallway adjacent to mechanical room 113 (revised water source)	FT-82016-005639-A	< 1	FT-82016-005639-B	< 1
2 HILLCREST RECREATION CENTER	WS- 005640	9/20/2016	1	Cooler	In hallway across from gym 100	FT-82016-005640-A	< 1	FT-82016-005640-B	< 1
3 HILLCREST RECREATION CENTER	WS- 005641	9/21/2016	1	Food Prep Sink	In pantry room 102 in kitchen	FT-82016-005641-A	< 1	FT-82016-005641-B	< 1