



Houston ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013307	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A02	WF-08082018-013307	8/17/2018	FT-FY19-082018-013307-A	< 1	FT-FY19-082018-013307-B	< 1
WS-013308	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A01	WF-08082018-013308	8/17/2018	FT-FY19-082018-013308-A	< 1	FT-FY19-082018-013308-B	< 1
WS-013309	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A04	WF-08082018-013309	8/17/2018	FT-FY19-082018-013309-A	< 1	FT-FY19-082018-013309-B	< 1
WS-013310	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A03	WF-08082018-013310	8/17/2018	FT-FY19-082018-013310-A	< 1	FT-FY19-082018-013310-B	< 1
WS-013311	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A06	WF-08082018-013311	8/17/2018	FT-FY19-082018-013311-A	< 1	FT-FY19-082018-013311-B	< 1
WS-013312	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A05	WF-08082018-013312	8/17/2018	FT-FY19-082018-013312-A	< 1	FT-FY19-082018-013312-B	< 1
WS-013317	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A13	WF-08082018-013317	8/17/2018	FT-FY19-082018-013317-A	< 1	FT-FY19-082018-013317-B	< 1
WS-013318	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A12	WF-08082018-013318	8/17/2018	FT-FY19-082018-013318-A	< 1	FT-FY19-082018-013318-B	< 1
WS-013319	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A15	WF-08082018-013319	8/17/2018	FT-FY19-082018-013319-A	< 1	FT-FY19-082018-013319-B	< 1
WS-013320	8/8/2018	8/8/2019	Ground Floor	Bathroom	In bathroom in classroom A14	WF-08082018-013320	8/17/2018	FT-FY19-082018-013320-A	< 1	FT-FY19-082018-013320-B	< 1
WS-013321	8/8/2018	8/8/2019	Ground Floor	Cooler	In hallway adjacent to storage room B07 High Left	WF-08082018-013321	8/17/2018	FT-FY19-082018-013321-A	< 1	FT-FY19-082018-013321-B	< 1
WS-013322	8/8/2018	8/8/2019	Ground Floor	Cooler	In hallway adjacent to storage room B07 Low Right	WF-08082018-013322	8/17/2018	FT-FY19-082018-013322-A	< 1	FT-FY19-082018-013322-B	< 1
WS-013323	8/8/2018	8/8/2019	Ground Floor	Cooler	In hallway adjacent to storage room B07 High Left	WF-08082018-013323	8/17/2018	FT-FY19-082018-013323-A	< 1	FT-FY19-082018-013323-B	< 1
WS-013324	8/8/2018	8/8/2019	Ground Floor	Cooler	In hallway adjacent to storage room B07 Low Right	WF-08082018-013324	8/17/2018	FT-FY19-082018-013324-A	< 1	FT-FY19-082018-013324-B	< 1
WS-013326	8/8/2018	8/8/2019	Ground Floor	Break Room	In staff lounge C06	WF-08082018-013326	8/17/2018	FT-FY19-082018-013326-A	< 1	FT-FY19-082018-013326-B	< 1
WS-013327	8/8/2018	8/8/2019	Ground Floor	Cooler	In hallway adjacent to SPED resource room C13 High Left	WF-08082018-013327	8/17/2018	FT-FY19-082018-013327-A	< 1	FT-FY19-082018-013327-B	< 1
WS-013328	8/8/2018	8/8/2019	Ground Floor	Cooler	In hallway adjacent to SPED resource room C13 Low Right	WF-08082018-013328	8/17/2018	FT-FY19-082018-013328-A	< 1	FT-FY19-082018-013328-B	< 1
WS-013329	8/8/2018	8/8/2019	Ground Floor	Cooler	In hallway adjacent to SPED resource room C13 High Left	WF-08082018-013329	8/17/2018	FT-FY19-082018-013329-A	< 1	FT-FY19-082018-013329-B	< 1
WS-013330	8/8/2018	8/8/2019	Ground Floor	Cooler	In hallway adjacent to SPED resource room C13 Low Right	WF-08082018-013330	8/17/2018	FT-FY19-082018-013330-A	< 1	FT-FY19-082018-013330-B	< 1
WS-013331	8/8/2018	8/8/2019	Ground Floor	Health Suite	In health suite C23	WF-08082018-013331	8/17/2018	FT-FY19-082018-013331-A	< 1	FT-FY19-082018-013331-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013305	Ground Floor	Food Prep Sink	In kitchen 2nd clockwise from entry	8/17/2018	FT-FY19-082018-013305-A	< 1	FT-FY19-082018-013305-B	< 1