



Houston Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-014300	10/13/2021	10/13/2022	1	Combo Faucet	In room 100 pre-school classroom	WF-10132021-014300	1/27/2022	FT-FY22-01042022-014300-A	<1	FT-FY22-01042022-014300-B	<1	
WS-014301	5/10/2021	5/10/2022	1	Combo Fountain	In room 100 pre-school classroom	WF-05102021-014301	1/27/2022	FT-FY22-01042022-014301-A	<1	FT-FY22-01042022-014301-B	<1	
WS-014304	10/13/2021	10/13/2022	1	Combo Faucet	In room 101 pre-school classroom	WF-10132021-014304	1/27/2022	FT-FY22-01042022-014304-A	<1	FT-FY22-01042022-014304-B	<1	
WS-014305	9/21/2021	9/21/2022	1	Combo Fountain	In room 101 pre-school classroom	WF-09212021-014305	1/27/2022	FT-FY22-01042022-014305-A	<1	FT-FY22-01042022-014305-B	<1	
WS-014306	10/13/2021	10/13/2022	1	Combo Faucet	In room 102 pre-k classroom	WF-10132021-014306	1/27/2022	FT-FY22-01042022-014306-A	<1	FT-FY22-01042022-014306-B	<1	
WS-014307	5/10/2021	5/10/2022	1	Combo Fountain	In room 102 pre-k classroom	WF-05102021-014307	1/27/2022	FT-FY22-01042022-014307-A	<1	FT-FY22-01042022-014307-B	<1	
WS-014310	10/13/2021	10/13/2022	1	Combo Faucet	In room 103 pre-school classroom	WF-10132021-014310	1/27/2022	FT-FY22-01042022-014310-A	<1	FT-FY22-01042022-014310-B	<1	
WS-014311	5/10/2021	5/10/2022	1	Combo Fountain	In room 103 pre-school classroom	WF-05102021-014311	1/27/2022	FT-FY22-01042022-014311-A	<1	FT-FY22-01042022-014311-B	<1	
WS-014312	5/10/2021	5/10/2022	1	Break Room	In room 108 teacher collaboration	WF-05102021-014312	1/27/2022	FT-FY22-01042022-014312-A	1.3	FT-FY22-01042022-014312-B	<1	
WS-014313	10/13/2021	10/13/2022	1	Combo Faucet	In room 109 pre-k classroom	WF-10132021-014313	1/27/2022	FT-FY22-01042022-014313-A	<1	FT-FY22-01042022-014313-B	<1	
WS-014314	5/10/2021	5/10/2022	1	Combo Fountain	In room 109 pre-k classroom	WF-05102021-014314	1/27/2022	FT-FY22-01042022-014314-A	<1	FT-FY22-01042022-014314-B	<1	
WS-014317	10/13/2021	10/13/2022	1	Combo Faucet	In room 110 kindergarten classroom	WF-10132021-014317	1/27/2022	FT-FY22-01042022-014317-A	<1	FT-FY22-01042022-014317-B	<1	
WS-014318	5/10/2021	5/10/2022	1	Combo Fountain	In room 110 kindergarten classroom	WF-05102021-014318	1/27/2022	FT-FY22-01042022-014318-A	<1	FT-FY22-01042022-014318-B	<1	
WS-014319	10/13/2021	10/13/2022	1	Combo Faucet	In room 111 kindergarten classroom	WF-10132021-014319	1/27/2022	FT-FY22-01042022-014319-A	<1	FT-FY22-01042022-014319-B	<1	
WS-014320	5/10/2021	5/10/2022	1	Combo Fountain	In room 111 kindergarten classroom	WF-05102021-014320	1/27/2022	FT-FY22-01042022-014320-A	<1	FT-FY22-01042022-014320-B	<1	
WS-014323	10/13/2021	10/13/2022	1	Combo Faucet	In room 112 kindergarten classroom	WF-10132021-014323	1/27/2022	FT-FY22-01042022-014323-A	<1	FT-FY22-01042022-014323-B	<1	
WS-014324	5/10/2021	5/10/2022	1	Combo Fountain	In room 112 kindergarten classroom	WF-05102021-014324	1/27/2022	FT-FY22-01042022-014324-A	<1	FT-FY22-01042022-014324-B	<1	
WS-014326	5/10/2021	5/10/2022	1	Combo Fountain	In room 113 Makerspace	WF-05102021-014326	1/27/2022	FT-FY22-01042022-014326-A	<1	FT-FY22-01042022-014326-B	<1	
WS-014327	5/10/2021	5/10/2022	1	Bottle Filler	In hallway adjacent to 113 makerspace	WF-05102021-014327	1/27/2022	FT-FY22-01042022-014327-A	<1	FT-FY22-01042022-014327-B	<1	
WS-014328	5/10/2021	5/10/2022	1	Cooler	In hallway adjacent to 113 makerspace	High Left	WF-05102021-014328	1/27/2022	FT-FY22-01042022-014328-A	<1	FT-FY22-01042022-014328-B	<1
WS-014329	5/10/2021	5/10/2022	1	Cooler	In hallway adjacent to 113 makerspace	Low Right	WF-05102021-014329	1/27/2022	FT-FY22-01042022-014329-A	<1	FT-FY22-01042022-014329-B	<1
WS-014332	5/10/2021	5/10/2022	1	Combo Fountain	In room 117 1st grade classroom	WF-05102021-014332	1/27/2022	FT-FY22-01042022-014332-A	<1	FT-FY22-01042022-014332-B	<1	
WS-014334	5/10/2021	5/10/2022	1	Combo Fountain	In room 118 speech classroom	WF-05102021-014334	1/27/2022	FT-FY22-01042022-014334-A	<1	FT-FY22-01042022-014334-B	<1	
WS-014336	5/10/2021	5/10/2022	1	Combo Fountain	In room 119 1st grade classroom	WF-05102021-014336	1/27/2022	FT-FY22-01042022-014336-A	<1	FT-FY22-01042022-014336-B	<1	
WS-014338	5/10/2021	5/10/2022	1	Combo Fountain	In room 120 special education	WF-05102021-014338	1/27/2022	FT-FY22-01042022-014338-A	<1	FT-FY22-01042022-014338-B	<1	
WS-014340	5/10/2021	5/10/2022	1	Combo Fountain	In room 121 resource room	WF-05102021-014340	1/27/2022	FT-FY22-01042022-014340-A	<1	FT-FY22-01042022-014340-B	<1	
WS-014342	5/10/2021	5/10/2022	1	Combo Fountain	In room 123 special education	WF-05102021-014342	1/27/2022	FT-FY22-01042022-014342-A	<1	FT-FY22-01042022-014342-B	<1	
WS-014344	5/10/2021	5/10/2022	1	Combo Fountain	In room 124 special education	WF-05102021-014344	1/27/2022	FT-FY22-01042022-014344-A	<1	FT-FY22-01042022-014344-B	<1	
WS-014346	5/10/2021	5/10/2022	1	Combo Fountain	In room 129 special education	WF-05102021-014346	1/27/2022	FT-FY22-01042022-014346-A	<1	FT-FY22-01042022-014346-B	<1	
WS-014349	5/10/2021	5/10/2022	1	Combo Fountain	In room 130 project science	WF-05102021-014349	1/27/2022	FT-FY22-01042022-014349-A	<1	FT-FY22-01042022-014349-B	<1	
WS-014350	5/10/2021	5/10/2022	1	Bottle Filler	In hallway adjacent to 130 project science	WF-05102021-014350	1/27/2022	FT-FY22-01042022-014350-A	<1	FT-FY22-01042022-014350-B	<1	
WS-014351	5/10/2021	5/10/2022	1	Cooler	In hallway adjacent to 130 project science	High Left	WF-05102021-014351	1/27/2022	FT-FY22-01042022-014351-A	<1	FT-FY22-01042022-014351-B	<1
WS-014352	5/10/2021	5/10/2022	1	Cooler	In hallway adjacent to 130 project science	Low Right	WF-05102021-014352	1/27/2022	FT-FY22-01042022-014352-A	<1	FT-FY22-01042022-014352-B	<1
WS-014355	5/10/2021	5/10/2022	2	Break Room	In room 201 staff lounge	WF-05102021-014355	1/27/2022	FT-FY22-01042022-014355-A	<1	FT-FY22-01042022-014355-B	<1	
WS-014356	5/10/2021	5/10/2022	2	Break Room	In room 203 teacher collaboration	WF-05102021-014356	1/27/2022	FT-FY22-01042022-014356-A	2.1	FT-FY22-01042022-014356-B	<1	

WS-014358	5/10/2021	5/10/2022	2	Combo Fountain	In room 205 3rd grade classroom	WF-05102021-014358	1/27/2022	FT-FY22-01042022-014358-A	1.6	FT-FY22-01042022-014358-B	<1
WS-014359	5/10/2021	5/10/2022	2	Bottle Filler	In hallway adjacent to 205 3rd grade classroom	WF-05102021-014359	1/27/2022	FT-FY22-01042022-014359-A	<1	FT-FY22-01042022-014359-B	<1
WS-014360	5/10/2021	5/10/2022	2	Cooler	In hallway adjacent to 205 3rd grade classroom High Left	WF-05102021-014360	1/27/2022	FT-FY22-01042022-014360-A	<1	FT-FY22-01042022-014360-B	<1
WS-014361	5/10/2021	5/10/2022	2	Cooler	In hallway adjacent to 205 3rd grade classroom Low Right	WF-05102021-014361	1/27/2022	FT-FY22-01042022-014361-A	<1	FT-FY22-01042022-014361-B	<1
WS-014363	5/10/2021	5/10/2022	2	Combo Fountain	In room 210 3rd grade classroom	WF-05102021-014363	1/27/2022	FT-FY22-01042022-014363-A	<1	FT-FY22-01042022-014363-B	<1
WS-014365	5/10/2021	5/10/2022	2	Combo Fountain	In room 211 4th grade classroom	WF-05102021-014365	1/27/2022	FT-FY22-01042022-014365-A	<1	FT-FY22-01042022-014365-B	<1
WS-014367	5/10/2021	5/10/2022	2	Combo Fountain	In room 217 4th grade classroom	WF-05102021-014367	1/27/2022	FT-FY22-01042022-014367-A	<1	FT-FY22-01042022-014367-B	<1
WS-014369	5/10/2021	5/10/2022	2	Combo Fountain	In room 218 5th grade classroom	WF-05102021-014369	1/27/2022	FT-FY22-01042022-014369-A	<1	FT-FY22-01042022-014369-B	<1
WS-014371	5/10/2021	5/10/2022	2	Combo Fountain	In room 223 5th grade classroom	WF-05102021-014371	1/27/2022	FT-FY22-01042022-014371-A	<1	FT-FY22-01042022-014371-B	<1
WS-014373	5/10/2021	5/10/2022	2	Combo Fountain	In room 224 library	WF-05102021-014373	1/27/2022	FT-FY22-01042022-014373-A	<1	FT-FY22-01042022-014373-B	<1
WS-014375	5/10/2021	5/10/2022	2	Bottle Filler	In hallway adjacent to C201 storage corridor	WF-05102021-014375	1/27/2022	FT-FY22-01042022-014375-A	<1	FT-FY22-01042022-014375-B	<1
WS-014376	5/10/2021	5/10/2022	2	Cooler	In hallway adjacent to C201 storage corridor High Left	WF-05102021-014376	1/27/2022	FT-FY22-01042022-014376-A	<1	FT-FY22-01042022-014376-B	<1
WS-014377	5/10/2021	5/10/2022	2	Cooler	In hallway adjacent to C201 storage corridor Low Right	WF-05102021-014377	1/27/2022	FT-FY22-01042022-014377-A	<1	FT-FY22-01042022-014377-B	<1
WS-014381	5/10/2021	5/10/2022	1	Break Room	In workroom 134	WF-05102021-014381	1/27/2022	FT-FY22-01042022-014381-A	<1	FT-FY22-01042022-014381-B	<1
WS-014383	5/10/2021	5/10/2022	1	Break Room	In parent resource 144	WF-05102021-014383	1/27/2022	FT-FY22-01042022-014383-A	<1	FT-FY22-01042022-014383-B	<1
WS-014384	5/10/2021	5/10/2022	1	Health Suite	In health suite in treatment room 150E	WF-05102021-014384	1/27/2022	FT-FY22-01042022-014384-A	<1	FT-FY22-01042022-014384-B	<1
WS-014386	5/10/2021	5/10/2022	1	Cooler	In hallway between restrooms 145 and 146 High Left	WF-05102021-014386	1/27/2022	FT-FY22-01042022-014386-A	<1	FT-FY22-01042022-014386-B	<1
WS-014387	5/10/2021	5/10/2022	1	Cooler	In hallway between restrooms 145 and 146 Low Right	WF-05102021-014387	1/27/2022	FT-FY22-01042022-014387-A	<1	FT-FY22-01042022-014387-B	<1
WS-014388	5/10/2021	5/10/2022	1	Bottle Filler	In cafeteria	WF-05102021-014388	1/27/2022	FT-FY22-01042022-014388-A	<1	FT-FY22-01042022-014388-B	<1
WS-014389	5/10/2021	5/10/2022	1	Cooler	In cafeteria High Left	WF-05102021-014389	1/27/2022	FT-FY22-01042022-014389-A	<1	FT-FY22-01042022-014389-B	<1
WS-014390	5/10/2021	5/10/2022	1	Cooler	In cafeteria Low Right	WF-05102021-014390	1/27/2022	FT-FY22-01042022-014390-A	<1	FT-FY22-01042022-014390-B	<1
WS-014402	5/10/2021	5/10/2022	2	Combo Fountain	In classroom 231	WF-05102021-014402	1/27/2022	FT-FY22-01042022-014402-A	<1	FT-FY22-01042022-014402-B	<1
WS-014404	5/10/2021	5/10/2022	2	Combo Fountain	In classroom 232	WF-05102021-014404	1/27/2022	FT-FY22-01042022-014404-A	2.5	FT-FY22-01042022-014404-B	<1
WS-014407	5/10/2021	5/10/2022	2	Combo Fountain	In classroom 234	WF-05102021-014407	1/27/2022	FT-FY22-01042022-014407-A	1.0	FT-FY22-01042022-014407-B	<1
WS-014409	5/10/2021	5/10/2022	2	Combo Fountain	In classroom 235	WF-05102021-014409	1/27/2022	FT-FY22-01042022-014409-A	2.1	FT-FY22-01042022-014409-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014397	2/22/2021	2/22/2022	1	Food Prep Sink	In kitchen second clockwise from entry	WF-02222021-014397	1/27/2022	FT-FY22-01042022-014397-A	<1	FT-FY22-01042022-014397-B	<1

FY22 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-014379	5/10/2021	5/10/2022	2	Combo Fountain	In room 226 special education	WF-05102021-014379	1/27/2022	FT-FY22-01042022-014379-A	9.5	FT-FY22-01042022-014379-B	<1